

**From:** Peter Warren pdw@warrenconstructiongroup.com  
**Subject:** Re: Grease Interceptor  
**Date:** April 11, 2014 at 5:15 PM  
**To:** Frank Brancely FJB@portlandmaine.gov  
**Cc:** Benjamin Pearson BNP@portlandmaine.gov, Bradley Roland BRAD@portlandmaine.gov, David Margolis-Pineo DMP@portlandmaine.gov, Helen Donaldson HCD@portlandmaine.gov, Nelle Hanig NRH@portlandmaine.gov, Rachelle Curran Apse rachellecturran@gmail.com, Robin Tannenbaum robin@kaplanthompson.com

---

Frank,  
Thank you for clearing this issue up.  
We will get moving on co ordination of this work so that the trade permit applications are clear as they are applied for.  
Regards, Peter

On Fri, Apr 11, 2014 at 4:47 PM, Frank Brancely <[FJB@portlandmaine.gov](mailto:FJB@portlandmaine.gov)> wrote:

Good Afternoon Mr. Warren,

You are good to go with the Schier "Great Basin" grease interceptor, model #GB-250, buried application beneath the foundation slab, of the proposed Portland Food Co-op, at 290 Congress Street. Be sure to plumb the mop sink to the grease interceptor, too.

Frank Brancely,  
Senior Engineering Technician,  
Department of Public Services,  
55 Portland Street,  
Portland, Maine 04101-2991  
[\(207\) 874-8832](tel:(207)874-8832) (phone),  
[\(207\) 874-8852](tel:(207)874-8852) (fax),  
<[fjb@portlandmaine.gov](mailto:fjb@portlandmaine.gov)>

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.

--  
Peter Warren  
Warren Construction Group  
PO Box 362  
South Freeport, Maine 04078  
207-865-3522  
207-865-3903 fax  
[pdw@warrenconstructiongroup.com](mailto:pdw@warrenconstructiongroup.com)