

From: Frank Brancely <fjb@portlandmaine.gov>
Date: May 31, 2016 at 11:30:47 AM EDT
To: whitten@cumberlandcounty.org
Cc: JFourni2@maine.rr.com, Rachel Smith <rms@portlandmaine.gov>
Subject: 142 Federal Street, "Anthony's Cafe"

Good Morning Mr. Whitten,

The Department of Public Works will permit a *twenty-five gallon per minute* passive grease interceptor to be installed, in "Anthony's Cafe" space, instead of an Automatic Grease Removal Unit, as originally proposed, by Mr. Bartrasso.

Keep in mind that any change of Food Service Establishment ownership, in the future, will subject the new owners to review of the grease interceptor, in light of their proposed business activities. This could result in an upgrade of the grease interceptor to an Automatic Grease Removal Unit.

Attached, please find several *twenty-five gallon per minute* passive grease interceptors acceptable, for "Anthony's Cafe," 142 Federal Street.

Frank Brancely,
Senior Engineering Technician,
Department of Public Works,
55 Portland Street,
Portland, Maine 04101-2991
[\(207\) 874-8832](tel:(207)874-8832) (phone),
[\(207\) 874-8852](tel:(207)874-8852) (fax),
<fjb@portlandmaine.gov>