

**... Fire Protection by Computer Design**

Dean & Allyn, Inc.  
116 Lewiston Road  
Gray, ME 04039  
(207) 657-5646

Job Name : 96 Federal Street  
Drawing :  
Location : 96 Federal Street, Portland, ME 04101  
Remote Area : Second Floor  
Contract : C161372  
Data File : Second Floor.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 96 FEDERAL STREET Date - 3/30/2017  
Location - 96 Federal Street, Portland, ME 04101  
Building - System No. - Second Floor  
Contractor - Dean & Allyn, Inc. Contract No. - C161372  
Calculated By - Chris Stewart Drawing No. - 1 of 1  
Construction: (X) Combustible ( ) Non-Combustible Ceiling Height ~9'-0"  
OCCUPANCY - Residential

S Type of Calculation: ( )NFPA 13 Residential (X)NFPA 13R ( )NFPA 13D  
Y Number of Sprinklers Flowing: ( )1 ( )2 (X)4 ( )  
S ( )Other  
T ( )Specific Ruling Made by Date  
E  
M Listed Flow at Start Point - 13 Gpm System Type  
Listed Pres. at Start Point - 9.1 Psi (X) Wet ( ) Dry  
D MAXIMUM LISTED SPACING 20 x 20 ( ) Deluge ( ) PreAction  
E Domestic Flow Added - Gpm Sprinkler or Nozzle  
S Additional Flow Added - Gpm Make Reliable Model RFC 43  
I Elevation at Highest Outlet - 26.35Feet Size 3/8" K-Factor 4.3  
G Note:\*36.21psi Safety Margin Temperature Rating 155F  
N

Calculation Gpm Required 59.30 Psi Required 58.78 At Test  
Summary C-Factor Used: Overhead 120 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:  
A Date of Test - OCT 2016 Rated Cap. Cap.  
T Time of Test - @ Psi Elev.  
E Static (Psi) - 95 Elev.  
R Residual (Psi) - 91 Other Well  
Flow (Gpm) - 1519 Proof Flow Gpm  
S Elevation - 1.5

P Location: 35' down street from 96 Federal Street

P  
L Source of Information: Portland Water District  
Y


# Water Supply Curve C

Dean & Allyn, Inc.  
96 Federal Street

Page 2  
Date 3/30/2017

City Water Supply:  
C1 - Static Pressure : 95  
C2 - Residual Pressure: 91  
C2 - Residual Flow : 1519

Demand:  
D1 - Elevation : 10.763  
D2 - System Flow : 59.299  
D2 - System Pressure : 58.778  
Hose ( Demand ) : \_\_\_\_\_  
D3 - System Demand : 59.299  
Safety Margin : 36.212



# Fittings Used Summary

Dean & Allyn, Inc.  
96 Federal Street

Page 3  
Date 3/30/2017

## Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24	
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65						
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
Zca	Colt C200 Horz Butt	Fitting generates a Fixed Loss Based on Flow																				

## Units Summary

Diameter Units           Inches  
 Length Units             Feet  
 Flow Units                US Gallons per Minute  
 Pressure Units           Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

Dean & Allyn, Inc.  
96 Federal Street

Page 4  
Date 3/30/2017

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
201	26.35	4.3	9.14	na	13.0	0.05	260	9.1
202	26.35	4.3	9.49	na	13.25	0.05	260	9.1
20	26.64		10.93	na				
21	26.64		13.26	na				
203	26.35	4.3	13.49	na	15.79	0.05	260	9.1
22	26.64		15.23	na				
204	26.35	4.3	16.11	na	17.26	0.05	260	9.1
23	26.64		17.26	na				
24	26.64		23.69	na				
25	26.64		26.56	na				
13	5.42		43.18	na				
TR	5.42		44.75	na				
BR	1.0		51.84	na				
FF	-6.0		61.94	na				
UG1	-6.0		62.02	na				
TEST	1.5		58.78	na				

The maximum velocity is 15.61 and it occurs in the pipe between nodes 203 and 22

# Final Calculations - Hazen-Williams - 2007

Dean & Allyn, Inc.  
96 Federal Street

Page 5  
Date 3/30/2017

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
201 to 202	26.350 26.350	4.30	13.00 13.0	1 1.049	E	2.0 0.0	4.000 2.000 6.000	120 0.0587	9.140 0.0 0.352		Vel = 4.83	
202 to 20	26.350 26.640	4.30	13.25 26.25	1 1.049	E	2.0 0.0	5.250 2.000 7.250	120 0.2152	9.492 -0.126 1.560		Vel = 9.74	
20 to 21	26.640 26.640		0.0 26.25	1 1.049	T	5.0 0.0	5.830 5.000 10.830	120 0.2152	10.926 0.0 2.331		Vel = 9.74	
21 to 203	26.640 26.350		0.0 26.25	1 1.049		0.0 0.0	0.500 0.0 0.500	120 0.2140	13.257 0.126 0.107		Vel = 9.74	
203 to 22	26.350 26.640	4.30	15.79 42.04	1 1.049		0.0 0.0	3.620 0.0 3.620	120 0.5144	13.490 -0.126 1.862		Vel = 15.61	
22 to 204	26.640 26.350		0.0 42.04	1.25 1.38		0.0 0.0	5.580 0.0 5.580	120 0.1353	15.226 0.126 0.755		Vel = 9.02	
204 to 23	26.350 26.640	4.30	17.26 59.3	1.25 1.38		0.0 0.0	5.000 0.0 5.000	120 0.2556	16.107 -0.126 1.278		Vel = 12.72	
23 to 24	26.640 26.640		0.0 59.3	1.25 1.38	T	6.0 0.0	19.160 6.000 25.160	120 0.2556	17.259 0.0 6.431		Vel = 12.72	
24 to 25	26.640 26.640		0.0 59.3	1.25 1.38	T	6.0 0.0	5.220 6.000 11.220	120 0.2556	23.690 0.0 2.868		Vel = 12.72	
25 to 13	26.640 5.420		0.0 59.3	1.5 1.61	2E 2T	8.0 16.0	37.600 24.000 61.600	120 0.1207	26.558 9.190 7.433		Vel = 9.35	
13 to TR	5.420 5.420		0.0 59.3	1.5 1.61	2E	8.0 0.0	5.000 8.000 13.000	120 0.1207	43.181 0.0 1.569		Vel = 9.35	
TR to BR	5.420 1		0.0 59.3	2.5 2.469	S Fsp I	14.0 0.0 6.0	3.000 20.000 23.000	120 0.0150	44.750 6.744 0.346	** Fixed Loss = 4.83	Vel = 3.97	
BR to FF	1 -6		0.0 59.3	2.5 2.469	Zca I	0.0 6.0	1.000 6.000 7.000	120 0.0150	51.840 9.998 0.105	** Fixed Loss = 6.967	Vel = 3.97	
FF to UG1	-6 -6		0.0 59.3	4 4.1	T	29.067 0.0	50.000 29.067 79.067	140 0.0010	61.943 0.0 0.076		Vel = 1.44	
UG1 to TEST	-6 1.5		0.0 59.3	8 8.27	3T E	166.063 28.468	35.000 194.531 229.531	140 0	62.019 -3.248 0.007		Vel = 0.35	
TEST			0.0 59.30						58.778		K Factor = 7.73	