

RISE/SMV SYMBOL	DESCRIPTION	CATALOG #
FACP	Fire Alarm Control Panel	EST 1050RD
FAA	Remote Annunciator	RALD-CR
FAU	Remote Annunciator	RALD-CR
BFSS	Backup Power Supply	BR-910A
F	Addressable Manual Station	SIQA-278
F <sub>MAN</sub>	Conventional Weatherproof Manual station	MP-912-249W-DE
F <sub>INT</sub>	Addressable Smoke Detector w/ Base (ER indicates elevator indicator)	SIQA-510
F <sub>INT</sub>	Addressable Duct Smoke Detector	SIQA-510
F <sub>INT</sub>	Addressable Heat Detector w/ Base	SIQA-518
F <sub>INT</sub>	Carbon Monoxide Detector	SD-7TRK
C9	Carbon Monoxide Detector	CO122RT
FR1	Remove Test Switch	PR1
FR1	Multi-Voltage Relay	SIQA-CTR
FR1	Addressable Input Module (T denotes single or double input)	SIQA-CTR
FR1	Addressable Control Module	SIQA-CR
FR1	Synchronization Module	SIQA-CTR
FR1	Smoke Unit (Adjustable Candle)	GF-F-4M
FR1	Smoke Unit (Adjustable Candle)	GF-F-4M
FR1	Smoke Unit (Adjustable Candle)	GF-F-4M
FR1	Low Frequency Horn Unit	GG4LFW-FH
FR1	Weather Proof Horn/Stroke Unit (Adjustable Candle)	79-24-1
FR1	Sprinkler Tamper Switch	F80
FR1	Weather Switch	F80
FR1	Magnetic Door Holder	F80

NFPA 720 (2009)  
Tables 6.5, 6.7.1, 6.1.2, & 6.7.3



LEGEND:

DWG NAME: FA-007  
**Luminato**  
**Portland, ME**  
**Floor Plan**  
**5th Floor**  
 DWG No: FA-007

**R.B. Allen**  
 Co., Inc.  
 P.O. BOX 770  
 131 LAFAYETTE RD  
 NO. HAMPTON, NH 03862  
 1-800-256-7264



EDWARDS SYSTEM TECHNOLOGY

JOB NAME:  
**Luminato**  
**Portland, Maine**  
**Floor Plan**  
**5th Floor**  
 Contractor:  
**Deblois Electric, Inc.**

SCALE: 1/8" = 1'0"

PO No. 91348	Luminato	Portland, ME	5th Floor	DWG No. FA-007
0	Original Issue	1/17	ENH	TRD
REV.	DESCRIPTION	DATE	DRWN:	RW'D: