

iO500RD Addressable Fire Alarm System
Luminato
Portland, Maine

System Narrative

In the event of an alarm from an actuated device, the following shall occur: (Devices reporting an alarm: Manual Station, Smoke Detector, Heat Detector, Water Flow Switch, Carbon Monoxide Detector)

- 1) Notify Portland Fire Department via Radio Master Box.
- 2) Notify Central Station via Digital Communicator (DACT)
- 2) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel.
- 3) Sound a Code 3 Temporal on all Horn Circuits
- 4) Flash all strobe appliance circuits in a synchronized manner

In the event of a supervisory condition from an actuated device, the following shall occur: (Devices reporting an Supervisory: Sprinkler Tamper Switch)

- 1) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel.
- 2) Notify Central Station via Digital Communicator (DACT)

In the event of a system trouble report, the following shall occur:

- 1) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel.