



1 FOUNDATION PLAN (BASEMENT LEVEL)
3/16" = 1'-0"

- FOUNDATION NOTES:
- FOR TYPICAL DETAILS & GENERAL NOTES SEE DRAWING S201 THRU S205.
 - FOR SLAB ELEVATION SEE PLAN.
 - F... INDICATES FOOTING MARK. FOR FOOTING SIZES & REINFORCING SEE FOOTING SCHEDULE ON THIS DRAWING.
 - P... INDICATES PIER TYPE. FOR DETAILS AND SCHEDULE SEE DRAWING S301.
 - C... INDICATES COLUMN MARK. FOR SIZES SEE COLUMN SCHEDULE ON DRAWING S301.
 - BOTTOM OF EXTERIOR FOOTING SHALL BE -4'-0" FROM REFERENCE SLAB ELEVATION UNLESS NOTED THUS: (...).
 - TOP OF EXTERIOR WALL (TOW) SHALL BE AS NOTED ON PLAN. NOTED THUS: "TOW EL."
 - TOP OF EXTERIOR PIER AND TOP OF EXTERIOR WALL PIERS SHALL BE AS NOTED THUS: (...).
 - TOP OF INTERIOR PIERS SHALL BE AS NOTED THUS: (...).
 - (----) INDICATES BOTTOM OF FOOTING ELEVATION.
 - (...>) INDICATES TOP OF PIER ELEVATION.
 - (T/F...) INDICATES TOP OF FOOTING ELEVATION.
 - ALL EXPOSED CONCRETE TO BE "RUBBED" FINISH.
 - FOR FLOOR DRAIN ELEVATIONS, SLAB DEPRESSIONS AND SLOPING CONCRETE FLOORS SEE ARCHITECTURAL DRAWINGS.
 - FOR DIMENSIONS & SLOPES OF LOADING DOCKS, RAMPS & SIDEWALKS SEE ARCHITECTURAL DRAWINGS.

- FOR ELEVATIONS OF FOUNDATION WALL PENETRATIONS SEE MECHANICAL AND CIVIL DRAWINGS. SEE DRAWING S202 FOR TYPICAL FOOTING DETAIL AT PIPE SLEEVES.
- THE GENERAL CONTRACTOR SHALL COORDINATE DEPTH OF ALL SLAB DEPRESSIONS SHOWN ON PLANS.
- PROVIDE #5 DOWEL X 5'-0" LG. TO MATCH SPACING OF MASONRY WALL REINFORCING.
- F.D. INDICATES FLOOR DRAINS. COORDINATE LOCATION WITH CIVIL DRAWINGS.
- THE EXTERIOR WALL FOOTINGS HAVE BEEN DROPPED AT LOCATIONS OF SEWERS, DRAINS, GAS LINES AND WATERLINES. THE TOP OF FOOTING IS SET AT 6 INCHES PLUS/MINUS LOWER THAN THE PIPE INVERT ELEVATION. THE GENERAL CONTRACTOR SHALL NOTIFY THE ENGINEER IF STEPPED FOOTINGS ARE NOT LOCATED AT EXTERIOR WALL PIPE PENETRATIONS.
- FOR LOCATION AND EXTENT OF FOUNDATION INSULATION SEE ARCHITECTURAL DRAWINGS.
- FOR ADDITIONAL FOUNDATION WALL DIMENSIONS SEE DRAWING S100A.

FOOTING SCHEDULE-1.5 TSF		
MARK	FOOTING SIZE	REINFORCING
F3.0	3'-0"x3'-0"x1'-0"	4-#4 EMB
F3.5	3'-6"x3'-6"x1'-0"	5-#4 EMB
F4.0	4'-0"x4'-0"x1'-0"	5-#4 EMB
F4.5	4'-6"x4'-6"x1'-0"	6-#4 EMB
F5.0	5'-0"x5'-0"x1'-0"	6-#5 EMB
F5.5	5'-6"x5'-6"x1'-1"	7-#5 EMB
F6.0	6'-0"x6'-0"x1'-2"	8-#5 EMB
F6.5	6'-6"x6'-6"x1'-4"	7-#6 EMB
F7.0	7'-0"x7'-0"x1'-5"	7-#6 EMB
F7.5	7'-6"x7'-6"x1'-6"	7-#7 EMB
F8.0	8'-0"x8'-0"x1'-7"	8-#7 EMB
F8.5	8'-6"x8'-6"x1'-8"	9-#7 EMB
F9.0	9'-0"x9'-0"x1'-9"	11-#7 EMB
F9.5	9'-6"x9'-6"x1'-10"	9-#8 EMB
F10.0	10'-0"x10'-0"x2'-0"	13-#7 EMB
F10.5	10'-6"x10'-6"x2'-1"	11-#8 EMB
F11.0	11'-0"x11'-0"x2'-2"	12-#8 EMB
F11.5	11'-6"x11'-6"x2'-4"	12-#8 EMB
F12.0	12'-0"x12'-0"x2'-10"	14-#8 EMB

Prepared For: **NewHeight Group**
118 Congress Street, Unit 401
Portland, Maine

Consulting Engineer: **VEITAS VEITAS** engineers
638 Granite Street, Suite 101
Business: Manchester, 02194
Tel: (603) 866-8868 Fax: (603) 866-2605

Architect: **ARCHETYPE** architects
48 Union Wharf Portland, Maine 04101
(207) 775-6022 ARCHETYPE@ARCHETYPEPA.COM

Project: **LUMINATO**
Newbury Street Portland, Maine

Date: **04/19/16** As indicated
Scale: **As indicated**

Revisions:
05/16/16 FOUNDATION PERMIT
06/07/16 80% REVIEW DRAWINGS
06/24/16 100% STRUCTURAL DRAWINGS
07/20/16 100% CONSTRUCTION DRAWINGS
08/05/16 ADDENDUM #A

FOUNDATION PLAN (BASEMENT LEVEL)