

POWER PRODUCTS
107 AUDOBON ROAD #10
WAKEFIELD, MA 01880

CUSTOMER:

Lumina

UNIT LOCATION:

109 Newbury St.

REFERENCE #

GENERATOR SET TEST REPORT

SHOP TEST

FIELD TEST

TIME IN MINUTES	0	15	30	45	60	75	90	105	120	135	150	165	180	195	210	225	240
AC VOLT	208	207	207	207	207	207	207	207	207								
	207	207	207	207	207	207	207	207	207								
AC AMPERAGE	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2								
	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2								
FREQUENCY	3-1	3-1	3-1	3-1	3-1	3-1	3-1	3-1	3-1								
CALCULATED KILOWATTS	60.1	60.1	60.1	60.1	60.1	60.1	60.1	60.1	60.1								
	59	58	58	58	58	58	58	58	58								
LUBE OIL PRESSURE PSI	82	49	38	37	37	37	37	37	37								
LUBE OIL TEMP °F																	
COOLANT TEMP °F	91	179	186	188	188	190	188	186	187								
FUEL PRESSURE PSI																	
FUEL LEVEL																	
AMBIENT TEMP. °F	69.5	100	105	103.0	104.5	110.0	111.5	113.0	114.5								

ENGINE MAKE: *Kohler*

ENGINE MODEL: *KD139077M*

ENGINE SERIAL #: *4630603540*

RATING: *60*

GEN MAKE: *Kohler*

/HOURS

KVA: *76*

GEN MODEL: *60RE02K*

GEN SPEC: *6M91435-6M3*

GEN SERIAL #: *SGM324Z25*

HZ: *60*

CREDIT CARD #

PHASE: *3*

T/SWITCH MODEL #

T/SWITCH SPEC#

WIRE: *12*

T/SWITCH SERIAL #

RPMs: *1800*

VOLT: *120/208*

SERVICE RO #

FL AMPS AT UNITY PF: *208*

FL AMPS AT 0.8PF: *166*

TECHNICIAN NAME

David Open

(Print)

CUSTOMER NAME

Alexander J. Carter

(Print)

J. Carter

DATE: *8-22-17*

TECHNICIAN SIGNATURE

[Signature]

CUSTOMER SIGNATURE

[Signature]

DATE: *8-22-17*