## CITY OF PORTLAND DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street Portland, Maine 04101

## **Inspection Violations**

0	wner/Mana	aer		Inspector		Inspection Date		
INDIA STREET PROPERTIES LLC				Suzanne Hunt		2/14/2008		
Locatation CBL			Status		Inspection Type			
78	INDIA ST		028 J006001	Re-Inspect 30 Days		Complaint-Inspection		
	Code	Int/Ext		Floor	Unit No.	Area	Compliance Date	
1)	6-108.c	Exterior		1		Entry Way		
	Violation:	Exterior wind	lows, doors and sky	s, doors and skylights				
	Notes: Exterior doors and windows must be weathertight and in good repair. The door is not weather							
2)	6-108.c Interior		1	Various locations				
	Violation:	Exterior wind	lows, doors and sky	kylights				
	<b>Notes:</b> Windows in unit have broken and missing sash cords. All windows must be in good repair ar weathertight.							
3)	6-108.a	Exterior		roof				
	Violation:	Foundations cellars, exterior walls, roofs						
<b>Notes:</b> water from roofs shall be drained so as not to cause hazard. The gutters repaired and or replaced to insure the safety of residents from ice and water the safety of residents from ice and							building must be	
Comments:		missing gutter above exit from unit. Water dripping directly on egress route. Evidence of ice having fallen there. Primary exit door is not weather tight, outside visible by door jamb . Several windows in apartment have missing/broken window weight ropes.						