GENERAL NOTES:
1. HANDRAILS SHALL EXTEND 12" MIN AT TOP OF STAIR AND 1 TREAD DEPTH AT THE BOTTOM, TYP
2. ALL HANDRAILS SHALL BE 1-1/2" DIAMETER AND PROJECT 1-1/2" FROM HE ADJACENT SURFACE, TYP
3. ALL STAIR RISERS SHALL BE CLOSED AND NOSINGS SHALL NOT EXCEED 3/8"

1 STAIR ST02 SECTION + DETAILS
1/4" = 1'-0"

GENERAL NOTES:
1. HANDRAILS SHALL EXTEND 12" MIN AT TOP OF STAIR AND 1 TREAD DEPTH AT THE BOTTOM, TYP
2. ALL HANDRAILS SHALL BE 1-1/2" DIAMETER AND PROJECT 1-1/2" FROM HE ADJACENT SURFACE, TYP
3. ALL STAIR RISERS SHALL BE CLOSED AND NOSINGS SHALL NOT EXCEED 3/8"

2 STAIR EX01 SECTION + DETAILS
1/4" = 1'-0"

9 EXTERIOR STAIR PLAN
1/4" = 1'-0"

8 FOURTH FLOOR STAIR PLAN
1/4" = 1'-0"

7 THIRD FLOOR STAIR PLAN
1/4" = 1'-0"

6 SECOND FLOOR STAIR PLAN
1/4" = 1'-0"

5 FIRST FLOOR STAIR PLAN
1/4" = 1'-0"

3 SOUTH ELEVATION
1/8" = 1'-0"

4 EAST ELEVATION
1/8" = 1'-0"

Reviewed for Code Compliance
Inspections Division
Portland, Maine

Date: 08/31/17

LICENSED ARCHITECT
Matthew Ahlberg
4401
STATE OF MAINE

REVISIONS:
2017.8.31 | CODE REVIEW UPDATES 4TH FLOOR BR
2017.8.28 | CODE REVIEW UPDATES
2017.8.24 | CODE REVIEW UPDATES
2017.7.5 | CANOPY REMOVED

33 HAMPSHIRE STREET
ELEVATIONS + DETAILS

DRAWING TITLE:
A.301

PROJECT NAME:
RENOVATIONS AND ALTERATIONS
33 HAMPSHIRE STREET
PORTLAND, MAINE 04101

DATE OF ISSUE:
AUGUST 31, 2017

ISSUED FOR:
PERMIT SET

SCALE:
AS NOTED

THIS DRAWING IS THE PROPERTY OF BARRETT MADE AND IS NOT TO BE COPIED OR REPRODUCED IN THE SOLE OF WHOLE. 2017 © BARRETT MADE

BARRETT MADE
HOMES · SPACES · DETAILS