WALL LEGEND

EXISTING WALL	
NEW WALL	
FIRE RATED WALL	
BRICK WALL	
1 HOUR	
EXISTING WALL TO BE REMOVED	

1ST FLOOR PLAN - 1 TENANT SCHEME

1/8"=1'-0"

1ST FLOOR PLAN - 2 TENANT SCHEME

1/8"=1'-0"

PROPOSED WALL - INTERIOR

1 6" METAL WALL - (1HR RATED)
(UL DESIGN: U 419sim.) FIRE CAULK PERIMETER

- EXTEND WALL TO UNDERSIDE OF FLOOR SYSTEM ABOVE -

* INSTALL ALL MATERIALS PER MANUFACTURE REQUIREMENTS

PROPOSED WALL - INTERIOR

2 6" METAL WALL - (1HR RATED)
(UL DESIGN: U 419) FIRE CAULK PERIMETER

- EXTEND WALL TO UNDERSIDE OF FLOOR SYSTEM ABOVE -

* INSTALL ALL MATERIALS PER MANUFACTURE REQUIREMENTS

PROPOSED WALL - EXTERIOR

3 2x6 STUD WALL - (NON-RATED)
CAULK PERIMETER

* INSTALL ALL MATERIALS PER MANUFACTURE REQUIREMENTS

LIFE SAFETY LEGEND:

	EMERGENCY BACKUP LIGHT
EXIT	EXIT LIGHT
SD	SMOKE DETECTOR
SS/SD	SMOKE & CO DETECTOR, SINGLE STATION
SD W/ SB,CO	PHOTOELEC SMOKE W/ SOUNDER BASE AND CO DETECTOR
HD	HEAT & CO DETECTOR
	HORN/STROBE
	STROBE
FE	FIRE EXTINGUISHER IN RECESSED CABINET
P S	PULL STATION - SPRINKLER SYSTEM

LIFE SAFETY NOTES:

-LIFE SAFETY AND FIRE ALARM SYSTEMS SHALL BE DESIGNED AND INSTALLED PER NFPA 72, BY A CITY/ STATE APPROVED CONTRACTOR WITH A SEPERATE PERMIT.

-ALL STROBES TO BE 30 CANDELA UNLESS OTHERWISE NOTED.

-SYSTEM SHALL BE SUPERVISED BY AN OFF-SITE CERTIFIED BY THE CITY OF PORTLAND THIRD PARTY

-EXISTING LIFE SAFETY SYSTEM SHALL REMAIN, TYP EACH SIDE

EAST BROWN COW

BUILDING PERMIT SET: JULY 01, 2013

CITY OF PORTLAND, MAINE RESURGAM

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 08/23/13

MARK MUELLER ARCHITECTS
A.I.A.
100 Commercial Street
Suite 205
Portland, Maine 04101
Phone/Fax 207.774.9057
Email:
rfi@muellerarchitects.com

© COPYRIGHT 2013
MARK MUELLER ARCHITECTS

ENTRY DOOR VESTIBULE:

EMERY WATERHOUSE BLOCK

66 PEARL STREET
PORTLAND, MAINE

PROPOSED FLOOR PLAN

DATE	June 2013
PROJECT	66 PEARL ENTRY
DRAWN BY	MRP
CHECK BY	MLM

A-1.1