1 WALL MOUNTED CONDUIT DETAIL

E402 SCALE: NONE

2 CONDUIT DETAIL

E402 SCALE: NONE

3 CONDUIT DETAIL

E402 SCALE: NONE

4 CONDUIT AT METAL STUD WALL

E402 SCALE: NONE

5 RECEPTACLE LOCATION AT FLOATING WALL FIXTURES

E402 SCALE: NONE

6 DETAIL- CASHWRAP OUTLET LOCATIONS

E402 SCALE: 3/4"=1'-0" (SURFACE MOUNT ON CABINET)

1. ELECTRICAL CONTRACTOR SHALL FURNISH AND INSTALL 120/12 VOLT TRANSFORMER FOR OPERATION OF REAR DOORBELL. MOUNT TRANSFORMER ADJACENT TO PANEL. TRANSFORMER SHALL BE EDWARDS # 88-250 OR EQUIVALENT.
2. AT REAR DOOR, ELECTRICAL CONTRACTOR SHALL FURNISH AND INSTALL A DOORBELL PUSH-BUTTON SURFACE MOUNTED ON OUTSIDE OF ENTRY DOOR. MOUNT PUSH-BUTTON @ 4'-6" AFF. OR AS REQUIRED BY LANDLORD. PUSH-BUTTON SHALL BE EDWARDS #6600 OR EQUIVALENT.
3. BELL SHALL BE MOUNTED ON WALL AT 12'-0". USE EDWARDS # 6660 OR EQUIVALENT INSTALLED IN A WALL MOUNTED BOX WITH WHITE LOUVERED COVER PLATE.

7 DOORBELL DETAIL

E402 SCALE: NONE

8 OCCUPANCY SENSOR WIRING DIAGRAM

E402 SCALE: NONE

Date: 09/22/14

NewStudio Architecture

4431 Lake Avenue South
White Bear Lake, MN 55110

p: 651.207.5527 f : 651.207.8247

ANTHROPOLOGIE

60 Pearl Street
Portland, ME 04101

HALLBERG ENGINEERING
Mechanical/Electrical Consulting Engineers
1750 Commerce Court, White Bear Lake, MN 55110
(651) 748-1100 - Fax (651) 748-8370

DRAWN BY: DJQ CHECKED BY: KLS/PJF

NSA PROJECT NUMBER: 2013-99

PROJECT PHASE: CD

HEI PROJECT NUMBER: R14-1941.000

ISSUE / DATE:

100% CHECKSET	07-11-2014
BID/PERMIT	08-01-2014

REVISION :

SHEET TITLE :

ELECTRICAL DETAILS

SHEET NO :

E402