



THIRD FLOOR FIRE ALARM PLAN
 SCALE: 1/8"=1'-0"

SHEET NOTES:

- ◇ PROVIDE HEAT DETECTOR(S) WITHIN 24" OF EACH SPRINKLER HEAD IN THE ELEVATOR CONTROL ROOM AND HOISTWAY(S). HEAT DETECTORS SHALL HAVE A LOWER TEMPERATURE RATING THAN THE SPRINKLERS IN THE AREA AND BE MONITORED FOR INTEGRITY.
- ◇ LOCATE DETECTORS AT TOP OF ELEVATOR HOISTWAY.

RESERVED FOR CITY STAMP

REVISION	DESCRIPTION	DATE
0	ISSUED FOR REVIEW & APPROVAL	9/26/2014
1	REMOVED 4TH FLR, CLIENT REVIEW	10/2/2014

CUNNINGHAM
Security Systems
 10 Princes Point Road, Yarmouth, Maine 04096
 Office: 207.846.3350 • Fax: 207.846.6080

66 PEARL STREET
 PORTLAND, MAINE 04101
THIRD FLOOR FIRE ALARM PLAN

UNIGAD Inc.
 Fire Alarm Design & Drafting Services
 5700 Exchange Blvd
 Suite 400
 Portland, ME 04103
 Phone: 207.846.6080
 Fax: 207.846.6080
 www.unigad.com

FA-5

DATE	9/26/2014
CHECKED	WYATT B. HARRIS NCEIT # 90496
DRAWN	JFB UNIGAD JOB #14555
REVISION	1
SCALE	1/8"=1'-0"