

May 8, 2007

Murray, Plumb & Murray
75 Pearl Street
Portland, ME 04104-5085

Simply Birkenstock
131 Middle Street
Portland, Me 04101

Cherry Pie Beauty and Lifestyle
127 Middle Street
Portland, Me 04101

Re: Demolition at 141 Middle Street (Attached garage at rear of building)

To whom it may concern,

This letter will serve as written notification, in accordance with the City Of Portland demolition permit application requirements, to the adjoining property owners of the upcoming garage demolition scheduled at rear of the property noted above. The work will commence as soon as the demolition permit has been issued by the City of Portland and arrangements have been made with City of Portland Public Works.


Sincerely,


A handwritten signature in black ink, appearing to read "Craig Hill".

Craig Hill
Assistant Project Manager

Building Maine's Great Spaces

Wright-Ryan Construction, Inc. • 10 Danforth Street • Portland, Maine 04101
Phone (207)773-3625 • Fax (207)773-5173 • www.wright-ryan.com







ENVIRONMENTAL SAFETY & HYGIENE ASSOCIATES, INC.

- Indoor Air Quality
- OSHA Compliance
- Asbestos Consulting
- Training
- Lead Consulting
- Industrial Hygiene

May 8, 2007

Craig Hill
Wright Ryan Construction
10 Danforth Street
Portland Maine 04101

Re: *Asbestos inspection at Howell Photography Garage, 75 Pearl Street, Portland Maine.*

Dear Mr. Hill:

Environmental Safety & Hygiene Associates Inc. (ESHA) is providing you with this asbestos inspection report for the visual inspection conducted on May 7, 2007 of suspect building materials that may contain asbestos prior to building demolition.

The garage that is to be demolished is a single story wood framed structure, plywood sheathing, corrugated metal roof, aluminum siding and was constructed in the mid 1980's.

No suspect building components were identified to be bulk sampled for asbestos content.

We appreciate the opportunity to service your asbestos testing needs, should you require further bulk or air quality sampling please feel free to contact us at any time.

Very truly,

Mark Griffeth
Asbestos Inspector AI-0230

Please call 874-8703 or 874-8693 to schedule your inspections as agreed upon

Permits expire in 6 months, if the project is not started or ceases for 6 months.

The Owner or their designee is required to notify the inspections office for the following inspections and provide adequate notice. Notice must be called in 48-72 hours in advance in order to schedule an inspection:

By initializing at each inspection time, you are agreeing that you understand the inspection procedure and additional fees from a "Stop Work Order" and "Stop Work Order Release" will be incurred if the procedure is not followed as stated below.

A Pre-construction Meeting will take place upon receipt of your building permit.

- _____ Footing/Building Location Inspection: Prior to pouring concrete
- _____ Re-Bar Schedule Inspection: Prior to pouring concrete
- _____ Foundation Inspection: Prior to placing ANY backfill
- _____ Framing/Rough Plumbing/Electrical: Prior to any insulating or drywalling
- 10 Final Certificate of Occupancy: Prior to any occupancy of the structure or use. ~~NOTE: There is a \$75.00 fee per inspection at this point.~~

Certificate of Occupancy is not required for certain projects. Your inspector can advise you if your project requires a Certificate of Occupancy. All projects DO require a final inspection

at If any of the inspections do not occur, the project cannot go on to the next phase, REGARDLESS OF THE NOTICE OR CIRCUMSTANCES.

NA CERTIFICATE OF OCCUPANCIES MUST BE ISSUED AND PAID FOR, BEFORE THE SPACE MAY BE OCCUPIED

<u>[Signature]</u>	<u>5/16/07</u>
Signature of Applicant/Designee	Date
<u>[Signature]</u>	<u>5-16-07</u>
Signature of Inspections Official	Date

CBL: 28 2005 Building Permit #: 070514