



Partition Type 3D is described on sheet A10 as (1) layer 5/8" GWB Type 'X' over 3 5/8" studs set 1/2" off of the face of existing 8" CMU. At this location, add (1) additional layer of 5/8" GWB Type 'X'.

The intent is for the completed assembly, inclusive of the CMU, to achieve a 2 hour rating for Stair 235.

See Sheets A9, A9.1 For Stair Details