

Jeff Levine, AICP, Director
Planning & Urban Development Department

Tammy Munson, Director
Inspections Division

Kitchen Exhaust System Checklist and Application

Dear Applicant,

The following is a checklist to assist you in filing for a permit for a Kitchen Exhaust system. Please complete this and submit job specific construction documents that demonstrate compliance.

1. Type of System:

Type I X Type II _____

Type I systems are systems that vent fryers, grills, broilers, ovens or woks.

Type II systems are systems that vent steamers and other non-grease producing appliances.

2. Type of Materials:

Is the hood Stainless steel or other type of steel? stainless steel

If other, what type? _____

Is the duct work Stainless steel or other type of steel? other

If other, what type? 16ga gauge galv steel

Thickness of the steel for the hood: 16ga Thickness of the duct for the hood: 16ga

Type of Hood and Duct Supports 3/8 thread rod from hood to roof truss

Type of seams and Joints welded

Grease Gutters provided? no Hood Clearance reduction to Combustibles design /specs:

18" of space above hood.

Duct Clearance reduction to Combustibles design /specs:

3m grease duct wrap on inside

Vibration Isolation System: N/A