



Department of Permitting and Inspections

Air Velocity within the duct system .75 fpm

Grease accumulation prevention system: N/A

Cleanouts: High temp door in each 10' and 90°

Grease Duct enclosure: 3m 615 Duct wrap

Exhaust Termination: Roof _____ Wall X

Fire Suppression System: Other

Exhaust fan mounting and clearance from the roof / wall or Combustibles:
18" Above roof and 56" Above roof fan

Exhaust fan distance from property lines: 10'

Exhaust fan distance from other vents or openings: 10'

Exhaust fan distance from adjacent buildings: 10'

Exhaust fan height above adjoining grade: 14'

3. Hood Specs

Style of Hood: Canopy

Type of Filter: Baffle Filters

Height of filter above nearest cooking surface: 36"

Capacity of hood CFM: 3900 CFM @ .75

Make up Air system description and capacity:
2500 CFM return in plenum box in front Hood mant make
up fan on roof