

. . . Fire Protection by Computer Design

EASTERN FIRE PROTECTION
170 KITTY HAWK AVE
AUBURN, ME 04210
207-784-1507

Job Name : 62 INDIA ST.
Drawing : 1 OF 3
Location : PORTLAND, ME.
Remote Area : 1
Contract : 5583-SP-17
Data File : 62 INDIA ST. DRY CALC..WXF

HYDRAULIC CALCULATIONS
for

Project name: 62 INDIA ST. DRY SYSTEM
Location: PORTLAND, ME.
Drawing no: 1 OF 3
Date: 6/9/17

Design

Remote area number: 1
Remote area location: PARKING GARGE
Occupancy classification: OHI
Density: .15 - Gpm/SqFt
Area of application: 2,048 - SqFt
Coverage per sprinkler: 130 - SqFt
Type of sprinklers calculated: RELIABLE F3QR SIN#R5714 DRY PENDENT
No. of sprinklers calculated: 19
In-rack demand: - GPM
Hose streams: 250 - GPM
Total water required (including hose streams): 694.345 - GPM @ 87.327 - Psi
Type of system: DRY
Volume of dry or preaction system: 310 - Gal

Water supply information

Date: 7/6/16
Location: NEWBURY ST. PORTLAND, ME.
Source: PORTLAND WATER DISTRICT

Name of contractor: EASTERN FIRE PROTECTION
Address: 170 KITTY HAWK AVE / / AUBURN, ME 04210
Phone number: 207-784-1507
Name of designer: EWM

Authority having jurisdiction: MAINE FIRE MARSHAL

Notes: (Include peaking information or gridded systems here.) REMOTE AREA INCREASED PER NFPA13 (2016) SEC. 11.2.3.2.5

Water Supply Curve C


EASTERN FIRE PROTECTION
62 INDIA ST.

City Water Supply:

C1 - Static Pressure : 95
C2 - Residual Pressure: 88
C2 - Residual Flow : 1582

Demand:

D1 - Elevation : 3.764
D2 - System Flow : 444.345
D2 - System Pressure : 87.327
Hose (Demand) : 250
D3 - System Demand : 694.345
Safety Margin : 6.148



Fittings Used Summary

EASTERN FIRE PROTECTION
62 INDIA ST.

Fitting Legend Abbrev. Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
Dge Dry Gem DPV-1							2.2	4.9		8.9		22								
E NFPA 13 90° Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I 90° Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
J 90° Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120
T NFPA 13 90° Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

- Diameter Units Inches
- Length Units Feet
- Flow Units US Gallons per Minute
- Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	95.0	88	1582.0	93.474	694.34	87.327

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
HEAD1	0.0	5.6	12.13	19.5	
1	43.19	5.3	21.83	24.76	K=K @ LIN1
2	43.19	5.3	22.59	25.19	K=K @ LIN1
3	43.19	5.3	28.21	28.14	K=K @ LIN1
5	43.19	5.3	13.54	19.5	K=K @ LIN1
6	44.08		13.91		
7	43.19	5.3	14.01	19.83	K=K @ LIN1
8	44.08		14.4		
9	43.19	5.3	15.32	20.74	K=K @ LIN1
10	44.08		15.96		
11	43.19	5.3	16.15	21.3	K=K @ LIN1
12	44.08		16.85		
13	43.19	5.3	23.53	25.71	K=K @ LIN1
4	44.08		45.87		
15	43.19	5.3	14.99	20.52	K=K @ LIN1
16	43.19	5.3	15.53	20.88	K=K @ LIN1
17	43.19	5.3	17.51	22.18	K=K @ LIN1
18	43.19	5.3	21.9	24.8	K=K @ LIN1
20	43.19	5.3	15.23	20.68	K=K @ LIN1
21	43.19	5.3	15.77	21.05	K=K @ LIN1
22	43.19	5.3	17.79	22.35	K=K @ LIN1
23	43.19	5.3	22.23	24.99	K=K @ LIN1
25	43.19	5.3	24.84	26.41	K=K @ LIN1
26	43.19	5.3	25.7	26.86	K=K @ LIN1
27	43.19	5.3	28.86	28.47	K=K @ LIN1
14	42.94		58.95		
19	42.94		59.06		
24	42.94		59.29		
28	42.94		59.62		
TOR2	42.565		72.33		
DPV	40.21		73.49		
HDR2	37.5		77.14		
BASE	34.5		86.74		
TEST	34.5		87.33	250.0	

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
HEAD1 to LIN1	0 0	5.60	19.50 19.5	1 1.049	2T 0.0	7.137 7.137	100 0.1740	12.125 0.0			
			0.0			8.137		1.416	Vel =	7.24	
LIN1			19.50					13.541	K Factor =	5.30	
1 to 2	43.190 43.190	5.3	24.76 24.76	1.25 1.442	0.0 0.0	13.330 0.0	100 0.0575	21.827 0.0	K = K @ LIN1		
						13.330		0.766	Vel =	4.86	
2 to 3	43.190 43.190	5.3	25.19 49.95	1.25 1.442	0.0 0.0	26.670 26.670	100 0.2105	22.593 0.0	K = K @ LIN1		
						26.670		5.613	Vel =	9.81	
3 to 4	43.190 44.080	5.3	28.14 78.09	1.25 1.442	3I T 0.0	7.956 5.304 0.0	24.250 13.260 37.510	100 -0.385 18.047	K = K @ LIN1		
			0.0					0.4811	Vel =	15.34	
4			78.09					45.868	K Factor =	11.53	
5 to 6	43.190 44.080	5.3	19.50 19.5	1 1.049	T 0.0	3.568 3.568	100 0.1739	13.541 -0.385	K = K @ LIN1		
						4.318		0.751	Vel =	7.24	
6 to 8	44.080 44.080		0.0 19.5	1.25 1.442	0.0 0.0	13.330 0.0	100 0.0369	13.907 0.0			
						13.330		0.492	Vel =	3.83	
8			0.0					14.399	K Factor =	5.14	
7 to 8	43.190 44.080	5.3	19.83 19.83	1 1.049	T 0.0	3.568 3.568	100 0.1792	14.010 -0.385	K = K @ LIN1		
						4.318		0.774	Vel =	7.36	
8 to 10	44.080 44.080		19.50 39.33	1.25 1.442	0.0 0.0	11.540 0.0	100 0.1354	14.399 0.0			
						11.540		1.562	Vel =	7.73	
10			0.0					15.961	K Factor =	9.84	
9 to 10	43.190 44.080	5.3	20.74 20.74	1 1.049	T 0.0	3.568 3.568	100 0.1950	15.317 -0.385	K = K @ LIN1		
						5.278		1.029	Vel =	7.70	
10 to 12	44.080 44.080		39.33 60.07	1.25 1.442	0.0 0.0	3.000 0.0	100 0.2960	15.961 0.0			
						3.000		0.888	Vel =	11.80	
12			0.0					16.849	K Factor =	14.63	
11 to 12	43.190 44.080	5.3	21.30 21.3	1 1.049	T 0.0	3.568 3.568	100 0.2046	16.154 -0.385	K = K @ LIN1		
						5.278		1.080	Vel =	7.91	
12 to 13	44.080 43.190		60.07 81.37	1.25 1.442	0.0 0.0	12.125 0.0	100 0.5193	16.849 0.385			
						12.125		6.296	Vel =	15.99	
13 to 4	43.190 44.080	5.3	25.71 107.08	1.25 1.442	3I 0.0	7.956 7.956	18.380 26.336	100 0.8628	23.530 -0.385	K = K @ LIN1	
						0.0		22.723	Vel =	21.04	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
62 INDIA ST.

Page 6
Date 6/9/17

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
4 to 14	44.080 42.940		78.09 185.17	2 2.157	I T 3.074 8.783 0.0	25.800 11.857 37.657	100 0.3344	45.868 0.494 12.592		Vel = 16.26	
14			0.0 185.17					58.954		K Factor = 24.12	
15 to 16	43.190 43.190	5.3	20.52 20.52	1.25 1.442	0.0 0.0 0.0	13.330 0.0 13.330	100 0.0406	14.990 0.0 0.541		K = K @ LIN1 Vel = 4.03	
16 to 17	43.190 43.190	5.3	20.88 41.4	1.25 1.442	0.0 0.0 0.0	13.330 0.0 13.330	100 0.1488	15.531 0.0 1.983		K = K @ LIN1 Vel = 8.13	
17 to 18	43.190 43.190	5.3	22.18 63.58	1.25 1.442	0.0 0.0 0.0	13.330 0.0 13.330	100 0.3290	17.514 0.0 4.385		K = K @ LIN1 Vel = 12.49	
18 to 19	43.190 42.940	5.3	24.80 88.38	1.25 1.442	4I T 10.608 5.304 0.0	45.340 15.912 61.252	100 0.6049	21.899 0.108 37.052		K = K @ LIN1 Vel = 17.36	
19			0.0 88.38					59.059		K Factor = 11.50	
20 to 21	43.190 43.190	5.3	20.68 20.68	1.25 1.442	0.0 0.0 0.0	13.330 0.0 13.330	100 0.0412	15.226 0.0 0.549		K = K @ LIN1 Vel = 4.06	
21 to 22	43.190 43.190	5.3	21.04 41.72	1.25 1.442	0.0 0.0 0.0	13.330 0.0 13.330	100 0.1509	15.775 0.0 2.011		K = K @ LIN1 Vel = 8.20	
22 to 23	43.190 43.190	5.3	22.35 64.07	1.25 1.442	0.0 0.0 0.0	13.330 0.0 13.330	100 0.3337	17.786 0.0 4.448		K = K @ LIN1 Vel = 12.59	
23 to 24	43.190 42.940	5.3	24.99 89.06	1.25 1.442	4I T 10.608 5.304 0.0	44.300 15.912 60.212	100 0.6136	22.234 0.108 36.948		K = K @ LIN1 Vel = 17.50	
24			0.0 89.06					59.290		K Factor = 11.57	
25 to 26	43.190 43.190	5.3	26.41 26.41	1.25 1.442	0.0 0.0 0.0	13.330 0.0 13.330	100 0.0647	24.837 0.0 0.863		K = K @ LIN1 Vel = 5.19	
26 to 27	43.190 43.190	5.3	26.86 53.27	1.25 1.442	0.0 0.0 0.0	13.330 0.0 13.330	100 0.2371	25.700 0.0 3.161		K = K @ LIN1 Vel = 10.47	
27 to 28	43.190 42.940	5.3	28.47 81.74	1.25 1.442	4I T 10.608 5.304 0.0	42.630 15.912 58.542	100 0.5236	28.861 0.108 30.653		K = K @ LIN1 Vel = 16.06	
28			0.0 81.74					59.622		K Factor = 10.59	
14 to 19	42.940 42.940		185.17 185.17	4 4.26	0.0 0.0 0.0	8.625 0.0 8.625	100 0.0122	58.954 0.0 0.105		Vel = 4.17	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
62 INDIA ST.

Page 7
Date 6/9/17

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
19 to 24	42.940 42.940		88.37 273.54	4 4.26		9.210 0.0 9.210	100 0.0251	59.059 0.0 0.231		Vel = 6.16	
24 to 28	42.940 42.940		89.06 362.6	4 4.26		7.875 0.0 7.875	100 0.0422	59.290 0.0 0.332		Vel = 8.16	
28 to TOR2	42.940 42.565		81.74 444.34	4 4.26	4I J 26.313 15.036 0.0	162.920 41.348 204.268	100 0.0614	59.622 0.162 12.543		Vel = 10.00	
TOR2 to DPV	42.565 40.210		0.0 444.34	4 4.26		2.355 0.0 2.355	100 0.0616	72.327 1.020 0.145		Vel = 10.00	
DPV to HDR2	40.210 37.500		0.0 444.34	4 4.26	Dge B T 11.719 15.8 26.334	2.710 53.853 56.563	120 0.0438	73.492 1.174 2.478		Vel = 10.00	
HDR2 to BASE	37.500 34.500		0.0 444.34	4 4.26		6.750 0.0 6.750	120 0.0439	77.144 9.299 0.296		** Fixed Loss = 8 Vel = 10.00	
BASE to TEST	34.500 34.500		0.0 444.34	6 6.16	E T G 20.084 43.037 4.304	40.000 67.425 107.425	140 0.0055	86.739 0.0 0.588		Vel = 4.78	
TEST			250.00 694.34					87.327		Qa = 250.00 K Factor = 74.30	