

Inspection Services
Michael J. Nugent
Manager



Housing & Neighborhood Services
Mark B Adelson
Director

CITY OF PORTLAND

November 2, 2001

Norman Jabar
47 Middle St.,
Portland, ME 04101

RE: Permit #01-1309 (028 P021)

Dear Norm,

With regard to your request for waiver of the 10' clearance above grade for the kitchen exhaust system for the above existing structure pursuant to Section 121.1 of the Building Code, this office grants the request to be at least 8' above grade, as there is practical difficulty in complying with this standard while providing 18" of clearance from combustibles and 36" of clearance from openings. Please contact this office when the system is opened up to allow the area inspector to view the wall penetration to insure clearance from combustibles.

Sincerely,

Mike Nugent
Manager of Inspection Services