CERTIFICATE OF FLAME RETARDANCE

ISSUED TO: MAINE BAY CANVAS INC.
53 INDUSTIRAL WAY
PORTLAND, ME 04103

NUMBER: 62010

DATE: 6/13/16

THIS CERTIFICATE OF COMPLIANCE IS ISSUED TO VERIFY THAT THE ITEMS OR AREAS DESCRIBED BELOW ON THIS CERTIFICATE HAVE BEEN TREATED WITH FLAME COAT™.

FLAME COAT™ IS A CLASS A FIRE RETARDANT.

Description of Material, Structure, etc.	
12	YARDS SUNBRELLA #4902 CAPTAIN NAVY TREATED WITH
	FLAMECOAT
	N.F.P.A. 701 SMALL SCALE, CLASS A. A.S.T.M.E-84,FLAME SPREAD:10 SMOKE DENSITY:25
	AFTER FLAME AVG:0.0 sec,CALIFORNIA TITLE 19 SECTION 1237,CALIFORNIA TB 117E

PERMENANT TREATMENT/WILL NOT WASH OFF, FOR INTERIOR & EXTERIOR USE

10-17-2011

ISSUED BY:

American Flamecoat Inc.

521-F Eagleton Downs Drive
Pineville, NC 28134
(704) 543-0903

REGISTERED STATE OF CALIFORNIA STATE FIRE MARSHAL FLAME RETARDANT GA-1201.01

*** This is a generic FR Cert. We will not have the actualy certificate until we recieve the fabric from American Flamecoat.

Director GA-1201.01
(General)

Note: Fabrics and/or materials described on this certificate are intended for interior use unless otherwise stated. Due to the number of external forces that can diminish flame retardancy, this fabric should be periodically retested to insure it retains its effectiveness. We do not warrant the length of time that the fabric remains fire retardant. We do state that when it leaves our facility, it meets the stated code. Certificate void if material is exposed to open flame or extremely hot lights or electrical wiring.

©2008 #137048