

. . . Fire Protection by Computer Design

ACCENDO FIRE PROTECTION LLC
38 ADDITON RD
GREENE, MAINE 04236
207-946-6182

Job Name : CPORT STANDPIPE
Drawing : STEEL AND CONCRETE
Location : PORTLAND, MAINE
Remote Area : STANDPIPE
Contract : 1020
Data File : CPORT STANDPIPE.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - CPORT CCREDIT UNION STANDPIPE Date - 1/8/18
 Location - PORTLAND, MAINE
 Building - STEEL AND CONCRETE System No. - STANDPIPE
 Contractor - AFP Contract No. - 1020
 Calculated By - JWD Drawing No. - 2 OF 2
 Occupancy - LIGHT HAZARD

S (X)NFPA 14 Number of Standpipes (X)1 ()2 ()3 ()4 ()
 Y ()Other

S ()Specific Ruling Made by Date

T					
E	Flow at Top Most Outlet	- 250	Gpm		System Type
M	Pres. at Top Most Outlet	- 100	Psi	(X) Wet	() Dry
	Flow For Ea. Additional Standpipe	- 250	Gpm		
D	Total Additional Flow	-	Gpm		
E	Elevation at Highest Outlet	- 149	Feet		
S	Hose Valve Connection	()1 1/2"	(X)2 1/2"		
I	Class Service	(X)I	()II	()III	
G	Note:				
N					

Calculation Gpm Required 500 Psi Required 130.08 At NODE FDC
 Summary C-Factor Used: Overhead 120 Underground 120

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 1/5/18		Cap.
T	Time of Test - N/A	Rated Cap.	Elev.
E	Static (Psi) - 150	@ Psi	
R	Residual (Psi) - 149	Elev.	Well
	Flow (Gpm) - 500		Proof Flow Gpm
S	Elevation - 100		

U Location: FDC LOCATED ON INDIA STREET SIDE OF BUILDING

P
 L Source of Information: PORTLAND FIRE DEPARTMENT PUMPER TRUCK
 Y


Water Supply Curve C

ACCENDO FIRE PROTECTION LLC
CPORT STANDPIPE

Page 2
Date

City Water Supply:
C1 - Static Pressure : 150
C2 - Residual Pressure: 149
C2 - Residual Flow : 500

Demand:
D1 - Elevation : 20.789
D2 - System Flow : 250
D2 - System Pressure : 131.086
Hose (Demand) : 250
D3 - System Demand : 500
Safety Margin : 17.914



Fittings Used Summary

ACCENDO FIRE PROTECTION LLC
CPORT STANDPIPE

Page 3
Date

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
L	NFPA 13 Long Turn Elbow	0.5	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

ACCENDO FIRE PROTECTION LLC
CPORT STANDPIPE

Page 4
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
SPRIG	0.0		100.0	na	250.0			
100	149.0		100.0	na	250.0			
102	141.0		104.42	na	250.0			
101	141.0		106.32	na				
103	132.0		111.17	na				
FDC	101.0		131.09	na				

The maximum velocity is 16.75 and it occurs in the pipe between nodes 100 and 101

Final Calculations - Hazen-Williams - 2007

ACCENDO FIRE PROTECTION LLC
CPORT STANDPIPE

Page 5
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
SPRIG to UP	0 0	H250	0.0 0.0	2.5 2.469	B T	7.0 12.0 0.0	0.250 19.000 19.250	120 0	100.000 0.0 0.0			Vel = 0
UP			0.0 0.0						100.000			K Factor = 0
100 to 101	149 141	+ 250.00	250.00 250.0	2.5 2.469	G T	1.0 12.0 0.0	0.250 13.000 13.250	120 0.2154	100.000 3.465 2.854			Vel = 16.75
101			0.0 250.00						106.319			K Factor = 24.25
102 to 103	141 132	+ 250.00	250.00 250.0	2.5 2.469	G T	1.0 12.0 0.0	0.250 13.000 13.250	120 0.2154	104.420 3.898 2.854			Vel = 16.75
103			0.0 250.00						111.172			K Factor = 23.71
101 to 103	141 132		250.00 250.0	4 4.26	2I T	18.434 26.334 0.0	18.420 44.768 63.188	120 0.0151	106.319 3.898 0.955			Vel = 5.63
103 to FDC	132 101		250.00 500.0	4 4.26	L T B S	7.9 26.334 15.8 28.968	40.000 79.002 119.002	120 0.0545	111.172 13.426 6.488			Vel = 11.25
FDC			0.0 500.00						131.086			K Factor = 43.67