HVAC CODED NOTES

ROUTE LIQUID AND SUCTION LINES FROM CONDENSING UNITS INTO EXTERIOR CHASE CONTRACTOR TO MINIMIZE TOTAL LENGTH OF PIPING AND NUMBER OF ELBOWS. SIZE, ROUTING, AND TOTAL REFRIGERANT RECHARGE TO BE FIELD VERIFIED.

NEW STORE

GAP INC. CORPORATE ARCHITECTURE 1 HARRISON STREET

SAN FRANCISCO, CA 94105 7641 STORE NO.:

STORE NAME: PORTLAND

STORE LOCATION: 152 MIDDLE STREET PORTLAND, ME 04101

0000053405 PROJ. I.D.:

PROTOTYPE DATE: 09/4/15 PROTOTYPE VERSION 4.1

CONSULTANT INFO:



PROFESSIONAL STAMP:

ARCHITECT INFO:



I HEREBY CERTIFY THAT THESE PLANS HAVE BEEN PREPARED IN MY OFFICE AND UNDER MY SUPERVISION AND THAT TO THE BEST OF MY KNOWLEDGE, THE SAME COMPLY WITH ALL LAWS, RULES, REGULATIONS AND ORDINANCES OF PORTLAND, ME RELATING TO STRUCTURES AND BUILDINGS.

ISSUE TYPE: 100% CD CHECKSET 5/20/16 PERMIT / BID LL APPROVAL

DRAWN BY: DG

A&E JOB NO.: 16-5433

SHEET TITLE: MECHANICAL PIPING PLANS

SHEET NUMBER:

M1-1