

### RESPONSIBILITY MATRIX LEGEND

STOREFRONT EXTRUSION	O	GC	FACTORY FINISHED
ITEM			COMMENTS
FURNISHED BY			
INSTALLED BY			

L = LANDLORD  
 O = OWNER (GAP INC.)  
 GC = GENERAL CONTRACTOR  
 E = EXISTING

### RESPONSIBILITY MATRIX

ITEM	FURNISHED BY	INSTALLED BY	COMMENTS
MAIN OVERCURRENT DEVICE AT (IF NOT LANDLORD'S SERVICE POINT)	GC	GC	
METER AT LANDLORD'S SERVICE POINT	GC	GC	
C/T'S AT LANDLORD'S SERVICE POINT	GC	GC	
C/T CABINET AT LANDLORD'S SERVICE POINT	GC	GC	
DOOR BUZZER SYSTEM	GC	GC	14
SERVICE ENTRANCE CONDUIT(S) LANDLORD'S TO LEASE SPACE WITH PULL WIRE	GC	GC	
208/120 VOLT PANEL(S)	GC	GC	
ELECTRICAL GEAR & LIGHTING CONTROLS (IF NOT FURNISHED BY LOEB ELECTRIC)	GC	GC	14
LIGHTING FIXTURES AND LAMPS	O	GC	2,6
MUSIC SYSTEM/SPEAKERS/CABINET	O	O	1,2,8,10
MUSIC SYSTEM WIRING	O	O	1,2,3,8,10
SECURITY CAMERA	O	O	-
BURGLAR ALARM	O	GC	5

**REMARKS:**

- ALL FINAL EQUIPMENT WIRING AND EQUIPMENT INSTALLATION BY OTHERS.
- GENERAL CONTRACTOR TO COORDINATE SCHEDULE AND DELIVERY WITH SUPPLIER. STANDARD SHIPPING PROVIDED BY GAP INC. ANY EXPEDITED SHIPPING COSTS ARE RESPONSIBILITY OF THE GENERAL CONTRACTOR.
- ROUGH-IN BY G.C.
- G.C. TO COORDINATE SCHEDULE AND DELIVERY WITH SUPPLIER. STANDARD SHIPPING PROVIDED BY ATHLETA. ANY EXPEDITED SHIPPING COSTS ARE RESPONSIBILITY OF THE GENERAL CONTRACTOR.
- ITEM DELIVERY SCHEDULED BY OWNER FOR LAST WEEK OF CONSTRUCTION.
- G.C. TO SCRIBE TO FIT.
- ALL FINAL EQUIPMENT WIRING AND EQUIPMENT INSTALLATION BY OTHERS.
- NOT USED.
- ROUGH-IN BY G.C.
- SEE PROJECT MANUAL & INSTALLATION GUIDE FOR DETAILED SUBMITTAL REQUIREMENTS.
- NOT USED.
- FOR LOEB ELECTRIC NATIONAL ACCOUNTS PRICING, SEE CONTACT INFO BELOW:

**NOTE:**  
 THE RESPONSIBILITY MATRIX ONLY DELINEATES ITEMS SUPPLIED AND/OR INSTALLED BY OWNER AND/OR LANDLORD. ANY WORK BY CONSTRUCTION DOCUMENTS NOT DEFINED AS RESPONSIBILITY OF OWNER OR LANDLORD IS SUPPLIED AND INSTALLED BY GENERAL CONTRACTOR. SEE BID CLARIFICATION LETTER FOR ANY VARIATION BY SCOPE OF WORK RESPONSIBILITY.

GENERAL CONTRACTOR IS RESPONSIBLE FOR THE UNLOADING OF ANY OWNER SUPPLIED CONSTRUCTION ITEMS.

#### LOEB ELECTRIC CONTACT INFORMATION

JOHN CALLICOAT  
 1800 E. 5TH AVENUE  
 COLUMBUS, OHIO 43219

PHONE: 614-421-5058  
 FAX: 614-299-6268  
 EMAIL: [TheGap@loebelectric.com](mailto:TheGap@loebelectric.com)

### ELECTRICAL SYMBOLS

	TELEPHONE OUTLET TELEPHONE OUTLET, FLOOR MOUNTED TELEPHONE OUTLET, CEILING MOUNTED DATA OUTLET DATA OUTLET, FLOOR MOUNTED DATA OUTLET, CEILING MOUNTED PHONE/DATA OUTLET, FLOOR MOUNTED PHONE/DATA OUTLET, CEILING MOUNTED PHONE/DATA OUTLET DUPLEX RECEPTACLE CEILING MOUNTED RECEPTACLE DUPLEX RECEPTACLE, FLOOR MOUNTED POWERSTRUT MOUNTED RECEPTACLE CEILING MOUNTED QUADRUPLEX RECEPTACLE QUADRUPLEX RECEPTACLE DUPLEX RCPT WITH GND FAULT CIRCUIT INTERRUPTER DUPLEX, WHITE RECEPTACLE AND COVERPLATE DUPLEX, WHITE RCPT AND STAINLESS STEEL COVERPLATE DUPLEX RECEPTACLE, STOREFRONT SINGLE RECEPTACLE QUADRUPLEX RECEPTACLE WITH ISOLATED GROUND DUPLEX RECEPTACLE WITH ISOLATED GROUND JUNCTION BOX SWITCH, 1-POLE, REFER TO ARCH FOR MOUNTING HEIGHT SWITCH, 3-WAY, REFER TO ARCH FOR MOUNTING HEIGHT MOTOR RATED SWITCH WITH THERMAL OVERLOAD PROTECTION DIMMER SWITCH MOTION SENSOR BYPASS BUTTON REMOTE BALLAST RELAY NON-FUSED DISCONNECT SWITCH FUSED DISCONNECT SWITCH MAGNETIC STARTER ELEC PANELBOARD (SHOWN TO SCALE ON PLANS) DRY TYPE TRANSFORMER PUSH BUTTON FOR BELL OR BUZZER DOOR BUZZER BUZZER OR BELL ADA PUSHBUTTON INTERCOM CALL BUTTON ADT CONTROL PANEL SPEAKER VOLUME CONTROL SPEAKER BASS MODULE MOUNTED ABOVE CEILING ACCESS PANEL. SEE ARCHITECTURAL DRAWINGS. HOMERUN CIRCUIT POWERSTRUT SUSPENDED FROM STRUCTURE UNISTRUT FIRE ALARM CONTROL PANEL FACP REMOTE ANNUNCIATOR PHOTO CELL MANUAL PULL STATION CEILING MOUNTED SMOKE DETECTOR DUCT MOUNTED SMOKE DETECTOR 120V POWER FROM RTU REC/LT CCT IF REQUIRED INTERNAL CONTACTOR CONTROL RELAY TAMPER SWITCH WATER FLOW SWITCH HORN WITH STROBE LIGHT WALL MOUNTED @ 80" AFF STROBE WALL MOUNTED @ 80" AFF HORN WALL MOUNTED @ 80" A.F.F. STROBE LIGHT CEILING MOUNTED. HORN WITH STROBE LIGHT CEILING MOUNTED HVAC TEMPERATURE SENSOR HVAC THERMOSTAT ELECTRICALLY POWERED EQUIPMENT ABOVE FINISH FLOOR ELECTRONIC ARTICLE SURVEILLANCE ELECTRIC BASEBOARD HEATER ELECTRICAL CONTRACTOR EMERGENCY ELECTRIC WATER COOLER - COORDINATE RECEPTACLE LOCATION WITH PLUMBING CONTRACTOR ISOLATED GROUND NIGHT LIGHTING WEATHER PROOF X = QUANTITY OF CONDUCTORS NOTE: NOT ALL SYMBOLS NECESSARILY USED ON PLAN.
--	---

- ### ELECTRICAL GENERAL NOTES
- THE ABBREVIATION G.C., WHEREVER IT APPEARS IN THESE ELECTRICAL DRAWING, SHALL REFER TO "GENERAL CONTRACTOR".
  - THE CONTRACTOR FOR THIS WORK IS REQUIRED TO READ THE SPECIFICATIONS AND REVIEW DRAWINGS OF ALL DIVISIONS OF WORK AND IS RESPONSIBLE FOR THE COORDINATION OF THIS WORK AND THE WORK OF ALL SUBCONTRACTORS WITH ALL DIVISIONS OF WORK. IT IS THE CONTRACTOR'S RESPONSIBILITY TO PROVIDE ALL SUBCONTRACTORS WITH A COMPLETE SET OF BID DOCUMENTS.
  - LIGHTING, RECEPTACLES AND EQUIPMENT SHALL BE CONNECTED TO EXACT PANEL AND BREAKER AS SHOWN ON PLANS.
  - ELECTRICAL HOME RUNS SHOWN ARE SCHEMATIC AND MAY ORIGINATE FROM DIFFERENT LOCATIONS UNLESS OTHERWISE NOTED. MULTIPLE CONNECTIONS TO A SINGLE LIGHT FIXTURE FOR VOLTAGE DROP CONDITIONS OR AS A RESULT OF A FIELD CONDITION ARE ACCEPTABLE. ANY RELATED COSTS FOR MULTIPLE CONNECTIONS SHALL BE INCLUDED IN BID.
  - SEE ARCHITECTURAL REFLECTED CEILING PLAN FOR EXACT LOCATION AND QUANTITY OF LIGHTING FIXTURES AND SIGNAGE ELEMENT LOCATIONS.
  - ALL LIGHTING AND RECEPTACLE CIRCUITS UP TO 60'-0" IN LENGTH SHALL UTILIZE #12 CONDUCTORS MINIMUM, CIRCUITS FROM 61'-0" THRU 100'-0" IN LENGTH SHALL UTILIZE #10 CONDUCTORS MINIMUM AND FROM 101'-0" THRU 150'-0" IN LENGTH SHALL UTILIZE #8 CONDUCTORS MINIMUM, UNLESS OTHERWISE NOTED.
  - IN DRYWALL CEILING AREAS, ARRANGE CIRCUITS TO AVOID THE USE OF JUNCTION BOXES IN INACCESSIBLE LOCATIONS. THE USE OF JUNCTION BOXES ABOVE DRYWALL CEILINGS SHALL BE LIMITED TO LOCATIONS NEAR ACCESS PANELS AS LOCATED ON PLANS. FIELD COORDINATE WITH G.C. PRIOR TO ROUGH-IN TO AVOID ANY CONFLICTS.
  - FIELD VERIFY EXACT LOCATION AND ELECTRICAL REQUIREMENTS OF ALL HVAC EQUIPMENT THROUGH G.C. PRIOR TO ORDERING RELATED ELECTRICAL EQUIPMENT.
  - PLACEMENT OF ALL RECEPTACLES IN THE "SALES" AREA SHALL BE INTENTIONAL (I.E. - CENTERED ON COLUMNS, WALL FEATURES OR TIGHT TO CORNERS AND FLUSH MOUNTED AT GYP BOARD WALL ONLY). FIELD VERIFY EXACT PLACEMENT OF RECEPTACLE WITH G.C. PRIOR TO ROUGH-IN.
  - CONTRACTOR TO VERIFY THAT ALL ITEMS ON CONTRACTOR CHECKLIST ARE COMPLETED PRIOR TO MEP COMMISSIONING. CONTRACTOR WILL RECEIVE CONTRACTOR CHECKLIST IN ELECTRONIC FORM WITH BID DOCUMENTS.

#### DRAWING SCHEDULE

NUMBER	TITLE
E0-1	ELECTRICAL NOTES AND LEGENDS
E1-0	POWER PLAN
E1-0A	POWER PLAN - HVAC
E1-1	LIGHTING PLAN
E4-0	LIGHT FIXTURE SCHEDULE
E5-0	EAS DETAIL
E6-0	CASHWRAP DETAILS
E9-0	POWER RISERS AND SCHEDULES
E9-1	PANEL SCHEDULES
E9-4	LIGHT FIXTURE DETAILS
E9-5	ELECTRICAL DETAILS

NEW STORE

# ATHLETA

GAP INC.  
 CORPORATE ARCHITECTURE  
 1 HARRISON STREET  
 SAN FRANCISCO, CA 94105

STORE NO.: **7641**

STORE NAME:  
**PORTLAND**

STORE LOCATION:  
152 MIDDLE STREET  
PORTLAND, ME 04101

PROJ. I.D.: 0000053356

PROTOTYPE DATE: 09/4/15  
PROTOTYPE VERSION 4.1

**DICKERSON ENGINEERING, INC.**  
 Professional Electrical Engineers  
 8101 NORTH MILWAUKEE AVENUE  
 NILES, ILLINOIS 60714  
 TEL (847) 966-0290

PROFESSIONAL STAMP:

SIGNATURE: *Rick A. Sabatello*  
 DATE: 05/20/2016 EXPIRATION DATE: 12/31/2017

ARCHITECT INFO:

**Chipman Design**  
 Architecture Group P.C.  
 2105 S. River Road, Suite 400  
 Portland, ME 04106  
 TEL 847.288.4900 FAX 847.288.4944

ISSUE TYPE:  
100% CD CHECKSET 5/20/16  
PERMIT / BID  
LL APPROVAL

DRAWN BY: PR  
A&E JOB NO.: 16-5433

SHEET TITLE:  
ELECTRICAL NOTES  
AND LEGENDS

SHEET NUMBER:  
**E0-1**