

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**  
RELM REALTY LLC

**Located at**  
150 MIDDLE ST

**PERMIT ID:** 2016-02410    **ISSUE DATE:** 10/31/2016    **CBL:** 029 A00101A

has permission to **For the installation of a 20" x 30" (4 SF), attached building wall sign for "Athleta"**.  
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Jeanie Bourke

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

***Approved Property Use - Zoning***

Retail

***Building Inspections***

**Use Group:** M

Mercantile

Exterior

MUBEC/IBC 2009

***Fire Department***

**Type:** Sign

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases 6 months.**
- **If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

### **REQUIRED INSPECTIONS:**

Electrical - Commercial

Final - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2016-02410	<b>Date Applied For:</b> 09/13/2016	<b>CBL:</b> 029 A00101A
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> Mercantile - Retail ("Athleta") - Storer Building		<b>Proposed Project Description:</b> For the installation of a 20" x 30" (4 SF), attached building wall sign for "Athleta".		
<b>Dept:</b> Historic <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Robert Wiener <b>Approval Date:</b> 10/31/2016 <b>Note:</b> <b>Ok to Issue:</b> <input checked="" type="checkbox"/> <b>Conditions:</b> 1) Wiring or conduit is to be hidden. 2) To avoid new holes in the façade, bracket mounting holes should be reused if at all possible. 3) HP staff suggests a slightly larger sign, due to the scale of the façade. This approval is for a sign up to 42" wide by 30" high.				
<b>Dept:</b> Zoning <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Christina Stacey <b>Approval Date:</b> 10/21/2016 <b>Note:</b> B-3 zone, PAD, multitenant <b>Ok to Issue:</b> <input checked="" type="checkbox"/> Allowed sign max 120 sf, proposed 4 sf - OK <b>Conditions:</b> 1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
<b>Dept:</b> Building Inspection <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Jeanie Bourke <b>Approval Date:</b> 10/25/2016 <b>Note:</b> <b>Ok to Issue:</b> <input checked="" type="checkbox"/> <b>Conditions:</b> 1) A separate permit is required for electrical installations 2) Signage and Awning Installation to comply with Chapters 16 (Structural Loads), 31 (Materials) & 32 (ROW Height & Encroachments) of the IBC 2009 building code. 3) Encroachments into public ways must be a minimum of 8' above grade for signs and 7' for awnings per section 3202 of IBC 2009.				

**PERMIT ID:** 2016-02410

**Located at:** 150 MIDDLE ST

**CBL:** 029 A00101A