

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT

This is to certify that

GUTWIN JOHN D & LENORA GUTWIN JTS

Located at

150 MIDDLE ST (Unit 4D)

PERMIT ID: 2016-00078

ISSUE DATE: 02/22/2016

CBL: 029 A00104D

has permission to **Interior Renovations - Kitchen remodeling for Unit 4D, which includes relocating appliances, cabinets, electrical, gas, and the removal of a non-load bearing wall.**
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning
residential condominium

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing

Electrical - Commercial

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-00078	Date Applied For: 01/13/2016	CBL: 029 A00104D
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Residential Condos - Unit 4D		Proposed Project Description: Interior Renovations - Kitchen remodeling for Unit 4D, which includes relocating appliances, cabinets, electrical, gas, and the removal of a non-load bearing wall.		
Dept: Historic	Status: Approved w/Conditions	Reviewer: Robert Wiener	Approval Date: 02/08/2016	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) No exterior alterations are approved with this permit. If any exterior work is planned, including but not limited to windows, venting, mechanicals, HVAC, etc. it must reviewed and approved separately prior to construction.				
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Christina Stacey	Approval Date: 02/03/2016	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) This property shall remain a single family condominium unit. Any change of use shall require a separate permit application for review and approval.				
Dept: Building Inspecti	Status: Approved w/Conditions	Reviewer: Tammy Munson	Approval Date: 01/15/2016	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 02/22/2016	Ok to Issue: <input type="checkbox"/>
Note:				
Conditions:				
1) Shall comply with NFPA 101, Chapter 31, Existing Apartment Buildings.				
2) All construction shall comply with City Code Chapter 10.				