



CUNNINGHAM
SECURITY SYSTEMS

October 2, 2018

Code Enforcement Office
City of Portland
389 Congress Street
Portland, ME 04101
(207) 874-8705
Fax#: (207) 874-8716

To Whom It May Concern:

This letter is to inform you that on September 20th, 2018, we completed the installation, programming and testing of (2) new horn strobes units and (1) new strobe unit in the building located at 5 Milk Street in Portland, Maine. These new devices were tied into the building's existing fire alarm control panel and were programmed and test to NFPA 72 standards. These devices were found to be fully functional at that time.

Should you have any questions or comments regarding this matter, please feel free to contact me at (207) 846-3350.

Sincerely,

Ronald S. Snider, Manager

cc: Acct. File