

## Page 1- Obellest PORTAND MAINE

Strengthening a Remarkable City, Building a Community for Life - www.portlandmaine.gov

Lee Urban - Director of Planning and Development Jeanie Bourke - Inspection Division Services Director

## Kitchen Exhaust System Checklist and code Provisions

Dear Applicant,

The following is a checklist to assist you in filing for a permit for a Kitchen Exhaust system. The applicable Mechanical Code provisions have also been attached. Please complete this and submit job specific construction documents that demonstrate compliance with the attached information.

compliance with the attached information.
Type of System:
Type I Type II
Type I systems are systems that vent fryers, grills, broilers, ovens or woks.  Type II systems are systems that vent steamers and other non grease producing appliances.
Type of Materials:
Is the hood Stainless steel or other type of steel? Stainless If Other, what
Type?
Is the duct work Stainless steel or other type of steel? <u>Carbon Steel</u> If Other what type?
Thickness of the steel for the hood 16 ga \$ /5  Thickness of the duct for the hood 16 ga. Steel
Thickness of the duct for the hood
Type of Hood and Duct Supports  - logged To Wall + hung from Ceiling  With Threaded Rod.  Type of seams and Joints All Welded
Type of seams and somes
3