

Page 2 Check list  
NORTH POINT

Grease Gutters provided? yes

Hood Clearance reduction to Combustibles design /specs:  
duct fire wrapped with zero clearance wrapping.

Duct Clearance reduction to Combustibles design /specs:  
0-

Vibration Isolation System:  
-

Air Velocity within the duct system 2000 RPM

Grease accumulation prevention system:  
yes

Cleanouts none - short duct run.

Grease Duct enclosure Fire Master insulation

Exhaust Termination Roof \_\_\_\_\_ Wall ✓

Fire Suppression System yes

Exhaust fan mounting and clearance from the roof / wall or Combustibles:  
min. 10'

Exhaust fan distance from property lines min 10'

Exhaust fan distance from other vents or openings 10'

Exhaust fan distance from adjacent buildings 10'

Exhaust fan height above adjoining grade \_\_\_\_\_

**Hood Specs**

Style of Hood Low Profile

Type of Filter Baffle

Height of filter above nearest cooking surface 42"

Capacity of hood CFM 1000 CFM

Make up Air system description and capacity  
None