



1 AHU HANGING DETAIL
SCALE: N.T.S

AIR HANDLING UNIT SCHEDULE															
TAG	AREA SERVED	COOLING TONS	HEATING MBH IN	MANUFACTURER	MODEL NUMBER	ELECTRIC VOLTS/PHASE	MCA AMPS	MAX FUSE	WEIGHT	STAGES	CFM	MIN O.A CFM	SEER	AFUE%	REMARKS
AHU-1	LEFT SIDE	4.0	---	YORK	AHR48D3XH21	230 / 1	4.8	15.0	147 LBS	1C	1,600	---	13.0	---	
AHU-2	RIGHT SIDE	4.0	---	YORK	AHR48D3XH21	230 / 1	4.8	15.0	147 LBS	1C	1,600	---	13.0	---	

REMARKS:

CONDENSING UNIT SCHEDULE												
TAG	AREA SERVED	COOLING TONS	HEATING MBH IN	MANUFACTURER	MODEL NUMBER	ELECTRIC VOLTS/PHASE	MCA AMPS	MAX FUSE	WEIGHT	STAGES	SEER	REMARKS
CU-1	AHU-1	4.0	----	YORK	YCD48S41S1	230 / 1	21.1	35.0	173 LBS	1C	13.0	
CU-2	AHU-2	4.0	----	YORK	YCD48S41S1	230 / 1	21.1	35.0	173 LBS	1C	13.0	

REMARKS:

AirTemp, Inc.
11 Wallace Ave
South Portland, Maine

COMFORT SYSTEMS USA
AirTemp, Inc.

4 MILK STREET
PORTLAND, MAINE

CLIENT: BRL
DATE: NOV. 26, 2014

SHEET TITLE: MECHANICAL PLAN

SCALE:
DRAWING: M-1