



Laurie Leader <lr@portlandmaine.gov>

Re: BP#2016-01135 341 Fore Street - Plan review

1 message

Brian Haapala <brhaapala@gmail.com>
To: Laurie Leader <lr@portlandmaine.gov>

Wed, Jul 6, 2016 at 3:42 PM

Laurie--

Thanks for following up. The historic preservation approval that came after my initial application was based on a railing system similar to the adjacent Regency property. I am looking at a local contractor now that can make it custom. I can ensure a 3" opening if you require.

-Brian

On Wed, Jul 6, 2016 at 2:19 PM, Laurie Leader <lr@portlandmaine.gov> wrote:

Brad,

I am handling the plan review for the above building permit. Can you provide the specifications for the proposed guardrail and cable system with turn buckle? Give these cables can loosen up, we generally like to see the opening limitations to be 3" on center rather than 4" on center.

Thanks,

Laurie

--

Laurie Leader
Plan Review/Code Enforcement
City of Portland, Maine
Inspections Division
389 Congress Street
Portland, ME 04101

P: [207-874-8714](tel:207-874-8714)

F: [207-874-8716](tel:207-874-8716)

E: lr@portlandmaine.gov

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.