Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 07/07/16

Portland Maine Yes. Google's good here.

Laurie Leader <lrl@portlandmaine

Re: BP#2016-01135 341 Fore Street - Plan review

1 message

Brian Haapala <brhaapala@gmail.com> Wed, Jul 6, 2016 at 3:42 PM
To: Laurie Leader <lrl@portlandmaine.gov>

Laurie--

Thanks for following up. The historic preservation approval that came after my initial application was based on a railing system similar to the adjacent Regency property. I am looking at a local contractor now that can make it custom. I can ensure a 3" opening if you require.

-Brian

On Wed, Jul 6, 2016 at 2:19 PM, Laurie Leader <lrl@portlandmaine.gov> wrote:

> Brad,
>
> I am handling the plan review for the above building permit. Can you provide the specifications for the proposed guardrail and cable system with turn buckle? Give these cables can loosen up, we generally like to see the opening limitations to be 3" on center rather than 4" on center.
>
> Thanks,
>
> Laurie
>
> --
> Laurie Leader
> Plan Review/Code Enforcement
> City of Portland, Maine
> Inspections Division
> 389 Congress Street
> Portland, ME 04101
>
> P: 207-874-8714
> F: 207-874-8716
> E: lrl@portlandmaine.gov
>
> Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.