



September 22, 1987

Mr. Sam Hoffses
Lt. Collins
Building Department
City of Portland
389 Congress Street
Portland, ME 04101

RE: Peat, Marwick, Main & Co.
2nd Floor, Building B
100 Middle Street

Gentlemen:

This letter is to confirm a discussion I had with you both (separately) on March 24, 1987 regarding second floor egress at Building B, 100 Middle Street. My question at the time was whether or not doors 214 and 215 (see attached plan sheet A-1) and adjacent walls need to have a one-hour rating.

The answer I received was that they would not have to be rated. In BOCA, reference was to the need for a 20 minute rating but that 10% of the area could be combustible. Therefore, the doors could be non-label hollow metal doors in hollow metal frames and the walls could be 1/2" drywall on both sides of 3 5/8" metal studs.

Reference in NFPA was to section 26.3.6.1, Exception 3, which states that corridors "...need not have a fire resistance rating within buildings protected throughout by an approved automatic sprinkler system."

I would appreciate your agreement with my understanding either by responding with a letter or by signing this letter in the space provided and returning the original to me in the envelope provided. If you are not in agreement with my understanding, please call me as soon as possible.

Respectfully submitted,


THE DESIGN ALLIANCE


Malcolm L. Collins AIA

75 MARKET STREET PORTLAND, ME 04101 (207) 773-1756

Mr. Sam Hoffses
Lt. Collins
September 22, 1987
Page 2

The above-stated understanding reflects our conversations and represents a correct interpretation of this specific situation.

 9/28/87
Sam Hoffses Date

 9/28/87
Lt. Collins Date

Enclosure

PERMIT # _____		PORTLAND BUILDING PERMIT APPLICATION DATE 8/14/87		PERMIT ISSUED AUG 20 1987 City Of Portland	
I. GENERAL INFORMATION					
Location/address of construction <u>100 Middle Street</u>					
1. Owner's name <u>100 Middle Street Investment Assoc.</u>		Tel. <u>772-0548</u>			
Address <u>38 Preble Street, Portland</u>					
2. Lessee's name <u>Bernstein, Shur, Sawyer & Nelson</u>		Tel. <u>774-1200</u>			
Address <u>1 Monument Square</u>					
3. Contractor's name <u>Allied Construction Company</u>		Tel. <u>772-2881</u>			
Address <u>P.O. Box 1996 04104</u>					
4. Is this a legally recorded lot? ☒ yes ☐ no					
II. DESCRIPTION OF WORK:					
to provide tenant improvements including partitions, finishes, electrical, mechanical and sprinkler system for the fifth, sixth & seventh floors of "B" building					
send permit to #3					
III. BUILDING DIMENSIONS: length _____ width _____ square footage _____ height _____ #stories _____					
IV. ZONE <u>B-3</u> Street frontage _____ Zoning board approval: ☐ yes ☐ date _____					
Setbacks: front _____ back _____ side _____ side _____ Planning board approval: ☐ yes ☐ date _____					
V. REVIEW REQUIRED: variance _____ other _____ Number of off-street parking spaces: _____					
site plan _____ subdivision _____ shore _____ floodplain mgmt _____ enclosed _____ outdoors _____					
VI. FEES:					
base fee _____		other fees _____			
subdivision fee _____		late fee _____			
site plan review fee _____		TOTAL <u>\$1,740</u>			
VII. DETAILS OF WORK					
1. WATER SUPPLY: ☐ public ☐ private		7. ELECTRICAL: service entrance size _____ # smoke detectors _____		8. CHIMNEY: # flues _____ material _____ # fireplaces _____	
2. SEWER: ☐ public ☐ private, type _____		9. FRAMING: floor joists _____ size _____ max. on center _____ ceiling joists _____ rafters _____ studs _____ wall studs _____			
3. HEAT: type _____ fuel _____		10. If 1-story building w/masonry walls: wall thickness _____ height _____		11. BEDROOM WINDOWS height _____ width _____ sill height _____ egress window? ☐ yes ☐ no	
4. FOUNDATION: type _____ thickness _____ footing _____					
5. ROOF type _____ pitch _____ covering _____ load _____					
6. PLUMBING: SPRINKLER SYST.? ☐ yes ☐ no					
VIII. OFFICE USE:		IX. NEW OR PHASED SUBDIVISION REFERENCE			
TAX MAP # _____		Name _____			
LOT # _____		Lot _____			
VALUE/STRUCTURE _____		Block _____			
PERMIT EXPIRATION _____					
CODE: If other, explain _____		Seasonal ☐ Condominium ☐ Apartment ☐			
X. PROPOSED USE: <u>offices</u>					
XI. PAST USE: <u>vacant</u>					
XII. OWNERSHIP: PUBLIC ☒ PRIVATE ☐					
XIII. EST. CONSTRUCTION COST: <u>\$343,329</u>		XIV. GR. SQ. FT. OF LOT _____ BUILDING _____			
COMPLETE XV AND XVI ONLY IF THE NUMBER OF UNITS WILL CHANGE					
XV. RESIDENTIAL BUILDINGS ONLY:		BEDROOMS		XVI. # RESIDENTIAL UNITS:	
# NEW DWELLING UNITS WITH:		1. BDRM _____ 2. BDRMS _____ 3. BDRMS _____		# NEW DWELLINGS _____	
# EXISTING DWELLING UNITS WITH:				# EXISTING DWELLINGS _____	
				TOTAL RESIDENTIAL UNITS _____	
APPROVALS BY: DATE _____		MISCELLANEOUS			
BUILDING INSPECTION PLAN EXAMINER _____		Will work require disturbing of any tree on a public street?			
ZONING: <u>G.F. [Signature] Aug 14 1987</u>		Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?			
C.E.O. _____					
FIRE DEPT. <u>[Signature]</u>					
NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical, and mechanicals.					
District No. <u>2</u>		XVII. SIGNATURE OF APPLICANT <u>[Signature]</u> PHONE # <u>772-2288</u>			
		TYPE NAME OF ABOVE <u>Paul Gillis Fox 100 Middle St. Invest.</u>			
White - GFCOG Green - Applicant Yellow - Assessor Pink - Office File Gold - Field Inspector					



APPLICATION FOR AMENDMENT TO PERMIT

Amendment No. 1

Portland, Maine, December 31, 1987

PERMIT ISSUED

JAN 26 1988

City of Portland

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for amendment to Permit No. 1066 pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location 100 Middle Street, 4th Floor "A" Building Within Fire Limits? Dist. No.
Owner's name and address 100 Middle Street Investment Associates 38 Preble Str. Telephone 772-0548
Lessee's name and address Morse Payson & Noyes, 100 Middle Str. Plaza Telephone 775-6000
Contractor's name and address Allied, PO Box 1396 Portland, ME 04104 Telephone 772-2888
Architect Plans filed No. of sheets
Proposed use of building Offices No. families
Last use same No. families
Increased cost of work 223,000 Additional fee 1115

Description of Proposed Work

To make interior renovations to the fourth floor, as per plans

Details of New Work

Is any plumbing involved in this work? ☒ no Is any electrical work involved in this work? ☐ yes
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Material of underpinning Height Thickness
Kind of roof Rise per foot Roof covering
No. chimneys Material of chimneys of lining
Framing lumber—Kind Dressed or full size?
Corner posts Sills Girt or ledger board? Size
Girders Size Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor, 2nd, 3rd, roof
On centers: 1st floor, 2nd, 3rd, roof
Maximum span: 1st floor, 2nd, 3rd, roof

Approved: OK. W. J. Turner Jan. 8, 1988

Signature of Owner [Signature]
PERMIT ISSUED WITH LETTER
Inspector of Buildings

INSPECTION COPY

FILE COPY

APPLICANT'S COPY

ASSESSOR'S COPY

W. M. Adig



CITY OF PORTLAND, MAINE

389 CONGRESS STREET
PORTLAND, MAINE 04101
(207) 775-5451

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

P. SAMUEL HOFFSES, CHIEF
INSPECTION SERVICES DIVISION

January 15, 1988

Allied Construction
P.O. Box 1396
Portland, ME 04104

Re: 100 Middle Street, 3rd & 4th floor


Dear Sir:

Your application to make interior renovations to the fourth floor as per plans has been reviewed and a permit is herewith issued subject to the following requirements.

1. The fire alarm system shall be extended to include all rooms and spaces.
2. These renovations shall meet the ANSI A117.1 - 1986 standards. (accessibility and usability for physically handicapped people).
3. This permit is being issued with the understanding that the Morse, Payson & Noyes occupies the whole third & fourth floor of Building A.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,


P. Samuel Hoffses
Chief, Inspection Services

/ksc

cc: Lt. Collins, Fire Prevention Bureau

BUILDING PERMIT REPORT

DATE: 1-13-88
ADDRESS: 100 Middle St. 3rd Fl. Bulld "A"
REASON FOR PERMIT: Renovations
BUILDING OWNER: 100 Middle St. Investment Assoc.
CONTRACTOR: Allied Const.
PERMIT APPLICANT: Kandace Gelpetruch
APPROVED: XX DENIED
CONDITION OF APPROVAL OR DENIAL:

- 1.) The fire alarm system shall be expanded to include all rooms and spaces.

2



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION One Hundred Middle Street Plaza

Issued to Allied Construction Co., Inc.

Date of Issue February 5, 1968

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. 87/1066, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

East Tower "A" Building - 1st Floor
East Tower "A" Bldg. - 2nd, 3rd, 4th Floors
Limiting Conditions:

Office spaces
Office spaces

This certificate supersedes
certificate issued

Approved:

2-5-68

(Date)

Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

Issued to **Peat Marwick, Maine Inc.** LOCATION **100 Middle Street** Date of Issue **November 16, 1987**

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. **86/911**, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Tower E 3rd Floor Entire & 2nd Floor partial

Limiting Conditions:

This certificate supersedes
certificate issued

Approved 11/16/87 A. Rowe
(Date) Inspector

[Signature]
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.



CONSTRUCTION CO., INC. P.O. BOX 1396 • PORTLAND, ME 04104 • 772-2888

January 27, 1988
Mid 1752

Mr. Samuel Hoffses
City of Portland
Chief of Inspection Services
389 Congress Street
Portland, ME 04104

SUBJECT: One Hundred Middle Street Plaza
Certificate of Occupancy Permit Inspection

Dear Sam:

This letter is to request a Certificate of Occupancy Permit Inspection for the following office spaces at One Hundred Middle Street Plaza:

East Tower "A" Building - 1st Floor
East Tower "A" Building - 2nd, 3rd & 4th Floors

If it will fit your schedule, we are requesting this inspection to be held on Tuesday, February 2, 1988, at 1:00 p.m.

Sincerely,

A handwritten signature in dark ink, appearing to read "John F. Carr".

John F. Carr
Executive Vice President

JAC/bmd

cc: Gail Jones
Jeff Andrews
Ernie Arsenaault
Lt. James Collins, PFD
Ernie Goodwin, Plumbing Inspector
Rick Russo, Electrical Inspector

OFFICE: 208 FORE ST. PORTLAND, ME

*TPSH -
I'll be out on vacation,
if A.G. isn't here
please ask someone else.
A.R.*

BUILDING PERMIT REPORT

DATE: 8-10-87

ADDRESS: 100 Middle St.

REASON FOR PERMIT: Renovations

BUILDING OWNER: Investment Assoc.

CONTRACTOR: Allied Construction

PERMIT APPLICANT: Paul Gillis

APPROVED: XX DENIED

CONDITION OF APPROVAL OR DENIAL:

- 1.) All doors along the paths of travel to the required exits shall swing in the direction of exit travel.
- 2.) Separate approvals and permits are required for the sprinkler and fire alarm systems.

2

PERMIT # 916 PORTLAND BUILDING PERMIT APPLICATION DATE _____ PERMIT ISSUED

I. GENERAL INFORMATION

Location/address of construction 130 Middle Street

AUG 11 1987

1. Owner's name 100 Middle St. Investment Assoc. Tel. 772-0548

Address 100 Middle St. 04101

City Of Portland

2. Lessee's name Messa, Laveon & Noves Tel. 775-6060

Address 130 Middle St. 04101

3. Contractor's name Allied Construction Co., Inc. Tel. 772-2888

Address P. O. Box 1396, Portland, ME 04104

4. Is this a legally recorded lot? yes X no _____

II. DESCRIPTION OF WORK: To provide tenant improvements including partitions, finishes, electrical, mechanical and sprinkler system for the second & third floors of "A" Building, as per plans.

ISSUED TO: CONTRACTOR

III. BUILDING DIMENSIONS: length _____ width _____ square footage _____ height _____ #stories _____

IV. ZONE _____ Street frontage _____ Zoning board approval: no ☐ yes ☐ date _____
Setbacks: front _____ back _____ side _____ Planning board approval: no ☐ yes ☐ date _____

V. REVIEW REQUIRED: variance _____ other _____ Number of off-street parking spaces: _____
site plan _____ subdivision _____ shore _____ floodplain mgmt. _____ enclosed _____ outdoors _____

VI. FEES:
base fee 238,800.00 other fees _____
subdivision fee _____ late fee _____
site plan review fee _____ TOTAL 1,215.00

VII. DETAILS OF WORK

1. WATER SUPPLY: ☐ public ☐ private	7. ELECTRICAL: yes ☐ service entrance size _____ # smoke detectors _____	8. CHIMNEY: # flues _____ material _____ # fireplaces _____
2. SEWER: ☐ public ☐ private, type _____	9. FRAMING: floor joists _____ size _____ max. on center _____ ceiling joists _____ rafters _____ studs _____ wall studs _____	
3. HEAT: type _____ fuel _____	10. If 1-story building w/masonry walls: wall thickness _____ height _____	11. BEDROOM WINDOWS height _____ width _____ sill height _____ egress window? yes ☐ no ☐
4. FOUNDATION: type _____ thickness _____ footing _____		
5. ROOF: type _____ pitch _____ covering _____ load _____		
6. PLUMBING: yes ☒ SPRINKLER SYSTEM? yes ☒ no ☐		

VIII. OFFICE USE: TAX MAP # _____ LOT # _____ VALUE/STRUCTURE _____ PERMIT EXPIRATION _____	IX. NEW OR PHASED SUBDIVISION REFERENCE Name _____ Lot _____ Block _____
---	---

CODE: If other, explain _____ Seasonal ☐ Condominium ☐ Apartment ☒

X. PROPOSED USE: 322 - 1st floor

XI. PAST USE: Vacant

XII. OWNERSHIP: PUBLIC ☐ PRIVATE ☒

XIII. EST. CONSTRUCTION COST: 238,800.00

XIV. GR. SQ. FT. OF LOT BUILDING _____

COMPLETE XV. AND XVI. ONLY IF THE NUMBER OF UNITS WILL CHANGE

XV. RESIDENTIAL BUILDINGS ONLY: # NEW DWELLING UNITS WITH: <u>1 BDRM</u> <u>2 BDRMS</u> <u>3 BDRMS</u> # EXISTING DWELLING UNITS WITH: _____	XVI. # RESIDENTIAL UNITS: # NEW DWELLINGS _____ # EXISTING DWELLINGS _____ TOTAL RESIDENTIAL UNITS _____
--	---

APPROVALS BY: _____ DATE _____ BUILDING INSPECTION - PLAN EXAMINER _____ ZONING: _____ C.E.O.: _____ FIRE DEPT: _____	MISCELLANEOUS Will work require dist. of any tree on a public street? <u>no</u> Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? <u>yes</u>
---	--

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical, and mechanicals.

District No. <u>7</u>	XVII. SIGNATURE OF APPLICANT <u>Paul Gilla</u> PHONE # <u>772-1122</u> TYPE NAME OF ABOVE <u>Paul Gilla</u> <u>1 2 3 4</u>
-----------------------	---

White - GPCOG Green - Applicant Yellow - Assessor Pink - Office File Gold - Field Inspector

Adatto

002037

CITY OF BUILDING PERMIT APPLICATION

MAP # LOT#

Fill out any part which applies to job. Proper plans must accompany form.

Owner: Office Tower A. Associates
Address: 38 Preble Street
LOCATION OF CONSTRUCTION: 100 Middle Street
CONTRACTOR: Office Tower A. Assoc. SUBCONTRACTORS:
ADDRESS: 38 Preble Street Office Complex
Est. Construction Cost: 89,000. Type of Use: Interior Renovations
Past Use:
Building Dimensions L W Sq. Ft. # Stories Lot Size:
Is Proposed Use: Seasonal Condominium Apartment
Conversion - Explain interior renovations (2 sets of plans)

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE

Residential Buildings Only:

Of Dwelling Units # Of New Dwelling Units

Foundation:

1. Type of Soil:
2. Set Backs - Front Rear Side(s)
3. Footings Size:
4. Foundation Size:
5. Other

Floor:

1. Sills Size: Sills must be anchored.
2. Girder Size:
3. Lally Column Spacing: Size:
4. Joists Size: Spacing 16" O.C.
5. Bridging Type: Size:
6. Floor Sheathing Type: Size:
7. Other Material:

Exterior Walls:

1. Studding Size Spacing
2. No. windows
3. No. Doors
4. Header Sizes Span(s)
5. Bracing: Yes No
6. Corner Posts Size
7. Insulation Type Size
8. Sheathing Type Size
9. Siding Type Weather Exposure
10. Masonry Materials
11. Metal Materials

Interior Walls:

1. Studding Size Spacing
2. Header Sizes Span(s)
3. Wall Covering Type
4. Fire Wall if required
5. Other Materials

For Official Use Only	
Date: April 19, 1989	Subdivision: Yes / No
Inside Fire Limit:	Name
Bldg Code:	Lot
Time Limit:	Block
Estimated Cost: 89,900.	Permit Expiration:
Value/Structure:	Ownership: Public Private
Fee: 465.00	

Ceiling:

1. Ceiling Joists Size:
2. Ceiling Strapping Size Spacing MAY 5 1989
3. Type Ceilings:
4. Insulation Type Size
5. Ceiling Height:

Roof:

1. Truss or Rafter Size Span
2. Sheathing Type Size
3. Roof Covering Type
4. Other

Chimneys:

Type: Number of Fire Places

Heating:

Type of Heat:

Electrical:

Service Entrance Size: Smoke Detector Required Yes No

Plumbing:

1. Approval of soil test if required Yes No
2. No. of Tubs or Showers
3. No. of Flushes
4. No. of Lavatories
5. No. of Other Fixtures

Swimming Pools:

1. Type:
2. Pool Size: x Square Footage
3. Mus. conform to National Electrical Code and State Law.

Zoning:

District Street Frontage Req. Provided
Required Setbacks: Front Back Side Side

Review Required:

Zoning Board Approval: Yes No Date:
Planning Board Approval: Yes No Date:
Conditional Use: Variance Site Plan Subdivision
Shore and Floodplain Mgmt. Special Exception
Other (Explain)
Date Approved

Permit Received By

Signature of Applicant: AS Agent for owner Date: 4/20/89

Signature of CEO: Date:

Inspection Dates: 5 aa

White-Tax Assessor

Yellow-GPCOG

White Tag -CEO

© Copyright GPCOG 1987

PERMIT # _____ CITY OF Portland BUILDING PERMIT APPLICATION

MAP # _____ LOT# _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Liberty Group

Address: 28 Preble St., Portland

LOCATION OF CONSTRUCTION: 100 Middle St., 5th floor

CONTRACTOR: J. V. R. Inc. SUBCONTRACTORS: 774-3969

ADDRESS: 13 Bates St., Portland, 04103

Est. Construction Cost: \$5,000 Type of Use: offices

Per Use: _____

Building Dimensions L _____ W _____ Sq Ft _____ # Stories: _____ Lot Size: _____

Is Proposed Use: _____ Seasonal _____ Condominium _____ Apartment _____

Conversion - Explain Erecting inner partitions. 1 set of floor plans submitted.

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE

Residential Buildings Only: _____

Of Dwelling Units _____ # Of New Dwelling Units _____

Foundation: _____

1. Type of Soil: _____

2. Set Backs - Front _____ Rear _____ Side(s) _____

3. Footings Size: _____

4. Foundation Size: _____

5. Other _____

Floor: _____

1. Sills Size: _____ Sills must be anchored.

2. Girder Size: _____

3. Lally Column Spacing: _____ Size: _____

4. Joists Size: _____ Spacing 16" O.C.

5. Bridging Type: _____ Size: _____

6. Floor Sheathing Type: _____ Size: _____

7. Other Material: _____

Exterior Walls: _____

1. Studding Size _____ Spacing _____

2. No. windows _____

3. No. Doors _____

4. Header Sizes _____ Span(s) _____

5. Bracing: Yes _____ No _____

6. Corner Posts Size _____

7. Insulation Type _____ Size _____

8. Sheathing Type _____ Size _____

9. Siding Type _____ Weather Exposure _____

10. Masonry Materials _____

11. Metal Materials _____

Interior Walls: _____

1. Studding Size _____ Spacing _____

2. Header Sizes _____ Span(s) _____

3. Wall Covering Type _____

4. Fire Wall if required _____

5. Other Materials _____

For Official Use Only	
Date: <u>March 15, 1989</u>	Subdivision: Yes / No _____
Inside Fire Limits _____	Name _____
Bldg Code _____	Lot _____
Time Limit _____	Block _____
Estimated Cost: <u>\$5,000</u>	Permit Expiration: _____
Value/Structure _____	Ownership: _____
Fee: <u>\$45.00</u>	Public / Private _____

Ceiling: _____

1. Ceiling Joists Size: _____

2. Ceiling Strapping Size _____ Spacing _____

3. Type Ceiling: _____

4. Insulation Type _____ Size _____

5. Ceiling Height: _____

Roof: _____

1. Truss or Rafter Size _____ Span _____

2. Sheathing Type _____ Size _____

3. Roof Covering Type _____

4. Other _____

Chimneys: _____

Type: _____ Number of Fire Places _____

Heating: _____

Type of Heat: _____

Electrical: _____

Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing: _____

1. Approval of soil test if required Yes _____ No _____

2. No. of Tubs or Showers _____

3. No. of Flushes _____

4. No. of Lavatories _____

5. No. of Other Fixtures _____

Swimming Pools: _____

1. Type: _____

2. Pool Size: _____ x _____ Square Footage _____

3. Must conform to National Electrical Code and State Law.

Zoning: _____

District _____ Street Frontage Req. _____ Provided _____

Required Setbacks: Front _____ Back _____ Side _____

Review Required: _____

Zoning Board Approval: Yes _____ No _____ Date: _____

Planning Board Approval: Yes _____ No _____ Date: _____

Conditional Use _____ Variance _____ Site Plan _____ Subdivision _____

Shore and Floodplain Mgmt _____ Special Exception _____

Other (Explain) _____

Date Approved _____

Permit Received By Nancy Grossman

Signature of Applicant James R. Gross AS AGT. for Owner Date 3/15/89

Signature of CEO Da Date _____

Inspection Dates _____

White-Tax Assessor

Yellow-GPCOG

White Tag -CEO

© Copyright GPCOG 1987

PLUMBING APPLICATION

PROPERTY ADDRESS

Town Or Plantation: PORTLAND

Street Subdivision Lot #: 100 N. MAIN STREET

PROPERTY OWNERS NAME 771 FOX

Last: LILANDY First: LILANDY

Applicant Name: ARTEMP

Mailing Address of Owner/Applicant (if Different): 310 Main Street SOUTH PORTLAND, ME 04106

Department of Human Services
Division of Health Engineering
(207) 289-3826

PORTLAND PERMIT # 3,417 TOWN COPY

Date Permit Issued: 5/12/89 \$ 111.61 FEE

Local Plumbing Inspector Signature: [Signature] L.P.I. # 1123

Owner/Applicant Statement

I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspector to deny a Permit.

Signature: [Signature] Date: 5/12/89

Caution: Inspection Required

I have inspected the installation authorized above and found it to be in compliance with the Maine Plumbing Rules.

Signature of Owner/Applicant: _____ Date: _____ Local Plumbing Inspector Signature: _____ Date Approved: _____

PERMIT INFORMATION

This Application is for:

1. ☒ NEW PLUMBING

2. ☐ RELOCATED PLUMBING

Type Of Structure To Be Served:

1. ☐ SINGLE FAMILY DWELLING

2. ☐ MODULAR OR MOBILE HOME

3. ☐ MULTIPLE FAMILY DWELLING

4. ☒ OTHER - SPECIFY OFFICE BUILDING

Plumbing To Be Installed By:

1. ☒ MASTER PLUMBER

2. ☐ OIL BURNERMAN

3. ☐ MFG'D. HOUSING DEALER/MECHANIC

4. ☐ PUBLIC UTILITY EMPLOYEE

5. ☐ PROPERTY OWNER

LICENSE # 06219

Hook-Up & Piping Relocation Maximum of 1 Hook-Up	Number	Column 2 Type of Fixture	Number	Column 1 Type of Fixture
HOOK-UP: to public sewer in those cases where the connection is not regulated and inspected by the local Sanitary District. OR HOOK-UP: to an existing subsurface wastewater disposal system.		Hosebibb / Sillcock		Bathtub (and Shower)
		Floor Drain		Shower (Separate)
		Urinal	1	Sink
		Drinking Fountain		Wash Basin
		Indirect Waste		Water Closet (Toilet)
		Water Treatment Softener, Filter, etc.		Clothes Washer
PIPING RELOCATION: of sanitary lines, drains, and piping without new fixtures.		Grease/Oil Separator		Dish Washer
		Dental Cuspidor		Garbage Disposal
		Bidet		Laundry Tub
Number of Hook-Ups & Relocations		Other: _____	1	Water Heater
Hook-Up & Relocation Fee		Fixtures (Subtotal) Column 2	2	Fixtures (Subtotal) Column 1
SEE PERMIT FEE SCHEDULE FOR CALCULATING FEE			0	Fixtures (Subtotal) Column 2
			2	Total Fixtures
			\$ 6.	Fixture Fee
			\$	Hook-Up & Relocation Fee
			\$ 6.	Permit Fee (Total)

TOWN COPY



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date February 13, 1989
Receipt and Permit number 00035

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 100 Middle St. 6th Floor Tower A

OWNER'S NAME: Liberty Group ADDRESS: Preble St.

	FEE
OUTLETS:	
Receptacles 120 Switches 35 Plugmold _____ ft. TOTAL 155.....	14.50
FIXTURES: (number of)	
Incandescent _____ Fluorescent 135 (not strip) TOTAL	15.50
Strip Fluorescent _____ ft.	
SERVICES:	
Overhead _____ Underground _____ Temporary _____ TOTAL amperes ..	
METERS: (number of)	
MOTORS: (number of)	
Fractional	
1 HP or over 8	8.00
RESIDENTIAL HEATING:	
Oil or Gas (number of units)	
Electric (number of rooms)	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler)	
Oil or Gas (by separate units)	
Electric Under 20 kws _____ Over 20 kws	
APPLIANCES: (number of)	
Ranges _____ Water Heaters _____	
Cook Tops _____ Disposals _____	
Wall Ovens _____ Dishwashers _____	
Dryers _____ Compactors _____	
Fans _____ Others (denote) _____	
TOTAL	
MISCELLANEOUS: (number of)	
Branch Panels 1	1.00
Transformers 1	2.00
Air Conditioners Central Unit	
Separate Units (windows)	
Signs 20 sq. ft. and under	
Over 20 sq. ft.	
Swimming Pools Above Ground	
In Ground	
Fire/Burglar Alarms Residential	
Commercial	
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under	
over 30 amps	
Circus, Fairs, etc.	
Alterations to wires	
Repairs after fire	
Emergency Lights, battery	
Emergency Generators	
INSTALLATION FEE DUE:	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE:	
FOR REMOVAL OF A "STOP ORDER" (304-16.b)	
TOTAL AMOUNT DUE:	41.00

INSPECTION:

Will be ready on _____, 19__; or Will Call X

CONTRACTOR'S NAME: Brian H. Milliken

ADDRESS: 114249 Middle Road Falmouth, Maine 04105

TEL: 879-1877

MASTER LICENSE NO.: 3604

LIMITED LICENSE NO.: _____

SIGNATURE OF CONTRACTOR:

Brian H. Milliken

INSPECTOR'S COPY — WHITE

OFFICE COPY — CANARY

CONTRACTOR'S COPY — GREEN

INSPECTIONS: Service _____ by _____
Service called in _____
Closing-in 2/24/89 by A. [unclear]

PROGRESS INSPECTIONS: _____

ELECTRICAL INSTALLATIONS —
Permit Number: 00035
Location: 190 Middle St. - Town A (6441)
Owner: Seabury, Strong
Date of Permit: 2/20/89
Final Inspection: 4/19/89
By Inspector: [Signature]
Permit Applicant a Register Page No. 26

DATE:	REMARKS:
<u>2/14/89</u>	<u>On Closing inspection direct electrician to permit # 29292 done on 6/28/88 as an inspection (final) can be made above suspended ceiling on the 5th floor of Town (B) this is done by the same electrician on this permit.</u>
<u>3/2/89</u>	<u>South west wing - walls may be closed and to</u>

CODE
COMPLIANCE
COMPLETED
DATE 4/19/89

PLUMBING APPLICATION

PROPERTY ADDRESS

Town or Plantation: _____

Street: _____

Subdivision Lot #: _____

PROPERTY OWNERS NAME

Last: _____ First: _____

Applicant Name: _____

Mailing Address of Owner/Applicant (if Different): _____

Department of Human Services
Division of Health Engineering
(207) 289-3526

PORTLAND **PERMIT # 3,314** **TOWN COPY**

Fee: \$1,212.89 **Fee:** \$1,191.04 **Double Fee Charged**

L.P.I. # 11213

Local Plumbing Inspector Signature: _____

Owner/Applicant Statement

I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspector to deny a Permit.

Signature of Owner/Applicant _____

Date _____

Caution: Inspection Required

I have inspected the installation authorized above and found it to be in compliance with the Maine Plumbing Rules.

Local Plumbing Inspector Signature _____

Date Approved _____

PERMIT INFORMATION

This Application is for

1. ☒ NEW PLUMBING
2. ☐ RELOCATED PLUMBING

Type Of Structure To Be Served:

1. ☐ SINGLE FAMILY DWELLING
2. ☐ MODULAR OR MOBILE HOME
3. ☐ MULTIPLE FAMILY DWELLING
4. ☐ OTHER - SPECIFY _____

Plumbing To Be Installed By:

1. ☒ MASTER PLUMBER
2. ☐ OIL BURNERMAN
3. ☐ MFG'D. HOUSING DEALER/MECHANIC
4. ☐ PUBLIC UTILITY EMPLOYEE
5. ☐ PROPERTY OWNER

LICENSE # 12345

Hook-Up & Piping Relocation Maximum of 1 Hook-Up		Number	Column 2 Type of Fixture	Number	Column 1 Type of Fixture
HOOK-UP: to public sewer in those cases where the connection is not regulated and inspected by the local Sanitary District. OR HOOK-UP: to an existing subsurface wastewater disposal system.			Hosebibb / Silcock		Bathtub (and Shower)
			Floor Drain		Shower (Separate)
			Urinal		Sink
			Drinking Fountain		Wash Basin
			Indirect Waste		Water Closet (Toilet)
			Water Treatment Softener, Filter, etc.		Clothes Washer
PIPING RELOCATION: of sanitary lines, drains, and piping without new fixtures.			Grease/Oil Separator		Dish Washer
			Dental Cuspidor		Garbage Disposal
			Bidet		Laundry Tub
Number of Hook Ups & Relocations			Other: _____		Water Heater
\$ Hook-Up & Relocation Fee			Fixtures (Subtotal) Column 2	3	Fixtures (Subtotal) Column 1
SEE PERMIT FEE SCHEDULE FOR CALCULATING FEE					Fixtures (Subtotal) Column 2
					Total Fixtures
				\$ 7.50	Fixture Fee
				\$	Hook-Up & Relocation Fee
				\$ 7.50	Permit Fee (Total)



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 109 Middle Street

Issued to Liberty Group

Date of Issue April 13, 1989

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. S9/1697, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

6th Floor Tower A

APPROVED OCCUPANCY

Offices

Limiting Conditions:
None

This certificate supersedes
certificate issued

Approved:

(Date)

Inspector

Inspector of Buildings

Note: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

PERMIT # _____ TOWN OF PORTLAND BUILDING PERMIT APPLICATION MAP # _____ LOT# _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Liberty Group 6 FL / Bldg A

Address: 100 Middle Street, Portland, ME

LOCATION OF CONSTRUCTION: 100 Middle Street, Portland, ME

CONTRACTOR: Allied Construction Co., Inc. SUBCONTRACTORS: 772-2888

ADDRESS: 100 Fore St., Portland, ME 04104

Est. Construction Cost: \$14,350 Type of Use: Office

Past Use: _____

Building Dimensions L _____ W _____ Sq. Ft. _____ # Stories _____ Lot Size _____

Is Proposed Use _____ Seasonal _____ Condominium _____ Apartment _____

Conversion - Explain: Alterations of empty space to offices.

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE

Residential Buildings Only: _____

Of Dwelling Units _____ # Of New Dwelling Units _____

Foundation:

1. Type of Soil: _____

2. Set Backs - Front _____ Rear _____ Side(s) _____

3. Footings Size: _____

4. Foundation Size: _____

5. Other: _____

Floor:

1. Sills Size: _____ Sills must be anchored.

2. Girder Size: _____

3. Lally Column Spacing: _____ Size: _____

4. Joists Size: _____ Spacing 16" O.C.

5. Bridging Type: _____ Size: _____

6. Floor Sheathing Type: _____ Size: _____

7. Other Material: _____

Exterior Walls:

1. Studding Size _____ Spacing _____

2. No. windows _____

3. No. Doors _____

4. Header Sizes _____ Span(s) _____

5. Bracing: Yes _____ No _____

6. Corner Posts Size _____

7. Insulation Type _____ Size _____

8. Sheathing Type: _____ Size _____

9. Siding Type _____ Weather Exposure _____

10. Masonry Materials _____

11. Metal Materials _____

Interior Walls:

1. Studding Size _____ Spacing _____

2. Header Sizes _____ Span(s) _____

3. Wall Covering Type _____

4. Fire Wall if required _____

5. Other Materials _____

For Official Use Only

Date: Feb. 2, 1989 Subdivision: Yes / No _____
 Inside Fire Limits: _____ Name: _____
 Block: _____
 Time Limit: _____ Block: _____
 Estimated Cost: \$14,350 Permit Expiration: _____
 Value: _____ Ownership: _____
 Fee: \$377.00 Public _____ Private _____

Ceiling:

1. Ceiling Joists Size: _____

2. Ceiling Strapping Size _____ Spacing: SPACING ISSUED

3. Type Ceiling: _____

4. Insulation Type _____ Size: FEB 21 1989

5. Ceiling Height: _____

Roof:

1. Truss or Rafter Size: _____

2. Sheathing Type: _____

3. Roof Covering Type: _____

4. Other: _____

Chimneys:

Type: _____ Number of Fire Places _____

Heating:

Type of Heat: _____

Electrical:

Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:

1. Approval of soil test if required Yes NOE No _____

2. No. of Tubs or Showers _____

3. No. of Flushes _____

4. No. of Lavatories _____

5. No. of Other Fixtures _____

Swimming Pools:

1. Type: _____

2. Pool Size: _____ x _____ Square Footage _____

3. Must conform to National Electrical Code and State Law.

Zoning:

District: B-3 Street Frontage Req: _____ Provided _____

Required Setbacks: Front _____ Back _____ Side _____

Review Required:

Zoning Board Approval: Yes _____ No _____ Date: _____

Planning Board Approval: Yes _____ No _____ Date: _____

Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____

Shore and Floodplain Mgmt _____ Special Exception _____

Other (Explain) _____

Date Approved: 2-2-89

Permit Received By: Travis M. Rinaldi

Signature of Applicant: Philip Desjardine Date: 2-2-89

Signature of CEO: Philip Desjardine Date: 2-2-89

Inspection Date: _____

White-Tax Assessor

Yellow-GPCOG

White Tag - CEO

Copyright GPCOG 1987

PLOT PLAN

N



FEES (Breakdown From Front)

Base Fee \$ 390.00
 Subdivision Fee \$
 Site Plan Review Fee \$
 Other Fees \$
 (Explain)
 Late Fee \$

Inspection Record

Type

Date

COMMENTS

Signature of Applicant Chris Dumaire
for Allied Construction Co., Inc.

Date 2-2-89

PERMIT # 002721 CITY OF PORTLAND BUILDING PERMIT APPLICATION

MAP # _____ LOT# _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: LIBERTY GROUP

Address: 38 PEARLE ST, PORTLAND, ME Tel 772-0548

LOCATION OF CONSTRUCTION 100 MIDDLE ST, PORTLAND, ME

CONTRACTOR: ALLIED CONSTRUCTION CO., INC. SUBCONTRACTORS: _____

ADDRESS: 208 FORE ST, PORTLAND, ME Tel 772-2890

Est. Construction Cost: \$122,000 Type of Use: OFFICE

Past Use: _____

Building Dimensions L _____ W _____ Sq. Ft. _____ # Stories: _____ Lot Size: _____

Is Proposed Use: _____ Seasonal _____ Condominium _____ Apartment _____

Conversion - Explain Tenant fit up. 2 sets of construction plans submitted.

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE

Residential Buildings Only:

Of Dwelling Units _____ # Of New Dwelling Units _____

Foundation:

1. Type of Soil: _____
2. Set Backs - Front _____ Rear _____ Side(s) _____
3. Footings Size: _____
4. Foundation Size: _____
5. Other _____

Floor:

1. Sills Size: _____ Sills must be anchored.
2. Gilder Size: _____
3. Lally Column Spacing: _____ Size: _____
4. Joists Size: _____ Soacing 16" O.C.
5. Bridging Type: _____ Size: _____
6. Floor Sheathing Type: _____ Size: _____
7. Other Material: _____

Exterior Walls:

1. Scladding Size _____ Spacing _____
2. No. windows _____
3. No. Doors _____
4. Header Sizes _____ Span(s) _____
5. Bracing: Yes _____ No _____
6. Corner Posts Size _____
7. Insulation Type _____ Size _____
8. Sheathing Type _____ Size _____
9. Siding Type _____ Weather Exposure _____
10. Masonry Materials _____
11. Metal Materials _____

Interior Walls:

1. Studding Size _____ Spacing _____
2. Header Sizes _____ Span(s) _____
3. Wall Covering Type _____
4. Fire Wall if required _____
5. Other Materials _____

For Official Use Only	
Date <u>June 27, 1989</u>	Subdivision: Yes ☐ No ☐
Inside Fire Limits _____	Name _____
Edg Code _____	Lot _____
Time Limit _____	Block _____
Estimated Cost <u>\$122,000</u>	Permit Expiration _____
Value/Structure _____	Overship _____
Fee <u>\$630.00</u>	Private _____

Ceiling:

1. Ceiling Joists Size: _____
2. Ceiling Strapping Size _____ Spacing _____
3. Type Ceiling: _____
4. Insulation Type _____ Size _____
5. Ceiling Height: _____

Roof:

1. Truss or Rafter Size _____ Span JUL 13 1990
2. Sheathing Type _____ Size _____
3. Roof Covering Type _____
4. Other _____

Chimneys:

Type: _____ Number of Fire Places _____

Heating:

Type of Heat: _____

Electrical:

Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:

1. Approval of soil test if required Yes _____ No _____
2. No. of Tubs or Showers _____
3. No. of Flushes _____
4. No. of Lavatories _____
5. No. of Other Fixtures _____

Swimming Pools:

1. Type: _____
2. Pool Size: _____ x _____ Square Footage _____
3. Must conform to National Electrical Code and State Law.

Zoning:

District _____ Street Frontage Req. _____ Provided _____

Review Required:

Required Setbacks: Front _____ Back _____ Side _____ Side _____

Zoning Board Approval: Yes _____ No _____ Date: _____

Planning Board Approval: Yes _____ No _____ Date: _____

Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____

Shore and Floodplain Mgmt _____ Special Exception _____

Other (Explain) _____

Date Approved _____

Permit Received By Nancy Grossman

Signature of Applicant Maire Dumaine Date 6-27-89

Signature of CEO _____ Date _____

Inspection Dates See

White-Trx Assessor

Yellow-GPCOG

White Tag-CEO

© Copyright GPCOG 1987



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date May 11, 1990
Receipt and Permit number 01295

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 100 Middle Street Plaza 5th floor
OWNER'S NAME: Bernstein, Shur, Sawyer ADDRESS: Same
Nelson

	FEES
OUTLETS:	
Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL <u>30</u>	<u>3.00</u>
FIXTURES: (number of)	
Incandescent _____ Fluorescent <u>24</u> (not strip) TOTAL <u>24</u>	<u>4.40</u>
Strip Fluorescent _____ ft. _____	
SERVICES:	
Overhead _____ Underground _____ Temporary _____ TOTAL amperes _____	
METERS: (number of) _____	
MOTORS: (number of)	
Fractional _____	
1 HP or over _____	
RESIDENTIAL HEATING:	
Oil or Gas (number of units) _____	
Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler) _____	
Oil or Gas (by separate units) _____	
Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of)	
Ranges _____	Water Heaters _____
Cook Tops _____	Disposals _____
Wall Ovens _____	Dishwashers _____
Dryers _____	Compactors _____
Fans _____	Others (denote) _____
TOTAL _____	
MISCELLANEOUS: (number of)	
Branch Panels _____	
Transformers _____	
Air Conditioners Central Unit _____	
Separate Units (windows) _____	
Signs 20 sq. ft. and under _____	
Over 20 sq. ft. _____	
Swimming Pools Above Ground _____	
In Ground _____	
Fire/Burglar Alarms Residential _____	
Commercial _____	
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
over 30 amps _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Emergency Lights, battery <u>x</u> _____	<u>.50</u>
Emergency Generators _____	
INSTALLATION FEE DUE: _____	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE: _____	
FOR REMOVAL OF A "STOP ORDER" (304-16.b) TOTAL AMOUNT DUE: <u>7.90</u>	

INSPECTION: 5/14
Will be ready on Monday, 1990; or Will Call _____
CONTRACTOR'S NAME: Herbert Elec.
ADDRESS: 29 Capisic St. Portland, Maine 04102
TEL: 774-9540
MASTER LICENSE NO.: 02576 SIGNATURE OF CONTRACTOR: Herbert Elec.
LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
OFFICE COPY — CANARY
CONTRACTOR'S COPY — GREEN

ELECTRICAL INSULATIONS —

Permit Number 0-2-22

Location 100m x 100m

Owner: Deans, L. E. & Son, Inc.

Date of Permit 2-11-60

Final Inspection

By Inspection
[Signature]

Permit No. _____ Union Register Page No. _____

INSPECTIONS: Service _____ by _____
Service called in _____
Closing-in 5-14-90 b. SB

PROGRESS INSPECTIONS: _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____

DATE:

REMARKS:

[illegible]



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date 10/30/90, 19
Receipt and Permit number 01703

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 100 Middle St. - Tower B - second floor

OWNER'S NAME: Liberty Gp ADDRESS: same

	FEES
OUTLETS:	
Receptacles <u>30</u> Switches <u>10</u> Plugmols <u> </u> ft. TOTAL <u>40</u>	5.00
FIXTURES: (number of)	
Incandescent <u> </u> Fluorescent <u>20</u> (not strip) TOTAL <u>20</u>	4.00
Strip Fluorescent <u> </u> ft.	
SERVICES:	
Overhead <u>x</u> Underground <u> </u> Temporary <u> </u> TOTAL amperes <u> </u>	
METERS: (number of) <u>1</u>	.50
MOTORS: (number of)	
Fractional <u> </u>	
1 HP or over <u> </u>	
RESIDENTIAL HEATING:	
Oil or Gas (number of units) <u> </u>	
Electric (number of rooms) <u> </u>	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler) <u> </u>	
Oil or Gas (by separate units) <u> </u>	
Electric Under 20 kws <u>x</u> Over 20 kws <u> </u>	5.00
APPLIANCES: (number of)	
Ranges <u> </u> Water Heaters <u> </u>	
Cook Tops <u> </u> Disposals <u> </u>	
Wall Ovens <u> </u> Dishwashers <u> </u>	
Dryers <u> </u> Compactors <u> </u>	
Fans <u> </u> Others (denote) <u> </u>	
TOTAL <u> </u>	
MISCELLANEOUS: (number of)	
Branch Panels <u>1</u>	1.00
Transformers <u> </u>	
Air Conditioners Central Unit <u>x</u>	5.00
Separate Units (windows) <u> </u>	
Signs 20 sq. ft. and under <u> </u>	
Over 20 sq. ft. <u> </u>	
Swimming Pools Above Ground <u> </u>	
In Ground <u> </u>	
Fire/Burglar Alarms Residential <u> </u>	
Commercial <u>x</u>	5.00
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under <u> </u>	
over 30 amps <u> </u>	
Circus, Fairs, etc. <u> </u>	
Alterations to wires <u> </u>	
Repairs after fire <u> </u>	
Emergency Lights, battery <u>2</u>	1.00
Emergency Generators <u> </u>	

INSTALLATION FEE DUE:
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE:
FOR REMOVAL OF A "STOP ORDER" (304-16.b)
TOTAL AMOUNT DUE: 26.50

INSPECTION: If possible, please
Will be ready on 10/31/-pm, 19 ; or Will Call
CONTRACTOR'S NAME: Michael Keeley
ADDRESS: Box 3235; Ptd, ME 04104
TEL.: 797-3772
MASTER LICENSE NO.: #04176 SIGNATURE OF CONTRACTOR: Michael Keeley
LIMITED LICENSE NO.:

INSPECTOR'S COPY — WHITE
OFFICE COPY — CANARY
CONTRACTOR'S COPY — GREEN



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date May 3, 1989
Receipt and Permit number 00277

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 100 Middle St. - 7th fl

OWNER'S NAME: Allied Construction ADDRESS: 208 Fore St. Portland

OUTLETS: Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL 80 FEES 7.00

FIXTURES: (number of) Incandescent _____ Fluorescent 100 (not strip) TOTAL 100 12.00

Strip Fluorescent 48 ft. 3.00

SERVICES: Overhead _____ Underground _____ Temporary _____ TOTAL amperes _____

METERS: (number of) _____

MOTORS: (number of) Fractional 8 4.00

1 HP or over _____

RESIDENTIAL HEATING: Oil or Gas (number of units) _____

Electric (number of rooms) _____

COMMERCIAL OR INDUSTRIAL HEATING: Oil or Gas (by a main boiler) _____

Oil or Gas (by separate units) _____

Electric Under 20 kws _____ Over 20 kws _____

APPLIANCES: (number of) Ranges _____ Water Heaters _____

Cook Tops _____ Disposals _____

Wall Ovens _____ Dishwashers _____

Dryers _____ Compactors _____

Fans _____ Others (denote) _____

TOTAL _____

MISCELLANEOUS: (number of) Branch Panels _____

Transformers _____

Air Conditioners Central Unit _____

Separate Units (windows) _____

Signs 20 sq. ft. and under _____

Over 20 sq. ft. _____

Swimming Pools Above Ground _____

In Ground _____

Fire/Burglar Alarms Residential _____

Commercial 1 5.00

Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____

over 30 amps _____

Circus, Fairs, etc. _____

Alterations to wires _____

Repairs after fire _____

Emergency Lights, battery _____

Emergency Generators _____

INSTALLATION FEE DUE: _____

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE: _____

FOR REMOVAL OF A "STOP ORDER" (304-16.b) TOTAL AMOUNT DUE: 31.00

INSPECTION: Will be ready on _____, 19____; or Will Call X

CONTRACTOR'S NAME: Larry R. Favreau

ADDRESS: RFD 1 Box 446 Orrs Island, Maine 04066

TEL: 725-2005

MASTER LICENSE NO.: 6232 SIGNATURE OF CONTRACTOR: Larry R. Favreau

LIMITED LICENSE NO.: 04232

Permit Number 04611
Location 100 Middle St
Owner ALIED CONSTRUCTION
Date of Permit _____
Final Inspection _____
By Inspector [Signature]
Permit Application Register Page No. 62

INSPECTIONS: Service _____ by _____
 Service called in _____
 Closing-in _____ by _____

PROGRESS INSPECTIONS: _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____

[illegible][illegible]

FOR ADDITIONAL WORK NOT ON ORIGINAL ORDER	INSTALLATION FEE PER HOUR
FOR REPAIR OF A CLOUP ORDER, 10% OFF	DUPLICATE PER HOUR
	TOTAL AMOUNT DUE

1. NAME
 2. ADDRESS
 3. CITY
 4. STATE
 5. ZIP
 6. PHONE NO.
 7. FAX NO.
 8. E-MAIL ADDRESS
 9. WEBSITE
 10. OTHER



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date July 6, 1989
Receipt and Permit number _____

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 100 Middle Street - 5th floor

OWNER'S NAME: Barry Dunn

ADDRESS: _____

		FEES
OUTLETS:		
Receptacles <u>68</u>	Switches <u>32</u> Plugmold _____ ft. TOTAL <u>100</u>	<u>9.00</u>
FIXTURES: (number of)		
Incandescent <u>7</u>	Flourescent <u>92</u> (not strip) TOTAL <u>99</u>	<u>8.90</u>
Strip Flourescent _____ ft.		
SERVICES:		
Overhead _____	Underground _____ Temporary _____ TOTAL amperes _____	
METERS: (number of) _____		
MOTORS: (number of)		
Fractional _____		
1 HP or over _____		
RESIDENTIAL HEATING:		
Oil or Gas (number of units) _____		
Electric (number of rooms) _____		
COMMERCIAL OR INDUSTRIAL HEATING:		
Oil or Gas (by a main boiler) _____		
Oil or Gas (by separate units) _____		
Electric Under 20 kws _____ Over 20 kws _____		
APPLIANCES: (number of)		
Ranges _____	Water Heaters _____	
Cook Tops _____	Disposals _____	
Wall Ovens _____	Dishwashers _____	
Dryers _____	Compactors _____	
Fans _____	Others (denote) _____	
TOTAL: _____		
MISCELLANEOUS: (number of)		
Branch Panels <u>2</u>		<u>2.00</u>
Transformers _____		
Air Conditioners Central Unit <u>3</u>		<u>15.00</u>
Separate Units (windows) _____		
Signs 20 sq. ft. and under _____		
Over 20 sq. ft. _____		
Swimming Pools Above Ground _____		
In Ground _____		
Fire/Burglar Alarms Residential _____		
Commercial _____		
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____		
over 30 amps _____		
Circus, _____		
Alterations _____		
Repairs at _____		
Emergency lights, battery _____		
Emergency Generators _____		

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT INSTALLATION FEE DUE:
FOR REMOVAL OF A "STOP ORDER" (304-16.b) DOUBLE FEE DUE:

TOTAL AMOUNT DUE: 34.90

INSPECTION:

Will be ready on Ready, 1989; or Will Call _____

CONTRACTOR'S NAME: Energy Electric

ADDRESS: 296 Warren Avenue

TEL.: _____

MASTER LICENSE NO.: 4645

LIMITED LICENSE NO.: _____

SIGNATURE OF CONTRACTOR:

James K. Dunn



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date August 9, 1989
Receipt and Permit number 60672

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 100 Middle St. 5th floor West Tower (UNUM)
OWNER'S NAME: Middle St. Inv. Assoc. ADDRESS: 38 Preble St. Portland

	FEES
OUTLETS: Receptacles <u>50</u> Switches <u>5</u> Plugmold _____ ft. TOTAL <u>55</u>	5.00
FIXTURES: (number of) Incandescent _____ Fluorescent <u>62</u> (not strip) TOTAL <u>62</u> Strip Fluorescent _____ ft.	8.20
SERVICES: Overhead _____ Underground _____ Temporary _____ TOTAL amperes _____	
METERS: (number of) _____	
MOTORS: (number of) Fractional _____ 1 HP or over _____	
RESIDENTIAL HEATING: Oil or Gas (number of units) _____ Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING: Oil or Gas (by a main boiler) _____ Oil or Gas (by separate units) _____ Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of) Ranges _____ Water Heaters _____ Cook Tops _____ Disposals _____ Wall Ovens _____ Dishwashers _____ Dryers _____ Compactors _____ Fans _____ Others (denote) _____	
TOTAL _____	
MISCELLANEOUS: (number of) Branch Panels _____ Transformers _____ Air Conditioners Central Unit _____ Separate Units (windows) _____ Signs 20 sq. ft. and under _____ Over 20 sq. ft. _____ Swimming Pools Above Ground _____ In Ground _____ Fire/Burglar Alarms Residential _____ Commercial _____ Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____ over 30 amps _____ Circus, Fairs, etc. _____ Alterations to wires _____ Repairs after fire _____ Emergency Lights, battery _____ Emergency Generators _____	

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT INSTALLATION FEE DUE:
FOR REMOVAL OF A "STOP ORDER" (304-16.b) DOUBLE FEE DUE:

TOTAL AMOUNT DUE: 13.20

INSPECTION:
Will be ready on 8/11/89 P.M., 1989; or Will Call X
CONTRACTOR'S NAME: Bay Electric Co., Inc.
ADDRESS: P.O. Box 6316 City Elizabeth, Maine 0417
TEL: 799-0350
MASTER LICENSE NO.: 09171 SIGNATURE OF CONTRACTOR: [Signature]
LIMITED LICENSE NO.: _____

Permit Number 00-6002

By Inspector A. J. Jones

Final Inspection 7/5/59

Date of Permit 8/2/89

Owner Phadolski, AT - Union

Location 100 Mueller St

INSPECTIONS: Service _____ by _____
Service called in _____
Closing-in 8/4/89 by [Signature]

PROGRESS INSPECTIONS: _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____

[illegible]

FOR REMOVAL OF A "STOP ORDER" (See 1-6)
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT
.. DOUBLE PER DUE
INSTALLATION PER DUE
TOTAL AMOUNT DUE

INSPECTION
Will be ready on 11/11/54
CONTRACTOR'S NAME: THE CONTRACTOR
ADDRESS: 100-1000
TEL: 100-1000
CATERING LICENSE NO: 100-1000
LIMITED LICENSE NO: 100-1000
SIGNATURE OF CONTRACTOR: 100-1000
100-1000



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICE
ELECTRICAL INSTALLATIONS

Date January 30, 1989
Receipt and Permit number 29998

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 100 Middle

OWNER'S NAME: Liberty Group

ADDRESS: _____

	FEES
OUTLETS:	
Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL _____	
FIXTURES: (number of)	
Incandescent _____ Fluorescent _____ (not strip) TOTAL _____	
Strip Fluorescent _____ ft. _____	
SERVICES:	
Overhead _____ Underground _____ Temporary _____ TOTAL amperes _____	
METERS: (number of) _____	
MOTORS: (number of)	
Fractional _____	
1 HP or over _____	
RESIDENTIAL HEATING:	
Oil or Gas (number of units) _____	
Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler) _____	
Oil or Gas (by separate units) _____	
Electric Under 20 kws <u>16</u> Over 20 kws <u>16</u> 48 kws total _____	10.00
APPLIANCES: (number of)	
Ranges _____	Water Heaters _____
Cook Tops _____	Disposals _____
Wall Ovens _____	Dishwashers _____
Dryers _____	Compactors _____
Fans _____	Others (denote) _____
TOTAL _____	
MISCELLANEOUS: (number of)	
Branch Panels _____	
Transformers _____	
Air Conditioners Central Unit _____	
Separate Units (windows) _____	
Signs 20 sq. ft. and under _____	
Over 20 sq. ft. _____	
Swimming Pools Above Ground _____	
In Ground _____	
Fire/Burglar Alarms Residential _____	
Commercial _____	
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
or 30 amps _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Emergency Lights, battery _____	
Emergency Generators _____	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT _____	INSTALLATION FEE DUE: _____
FOR REMOVAL OF A "STOP ORDER" (304-16.b) _____	DOUBLE FEE DUE: _____
	TOTAL AMOUNT DUE: <u>10.00</u>

INSPECTION:

Will be ready on _____, 19__; or Will Call XX

CONTRACTOR'S NAME: Favreau's Elec.

ADDRESS: P.O. Box 598 #37 Jordan Ave. Brunswick

TEL: _____

MASTER LICENSE NO.: 4232 (4232)

LIMITED LICENSE NO.: _____

SIGNATURE OF CONTRACTOR: _____

Randy P. Favreau

Permit Number 1449
Location 100 Maple St
Owner J. B. Smith
Date of Permit 1/25/11
Final Inspection [Signature]
By Inspector [Signature]
Permit Application Register Page No. 55

INSPECTIONS: Service _____ by _____
 Service called in _____
 Closing-in _____ by _____

PROGRESS INSPECTIONS: _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____

[illegible]

FOR REMOVAL OF A "STOP ORDER" (69-181)
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT

TOTAL AMOUNT DUE:

INSTALLATION FEE DUE:

Emergency Generator
Emergency Lighting System
Repairs after fire
Alterations to wiring
Current Panels, etc.

100 Volt branch circuit weight 30 amps and under
over 30 amps

DATE: _____
TIME: _____
BY: _____
CITY: _____
STATE: _____
COUNTY: _____
ZIP: _____

UNITED LICENSE
 MASTER LICENSE NO.
 TITLE
 ADDRESS
 CONTRACTOR'S NAME
 Will be ready on
 19
 of Will Call



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date May 9, 1989, 19
Receipt and Permit number 00300

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 100 Middle St. 5th floor
OWNER'S NAME: Liberty Group ADDRESS: _____

FRES

OUTLETS:		
Receptacles _____	Switches _____	Plugmold _____ ft. TOTAL _____
FIXTURES: (number of)		
Incandescent _____	Flourescent <u>23</u> (not strip) TOTAL <u>23</u>	4.30
Strip Flourescent _____	ft. _____	
SERVICES:		
Overhead _____	Underground _____	Temporary _____ TOTAL amperes _____
METERS: (number of) _____		
MOTORS: (number of)		
Fractional _____		
1 HP or over _____		
RESIDENTIAL HEATING:		
Oil or Gas (number of units) _____		
Electric (number of rooms) _____		
COMMERCIAL OR INDUSTRIAL HEATING:		
Oil or Gas (by a main boiler) _____		
Oil or Gas (by separate units) _____		
Electric Under 20 kws _____	Over 20 kws _____	
APPLIANCES: (number of)		
Ranges _____	Water Heaters _____	
Cook Tops _____	Disposals _____	
Wall Ovens _____	Dishwashers _____	
Dryers _____	Compactors _____	
Fans _____	Others (denote) _____	
TOTAL _____		
MISCELLANEOUS: (number of)		
Branch Panels _____		
Transformers _____		
Air Conditioners Central Unit _____		
Separate Units (windows) _____		
Signs 20 sq. ft. and under _____		
Over 20 sq. ft. _____		
Swimming Pools Above Ground _____		
In Ground _____		
Fire/Burglar Alarms Residential _____		
Commercial _____		
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____		
over 30 amps _____		
Circus, Fairs, etc. _____		
Alterations to wires _____		
Repairs after fire _____		
Emergency Lights, battery _____		
Emergency Generators _____		

INSTALLATION FEE DUE: _____
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE: _____
FOR REMOVAL OF A "STOP ORDER" (304-16.b)
TOTAL AMOUNT DUE: 5.00 min

INSPECTION:
Will be ready on May 9, 1989, 19; or Will Call _____
CONTRACTOR'S NAME: Anthony Mancini
ADDRESS: 179 Sheridan St
TEL.: _____
MASTER LICENSE NO.: 8436-24.6 SIGNATURE OF CONTRACTOR: Anthony Mancini
LIMITED LICENSE NO.: _____

Permit Number 60300Permit Number 60300

Location 100 m. S. of 57th E 1907

Owner Liberty Biscuit

Date of Permit 5/9/89

Final Inspection

By Inspection

Permit Application Register Page No. 63

INSPECTIONS: Service _____ by _____
Service called in _____
Closing-in 5/17/89 by [Signature]
PROGRESS INSPECTIONS: _____

PROGRESS INSPECTIONS:

DATE:

REMARKS:

[illegible][illegible]

RECEIVED
JAN 11 1964
U.S. AIR FORCE
HEADQUARTERS
WASHINGTON, D.C.



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date March 29, 1980
Receipt and Permit number 80182

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 100 Middle St. West Tower 5th floor

OWNER'S NAME: Liberty Group ADDRESS: 38 Preble St. Portland

OUTLETS: Receptacles 11 Switches 4 Plugmold _____ ft. TOTAL 15 FEES 3.00

FIXTURES: (number of) Incandescent _____ Fluorescent _____ (not strip) TOTAL _____
Strip Fluorescent _____ ft.

SERVICES: Overhead _____ Underground _____ Temporary _____ TOTAL amperes _____

METERS: (number of) _____
MOTORS: (number of) _____

Fractional _____
1 HP or over _____

RESIDENTIAL HEATING: Oil or Gas (number of units) _____
Electric (number of rooms) _____

COMMERCIAL OR INDUSTRIAL HEATING: Oil or Gas (by a main boiler) _____
Oil or Gas (by separate units) _____
Electric Under 20 kws X Over 20 kws _____ 1 Unit 10 Amp. - 1 Unit 9.4 Amp. 5.00

APPLIANCES: (number of) Ranges _____ Water Heaters _____
Cook Tops _____ Disposals _____
Wall Ovens _____ Dishwashers _____
Dryers _____ Compactors _____
Fans _____ Others (denote) _____

TOTAL _____

MISCELLANEOUS: (number of) _____

Branch Panels _____

Transformers _____

Air Conditioners Central Unit _____

Separate Units (windows) _____

Signs 20 sq. ft. and under _____

Over 20 sq. ft. _____

Swimming Pools Above Ground _____

In Ground _____

Fire/Alarm Alarms Residential _____

Commercial _____

Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____

over 30 amps _____

Circus, Fairs, etc. _____

Alterations to wires _____

Repairs after fire _____

Emergency Lights, battery _____

Emergency Generators _____

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT INSTALLATION FEE DUE: _____

FOR REMOVAL OF A "STOP ORDER" (304-16.b) DOUBLE FEE DUE: _____

TOTAL AMOUNT DUE: 8.00

INSPECTION: Will be ready on NOW, 1980; or Will Call _____

CONTRACTOR'S NAME: Robert E. Young, Jr. 3288

ADDRESS: 25 Evergreen Drive Portland, Me

TEL.: 797-0593

MASTER LICENSE NO.: 3288 SIGNATURE OF CONTRACTOR: _____

LIMITED LICENSE NO.: _____

ELECTRICAL INSTALLATIONS—

Permit Number 00102

Location

Owner

Date of Permi

Final Inspection

By Inspection

Permit Application Register Page No. 60

INSPECTIONS: Service _____ by _____

Service called in

Closing-in 6/2/89

PROGRESS INSPECTIONS:

DATE: _____

REMARKS:

CONFIDENTIAL

DOUBT: THE ONE

LEUC TIRKMA JAZ



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date November 19, 1987
Receipt and Permit number 22587

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 100 Middle Street

OWNER'S NAME: Gruntal & Co.

ADDRESS: 100 Middle Street

	FEES
OUTLETS:	
Receptacles <u>45</u> Switches <u>26</u> Plugmold _____ ft. TOTAL <u>51</u>	<u>5.00</u>
FIXTURES: (number of)	
Incandescent <u>13</u> Fluorescent <u>62</u> (not strip) TOTAL <u>78</u>	<u>9.80</u>
Strip Fluorescent _____ ft.	
SERVICES:	
Overhead _____ Underground <u>X</u> Temporary _____ TOTAL amperes <u>200</u> ..	<u>3.00</u>
METERS: (number of) <u>1</u>	<u>.50</u>
MOTORS: (number of)	
Fractional _____	
1 HP or over _____	
RESIDENTIAL HEATING:	
Oil or Gas (number of units) _____	
Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler) _____	
Oil or Gas (by separate units) _____	
Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of)	
Ranges _____	Water Heaters _____
Cook Tops _____	Disposals _____
Wall Ovens _____	Dishwashers _____
Dryers _____	Compactors _____
Fans _____	Others (denote) _____
TOTAL _____	
MISCELLANEOUS: (number of)	
Branch Panels <u>3</u>	<u>3.00</u>
Transformers <u>1</u>	<u>2.00</u>
Air Conditioners Central Unit _____	
Separate Units (windows) _____	
Signs 20 sq. ft. and under _____	
Over 20 sq. ft. _____	
Swimming Pools Above Ground _____	
In Ground _____	
Fire/Burglar Alarms Residential _____	
Commercial <u>1</u>	<u>5.00</u>
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
over 30 amps _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Emergency Lights, battery _____	
Emergency Generators _____	

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE:
FOR REMOVAL OF A "STOP ORDER" (304-16.b)

TOTAL AMOUNT DUE: 28.30

INSPECTION:

Will be ready on _____, 19____; or Will Call X

CONTRACTOR'S NAME: Favreau's Electric

ADDRESS: 37 Jordan Ave, Brunswick

TEL.: 725-2005

MASTER LICENSE NO.: 04232

LIMITED LICENSE NO.: _____

SIGNATURE OF CONTRACTOR:

[Signature]

INSPECTOR'S COPY — WHITE

ELECTRICAL INSTALLATIONS -

Permit Number 22-587

Location 100 Middle St

Owner James H. O Co.

Date of Permit 11/19/87

Final Inspection

By Inspector J. J. [Signature]

Permit Application Register Page No. 17

INSPECTIONS: Service 200 amp by Russ

Service called in 11/21/87

Closing-in 12/21/87 by [Signature]

PROGRESS INSPECTIONS: 1/29/88

DATE:

REMARKS:

2/2/88 Final for C & O ~~work~~ completed & ready



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date April 15 1987
Receipt and Permit number 09284

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 100 Middle St. - 2nd. & 3rd. Fl. Tower A

OWNER'S NAME: Morse, Payson & Noyes ADDRESS: same

	FEE
OUTLETS:	
Receptacles <u>500</u> Switches <u>87</u> Plugmold _____ ft. TOTAL <u>587</u>	<u>57.70</u>
FIXTURES: (number of)	
Incandescent <u>375</u> Fluorescent <u>524</u> (not strip) TOTAL <u>899</u>	<u>91.00</u>
Strip Fluorescent <u>46</u> ft.	<u>3.00</u>
SERVICES:	
Overhead <u>X</u> Underground _____ Temporary _____ TOTAL amperes <u>600</u> ..	<u>6.00</u>
METERS: (number of) <u>1</u>	<u>5.00</u>
MOTORS: (number of)	
Fractional _____	
1 HP or over _____	
RESIDENTIAL HEATING:	
Oil or Gas (number of units) _____	
Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler) _____	
Oil or Gas (by separate units) _____	
Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of)	
Ranges <u>1</u> Water Heaters <u>2</u>	
Cook Tops _____ Disposals _____	
Wall Ovens _____ Dishwashers _____	
Dryers _____ Compactors _____	
Fans _____ Others (denote) _____	
TOTAL <u>3</u>	<u>4.50</u>
MISCELLANEOUS: (number of)	
Branch Panels <u>9</u>	<u>9.00</u>
Transformers <u>2</u>	<u>4.00</u>
Air Conditioners Central Unit _____	
Separate Units (windows) _____	
Signs 20 sq. ft. and under _____	
Over 20 sq. ft. _____	
Swimming Pools Above Ground _____	
In Ground _____	
Fire/Burglar Alarms Residential _____	
Commercial <u>X</u>	<u>5.00</u>
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
over 30 amps _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Emergency Lights, battery _____	
Emergency Generators _____	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT	INSTALLATION FEE DUE: _____
FOR REMOVAL OF A "STOP ORDER" (304-16.b)	DOUBLE FEE DUE: _____
	TOTAL AMOUNT DUE: <u>180.70</u>

INSPECTION:

Will be ready on _____, 19____; or Will Call X

CONTRACTOR'S NAME: Favreau's Electric

ADDRESS: 37 Jordan Ave., Brunswick, Me. 04011

TEL.: 725-2005

MASTER LICENSE NO.: 04232

LIMITED LICENSE NO.: _____

SIGNATURE OF CONTRACTOR:

Larry Favreau R.E.

INSPECTOR'S COPY — WHITE

PROGRESS INSPECTIONS: 3/21/87, 4/20/87 _____

5/2/87, _____
6/22/87, _____
7/2/87, _____
9/30/87, _____
11/9/87, _____

Street "A"
 ELECTRICAL INSTALLATIONS —
 Permit Number 092254
 Location 100 Middle St
 Owner Murphy & Ryan
 Date of Permit 4/15/87
 Final Inspection 5/19/88
 By Inspector G. J. Ward
 Permit Application Register Page No. 145

[illegible]



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date May 18, 19 87
Receipt and Permit number D 09429

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 100 Middle Street "5th, 6th & 7th floor b Tower"

OWNER'S NAME: Vernstein & Shur ADDRESS: same

	FEE
OUTLETS:	
Receptacles <u>498</u> Switches <u>241</u> Plugmold _____ ft. TOTAL _____	72.90
FIXTURES: (number of)	
Incandescent <u>39</u> Fluorescent <u>557</u> (not strip) TOTAL <u>596</u>	62.60
Strip Fluorescent _____ ft.	
SERVICES:	
Overhead _____ Underground <u>X</u> Temporary _____ TOTAL amperes <u>400</u>	6.00
METERS: (number of) <u>1</u>	.50
MOTORS: (number of)	
Fractional _____	
1 HP or over _____	
RESIDENTIAL HEATING:	
Oil or Gas (number of units) _____	
Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler) _____	
Oil or Gas (by separate units) _____	
Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of)	
Ranges _____	
Cook Tops _____	
Wall Ovens _____	
Dryers _____	
Fans _____	
Water Heaters _____	
Disposals _____	
Dishwashers _____	
Compactors _____	
Others (denote) _____	
TOTAL _____	
MISCELLANEOUS: (number of)	
Branch Panels <u>7</u>	7.00
Transformers <u>4</u>	8.00
Air Conditioners Central Unit _____	
Separate Units (windows) _____	
Signs 20 sq. ft. and under _____	
Over 20 sq. ft. _____	
Swimming Pools Above Ground _____	
In Ground _____	
Fire/Burglar Alarms Residential _____	
Commercial <u>X</u>	5.00
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
over 30 amps _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Emergency Lights, battery _____	
Emergency Generators _____	
INSTALLATION FEE DUE: _____	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE: _____	
FOR REMOVAL OF A "STOP ORDER" (304-16.b) _____	
TOTAL AMOUNT DUE: _____	162.00

INSPECTION:

Will be ready on _____, 19 ____; or Will Call X

CONTRACTOR'S NAME: Favreau's Electric

ADDRESS: 37 Jordan Avenue - Brunswick, ME 04011

TEL.: 725-2005

MASTER LICENSE NO.: 04232

LIMITED LICENSE NO.: _____

SIGNATURE OF CONTRACTOR:

Larry Favreau

INSPECTOR'S COPY - WHITE

INSPECTIONS: Service 400 Amp by Russ
 Service called in 10/30/87
 Closing-in See Remarks by Russ

PROGRESS INSPECTIONS: 6/4/87 11/9/87
7/16/87 11/15/87
8/7/87 11/15/87
8/19/87 11/15/87
9/2/87 11/15/87
9/23/87 11/15/87

Alper 'B'
 ELECTRICAL INSTALLATIONS —
 Permit Number 09429
 Location 100 Middle St
 Owner Almon & Sons
 Date of Permit 5/18/87
 Final Inspection 11/15/87
 By Inspector D. H. Jones
 Permit Application Register Page No. 150

DATE:	REMARKS:
6/4/87	Center line all 7 floors-walls may be closed
7/16/87	7th floor. North & East walls may be closed. Inside perimeter walls may be closed.
7/23/87	Outside walls south & west may be closed.
7/29/87	7th fl. -
8/5/87	Remainder of 7th fl. - walls may be closed.
8/19/87	East walls may be closed. 6th fl. meter may be placed 6th fl.
8/19/87	Entire 6th floor, walls may be closed.
9/2/87	walls may be closed. 5th fl East side
9/23/87	Final Inspection 7th fl Tower B - plates needed
11/9/87	Final inspection for C90 - 5th, 6th & 7th floors. Panels will be marked by 11/13/87.



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date May 18, 19 87
Receipt and Permit number D 09432

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 100 Middle Street 2nd & 3rd floor B Tower

OWNER'S NAME: Peat, Markwick, Mitchell & ADDRESS: same

OUTLETS:	FEE
Receptacles <u>140</u> Switches <u>103</u> Plugmold _____ ft. TOTAL <u>243</u>	23.30
FIXTURES: (number of)	
Incandescent <u>37</u> Fluorescent <u>350</u> (not strip) TOTAL <u>387</u>	40.70
Strip Fluorescent _____ ft.	
SERVICES:	
Overhead _____ Underground <u>X</u> Temporary _____ TOTAL amperes <u>400</u>	6.00
METERS: (number of) <u>1</u>	.50
MOTORS: (number of)	
Fractional _____	
1 HP or over _____	
RESIDENTIAL HEATING:	
Oil or Gas (number of units) _____	
Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler) _____	
Oil or Gas (by separate units) _____	
Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of)	
Ranges _____	
Cook Tops _____	
Wall Ovens _____	
Dryers _____	
Fans _____	
Water Heaters _____	
Disposals _____	
Dishwashers _____	
Compactors _____	
Others (denote) _____	
TOTAL _____	
MISCELLANEOUS: (number of)	
Branch Panels <u>5</u>	5.00
Transformers <u>1</u>	2.00
Air Conditioners Central Unit _____	
Separate Units (windows) _____	
Signs 20 sq. ft. and under _____	
Over 20 sq. ft. _____	
Swimming Pools Above Ground _____	
In Ground _____	
Fire/Burglar Alarms Residential _____	
Commercial <u>1</u>	5.00
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
over 30 amps _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Emergency Lights, battery _____	
Emergency Generators _____	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT	INSTALLATION FEE DUE:
FOR REMOVAL OF A "STOP ORDER" (304-16.b)	DOUBLE FEE DUE:
	TOTAL AMOUNT DUE: 82.50

INSPECTION:

Will be ready on _____, 19 ____; or Will Call X

CONTRACTOR'S NAME: Favreau's Elec.

ADDRESS: 37 Jordan Avenue, Brunswick, ME 04011

TEL: 725-2005

MASTER LICENSE NO.: 04232

LIMITED LICENSE NO.: _____

SIGNATURE OF CONTRACTOR:

Larry Favreau

INSPECTOR'S COPY — WHITE

Tower "B"
ELECTRICAL INSTALLATIONS —

INSPECTIONS: Service 300 amp by Russo
Service called in 8/10/87
Closing-in 8/18/87 by Russo

PROGRESS INSPECTIONS: 8/28/87 1
9/2/87 1
9/16/87 1
10/9/87 1
11/13/87 1
1 1

Permit Number 09432
Location 100 Middle St
Owner East Mercantile
Date of Permit 5/18/87
Final Inspection 11/17/87
By Inspector J. Russo
Permit Application Register Page No. 150

DATE:	REMARKS:
8/18/87	3rd fl East outside wall and adjoining office walls may be closed.
8/26/87	3rd fl West outside walls and office walls may be closed.
9/2/87	3rd fl entire fl walls may be closed.
9/16/87	Outside and occupied offices West wall may be closed in - 2nd fl.
10/9/87	meter may be placed 2nd fl Tower B.
11/13/87	Final inspection for C&O Completed this date.



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date May 18, 19 87
Receipt and Permit number D 09430

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 100 Middle Street "5th Floor Tower A"

OWNER'S NAME: Berry Dunn ADDRESS: same

FEEES

OUTLETS:	Receptacles _____	Switches _____	Plugmold _____	ft. TOTAL _____	_____
FIXTURES:	Incandescent _____	Flourescent _____	(not strip) TOTAL _____	_____	_____
	Strip _____	ft. _____	_____	_____	_____
SERVICES:	Overhead _____	Underground _____	Temporary _____	TOTAL amperes _____	_____
METERS: (number of) _____	_____	_____	_____	_____	_____
MOTORS: (number of)	Fractional _____	_____	_____	_____	_____
	1 HP or over _____	_____	_____	_____	_____
RESIDENTIAL HEATING:	Oil or Gas (number of units) _____	_____	_____	_____	_____
	Electric (number of rooms) _____	_____	_____	_____	_____
COMMERCIAL OR INDUSTRIAL HEATING:	Oil or Gas (by a main boiler) _____	_____	_____	_____	_____
	Oil or Gas (by separate units) _____	_____	_____	_____	_____
	Electric Under 20 kws _____	Over 20 kws _____	_____	_____	_____
APPLIANCES: (number of)	Ranges _____	Water Heaters _____	_____	_____	_____
	Cook Tops _____	Disposals _____	_____	_____	_____
	Wall Ovens _____	Dishwashers _____	_____	_____	_____
	Dryers _____	Compactors _____	_____	_____	_____
	Fans _____	Others (denote) _____	_____	_____	_____
	TOTAL _____	_____	_____	_____	_____
MISCELLANEOUS: (number of)	Branch Panels _____	_____	_____	_____	_____
	Transformers _____	_____	_____	_____	_____
	Air Conditioners Central Unit _____	_____	_____	_____	_____
	Separate Units (windows) _____	_____	_____	_____	_____
	Signs 20 sq. ft. and under _____	_____	_____	_____	_____
	Over 20 sq. ft. _____	_____	_____	_____	_____
	Swimming Pools Above Ground _____	_____	_____	_____	_____
	In Ground _____	_____	_____	_____	_____
	Fire/Burglar Alarms Residential _____	_____	_____	_____	_____
	Commercial ☒ _____	_____	_____	_____	5.00
	Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	_____	_____	_____	_____
	over 30 amps _____	_____	_____	_____	_____
	Circus, Fairs, etc. _____	_____	_____	_____	_____
	Alterations to wires _____	_____	_____	_____	_____
	Repairs after fire _____	_____	_____	_____	_____
	Emergency Lights, battery _____	_____	_____	_____	_____
	Emergency Generators _____	_____	_____	_____	_____
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT	INSTALLATION FEE DUE: _____	DOUBLE FEE DUE: _____	_____	_____	_____
FOR REMOVAL OF A "STOP ORDER" (304-16.b)	_____	_____	_____	_____	_____
	TOTAL AMOUNT DUE: _____	_____	_____	_____	5.00

INSPECTION:

Will be ready on _____, 19____; or Will Call ☒

CONTRACTOR'S NAME: Favreau's Elec

ADDRESS: 37 Jordan Avenue Brunswick, ME 04011

TEL: 725-2005

MASTER LICENSE NO.: 04232

LIMITED LICENSE NO.: _____

SIGNATURE OF CONTRACTOR:

Favreau

INSPECTOR'S COPY — WHITE

ELECTRICAL INSTALLATIONS -

Permit Number 09230

Location 148 Maple St

Owner Benny Green

Date of Permit 4/5/61

Final Inspection

By Inspector D. P. Reed

Permit Application Register Page No. 156

INSPECTIONS: Service _____ by _____

Service called in _____

Closing-in _____ by _____

PROGRESS INSPECTIONS: _____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____

DATE:

REMARKS:

11/9/81

Final for Cgo - Completed this date