



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 100 Middle St 029-E-006

Issued to Middle Street Office Tower Associates

Date of Issue 02 January 1998

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 961113, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

6th & 7th floors

Office Space

Limiting Conditions: TEMPORARY:

U.S. Attorney's Office

1. Signage of electric room door. Within 10 days.
2. Install GFCI outlets in men's room kitchen counter.

This certificate supersedes certificate issued

Approved:

(Date)

1/2/98

Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.