

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

25 PEARL MHR LLC

Located at

25 PEARL ST

PERMIT ID: 2015-01819

ISSUE DATE: 09/08/2015

CBL: 029 E009001

has permission to **Alterations - To add three (3) antennae, painted to match background, add three (3) remote radio heads with A2 Modules to existing unistruts on the concrete wall, and swap out 9E/10E boxes with surge arrestors.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Jeanie Bourke

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

1st floor restaurant, offices (Registry of Deeds), parking garage above

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

| | | | | |
|---|--------------------------------------|--|--|---|
| City of Portland, Maine - Building or Use Permit | | Permit No: 2015-01819 | Date Applied For: 07/28/2015 | CBL: 029 E009001 |
| 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 | | | | |
| Proposed Use: Same: AT&T Wireless Communication Facility (Custom House Garage) | | Proposed Project Description: Alterations - To add three (3) antennae, painted to match background, add three (3) remote radio heads with A2 Modules to existing unistruts on the concrete wall, and swap out 9E/10E boxes with surge arrestors. | | |
| Dept: Zoning | Status: Approved | Reviewer: Jeanie Bourke | Approval Date: 09/08/2015 | |
| Note: B-3 Zone | | | | Ok to Issue: <input checked="" type="checkbox"/> |
| Conditions: | | | | |
| Dept: Building Inspecti | Status: Approved w/Conditions | Reviewer: Jeanie Bourke | Approval Date: 09/08/2015 | |
| Note: | | | | Ok to Issue: <input checked="" type="checkbox"/> |
| Conditions: | | | | |
| 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. | | | | |
| 2) The installation shall comply with the wind load requirements of the IBC 2009, Sec. 16091.1 pre TIA-222. | | | | |
| 3) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. | | | | |
| Dept: Engineering DPS | Status: Not Applicable | Reviewer: Benjamin Pearson | Approval Date: 08/10/2015 | |
| Note: | | | | Ok to Issue: <input checked="" type="checkbox"/> |
| Conditions: | | | | |
| 1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov | | | | |