

# CUNNINGHAM

## Security Systems

10 Princes Point Road • Yarmouth, Maine 04096  
(207) 846-3350 • Fax (207) 846-6080 • (800) 210-0257

July 28, 2015


Attn: Craig Messinger  
Fire Prevention Bureau  
Portland Fire Department  
380 Congress Street  
Portland, ME 04101  
(207) 756-8096  
Fax#: (207) 874-8410

Dear Craig,

This letter is to inform you that on July 14, 2015, we completed the installation, programming and testing of the new fire alarm devices added in the Northeast bank space in the building located at 27 Pearl Street in Portland, Maine. These new fire alarm devices were tied into the existing building fire alarm control panel and were installed, programmed and tested to NFPA 72 standards with signals sent to and received at our central monitoring station. All these devices were found to be fully functional at that time.

Should you have any questions or comments regarding this matter, please feel free to contact me at (207) 846-3350.

Sincerely,



Ronald S. Sneider, Manager

cc: Acct. File