DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

130 LIMITED LIABILITY COMPAMY

Located at

31 PEARL ST

PERMIT ID: 2015-01121

ISSUE DATE: 06/05/2015

CBL: 029 E016001

has permission to For the installation of a Water-Based Fire Suppression System (Renovation to existing NSPA 13 system to meet codes).

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 05/20/2015 2015-01121 029 E016001 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: **Proposed Project Description:** Same: Office & Business Service For the installation of a Water-Based Fire Suppression System (Renovation to existing NSPA 13 system to meet codes). **Dept:** Zoning **Status:** Approved w/Conditions Reviewer: Tammy Munson **Approval Date:** 05/21/2015 Ok to Issue: Note: **Conditions:** 1) This approves the installation only. It does not certify the legal use of the building. 06/04/2015 **Dept:** Fire **Status:** Approved w/Conditions Reviewer: Craig Messinger **Approval Date:** Note: Ok to Issue: **Conditions:**

- 1) Installation shall be in accordance with the City of Portland Fire Department Regulations and NFPA 13 as published. A copy of the State Sprinkler permit with RMS date and signature and the Contractor's Material and Test Certificate for Aboveground Piping (NFPA 13 figure 24.1) shall be provided prior to scheduling of the final inspection.
- 2) The entire sprinkler system shall be maintained in accordance with NFPA 25, Standard for Inspection, Testing and Maintenance of Water-Based Fire Protection Systems, 2008 edition. This applies to the entire building and a letter must be submitted to the Fire Prevention Office, before a final inspection is scheduled. The intent of this requirement is to verify code compliance for the entire building.