

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT

This is to certify that

130 LIMITED LIABILITY COMPAMY

Located at

31 PEARL ST

PERMIT ID: 2015-00776

ISSUE DATE: 04/29/2015

CBL: 029 E016001

has permission to **Installation of 3 attached building wall signs for Northeast Bank: Sign A - 4'6"x13'4" (60 SF), Sign B - 10'5"x3'6"(37 SF) and Sign D - 3'0"x2'0" (6 SF).**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.	A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.
---	--

N/A

/s/ Laurie Leader

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-00776	Date Applied For: 04/16/2015	CBL: 029 E016001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Office & Business Service		Proposed Project Description: Installation of 3 attached building wall signs for Northeast Bank: Sign A - 4'6"x13'4" (60 SF), Sign B - 10'5"x3'6"(37 SF) and Sign D - 3'0"x2'0" (6 SF).		
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Laurie Leader	Approval Date: 04/29/2015	
Note: B3 ground floor tenant 2x88=176SF Allow. A+D=66 SF OK *Proposed sign B does not meet requirements of Section 14-369.5 Table 2.8 - Only one wall sign permitted		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions: 1) This permit is approving signs A and D on the Pearl Street façade. Sign B facing the parking lot is not approved at this time.				
Dept: Building Inspecti	Status: Approved w/Conditions	Reviewer: Laurie Leader	Approval Date: 04/29/2015	
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions: 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Planning	Status: Approved	Reviewer: Shukria Wiar	Approval Date: 06/18/2015	
Note: Special Sign Exemption for extra sign.		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions: 1) The special sign exemption is for the "sign B" as submitted in coverletter from Northeast Bank dated 05.21.2015.				