

# Fire Alarm and Life Safety System Inspection Certificate

*For*

100 Middle Street  
100 Middle Street  
Portland, ME 04101

Tested to NFPA 72 Standards

*This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.*

*Inspection Date*  
*Apr 11, 2017*

Building: 100 Middle Street  
Contact: Bill McHugh  
Title: Facilities Manager

Company: R.B. Allen Company, Inc.  
Contact: Jeremy Bell  
Title: Inspector

# Executive Summary

Generated by: BuildingReports.com

Building Information		
Building: 100 Middle Street	Contact: Bill McHugh	
Address: 100 Middle Street	Phone: 207-780-1680 XT3	
Address:	Fax:	
City/State/Zip: Portland, ME 04101	Mobile:	
Country: United States of America	Email: bmchugh@maine.rr.com	
Inspection Performed By		
Company: R.B. Allen Company, Inc.	Inspector: Jeremy Bell	
Address: 131 Lafayette Road	Phone: 603-964-8140	
Address:	Fax: 603-964-8885	
City/State/Zip: North Hampton, NH 03862	Mobile: 603-394-5938	
Country: United States of America	Email: jeremybell@rballen.com	
System Control Unit		
Manufacturer: GE Security	Inspection Date: 04/11/2017	IDC Style:
Model Number: EST-3	Install Date: 05/08/2009	SLC Style:
Software Version: 3.52	Version Date: 05/08/2009	NAC Style:
Location: 1ST FL SECURITY DESK	Current Protection:	
Monitoring		
Company:	Phone:	Account #:
Central Station Signal Verification		
Type:	Mfg:	Model #:
Test Time/Date:	Restore Time	

<b>Inspection Summary</b>								
<b>Category</b>	<b>Total Items</b>		<b>Serviced</b>		<b>Passed</b>		<b>Failed/Other</b>	
	<b>Qty</b>	<b>%</b>	<b>Qty</b>	<b>%</b>	<b>Qty</b>	<b>%</b>	<b>Qty</b>	<b>%</b>
Auxiliary	3	0.87%	3	100.00%	3	100.00%	0	0%
Indicating	166	47.98%	166	100.00%	166	100.00%	0	0%
Initiating	165	47.69%	164	99.39%	164	100.00%	0	0%
Control	12	3.47%	12	100.00%	12	100.00%	0	0%
<b>Totals</b>	<b>346</b>	<b>100%</b>	<b>345</b>	<b>99.71%</b>	<b>345</b>	<b>100.00%</b>	<b>0</b>	<b>0%</b>

**Certification**

Company: R.B. Allen Company, Inc.

Building: 100 Middle Street

Inspector: Jeremy Bell

Contact: Bill McHugh

Signed:

Signed:

**Jeremy Bell**

<b>Certification Type</b>	<b>Number</b>
IMSA Fire Alarm Interior Level I	

# Notes & Recommendations

Generated by: BuildingReports.com

ScanID	Note	Device Type	Location	Comment
Building: 100 Middle Street		Control Panel: 1 - GE Security EST-3		
<p><i>The Notes &amp; Recommendations Report details additional inspection notes made by the Inspectors during the course of the building inspection. Notes are grouped by Category.</i></p>				
<b><i>Control</i></b>				
31145938	1	Battery	1ST FL SECURITY DESK INSIDE FLEXALERT	Passed
	Load Test 90%			
31145937	2	Battery	1ST FL SECURITY DESK INSIDE FLEXALERT	Passed
	Load Test 90%			
31145904	3	Battery	2ND FL WEST ELECTRIC ROOM IN BOOSTER	Passed
	Load Test 80%			
31145905	4	Battery	2ND FL WEST ELECTRIC ROOM IN BOOSTER	Passed
	Load Test 80%			
31145911	5	Battery	3RD FL WEST TOWER B INSIDE BOOSTER	Passed
	Load Test 90%			
31145910	6	Battery	3RD FL WEST TOWER B INSIDE BOOSTER	Passed
	Load Test 90%			
<b><i>Initiating</i></b>				
18981900	7	Smoke Detector	4TH FL EAST TOWER A GRETA DIAMOND CONFERENCE	Passed
	105006. Incorrect Description			

# Inspection & Testing

Generated by: BuildingReports.com

<b>Building: 100 Middle Street</b>	<b>Control Panel: 1 - GE Security EST-3</b>
------------------------------------	---

*The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.*

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
<b>Auxiliary</b>				
Releasing Device	3RD FL WEST TOWER BOTTOM OF STAIRS	Tested	6:51:13 AM	04/11/2017
Releasing Device	7TH FL WEST TOWER B ELEV LOBBY	Tested	6:48:15 AM	04/11/2017
Releasing Device	7TH FL WEST TOWER B ELEV LOBBY	Tested	6:48:18 AM	04/11/2017
<b>Control</b>				
Battery	1ST FL SECURITY DESK INSIDE FLEXALERT	Checked	8:19:37 AM	04/11/2017
Battery	1ST FL SECURITY DESK INSIDE FLEXALERT	Checked	8:19:40 AM	04/11/2017
Battery	2ND FL WEST ELECTRIC ROOM IN BOOSTER	Checked	8:15:53 AM	04/11/2017
Battery	2ND FL WEST ELECTRIC ROOM IN BOOSTER	Checked	8:15:57 AM	04/11/2017
Battery	3RD FL EAST ELECTRIC ROOM INSIDE BOOSTER	Checked	8:14:32 AM	04/11/2017
Battery	3RD FL EAST ELECTRIC ROOM INSIDE BOOSTER	Checked	8:15:48 AM	04/11/2017
Battery	3RD FL WEST TOWER B INSIDE BOOSTER	Checked	8:15:32 AM	04/11/2017
Battery	3RD FL WEST TOWER B INSIDE BOOSTER	Checked	8:15:25 AM	04/11/2017
Control Panel	1ST FL SECURITY DESK	Tested	6:50:07 AM	04/11/2017
Expander Panel	2ND FL WEST ELECTRIC ROOM	Tested	7:40:58 AM	04/11/2017
Expander Panel	3RD FL STROBES EAST TOWER A	Tested	7:41:09 AM	04/11/2017
Expander Panel	3RD FL STROBES WEST TOWER B	Tested	7:41:02 AM	04/11/2017
<b>Indicating</b>				
Speaker/Strobe	PENTHOUSE EAST TOWER	Tested	6:43:08 AM	04/11/2017
Speaker/Strobe	PENTHOUSE WEST TOWER OPEN AREA	Tested	6:53:20 AM	04/11/2017
Speaker/Strobe	1ST FL MAIN LOBBY FRONT EXIT	Tested	6:43:39 AM	04/11/2017
Speaker/Strobe	1ST FL EAST TOWER GARAGE	Tested	6:42:20 AM	04/11/2017
Speaker/Strobe	1ST FL EAST TOWER GARAGE	Tested	6:42:25 AM	04/11/2017
Speaker/Strobe	1ST FL EAST TOWER MORGAN STANLEY OFFICE	Tested	6:47:37 AM	04/11/2017
Speaker/Strobe	1ST FL EAST TOWER MORGAN STANLEY OPEN OFFICE	Tested	6:47:31 AM	04/11/2017
Speaker/Strobe	1ST FL EAST TOWER MORGAN STANLEY OPEN OFFICE	Tested	6:47:34 AM	04/11/2017
Speaker/Strobe	1ST FL EAST TOWER GARAGE	Tested	6:43:31 AM	04/11/2017
Speaker/Strobe	1ST FL WEST TOWER CITIZENS BANK	Tested	6:42:17 AM	04/11/2017
Speaker/Strobe	1ST FL WEST TOWER GARAGE	Tested	6:41:58 AM	04/11/2017
Speaker/Strobe	1ST FL WEST TOWER GARAGE	Tested	6:42:28 AM	04/11/2017
Speaker/Strobe	1ST FL WEST TOWER GARAGE	Tested	6:42:31 AM	04/11/2017
Speaker/Strobe	1ST FL WEST TOWER HALL BY STAIR 3	Tested	6:42:15 AM	04/11/2017
Speaker/Strobe	2ND FL EAST TOWER INSIDE STAIR 1	Tested	6:47:18 AM	04/11/2017
Speaker/Strobe	2ND FL EAST TOWER NORTHCROSS CONF RM	Tested	6:47:22 AM	04/11/2017
Speaker/Strobe	2ND FL EAST TOWER NORTHCROSS OPEN	Tested	6:47:25 AM	04/11/2017

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Speaker/Strobe	OFFICE 2ND FL EAST TOWER NORTHCROSS OPEN	Tested	6:47:28 AM	04/11/2017
Speaker/Strobe	OFFICE 2ND FL EAST TOWER OUTSIDE STAIR 1	Tested	6:47:07 AM	04/11/2017
Speaker/Strobe	2ND FL EAST TOWER RHI FRONT OFFICE	Tested	6:47:15 AM	04/11/2017
Speaker/Strobe	2ND FL EAST TOWER CORRIDOR	Tested	6:46:58 AM	04/11/2017
Speaker/Strobe	2ND FL EAST TOWER DEPT OF LABOR OFFICE	Tested	6:46:33 AM	04/11/2017
Speaker/Strobe	2ND FL EAST TOWER INSIDE EDA OFFICE	Tested	6:46:54 AM	04/11/2017
Speaker/Strobe	2ND FL EAST TOWER INSIDE NOAA OFFICE	Tested	6:46:51 AM	04/11/2017
Speaker/Strobe	2ND FL EAST TOWER INSIDE STAIR 2	Tested	6:46:47 AM	04/11/2017
Speaker/Strobe	2ND FL EAST TOWER MEDIATION & CONCILIATION OFFICE	Tested	6:46:30 AM	04/11/2017
Speaker/Strobe	2ND FL EAST TOWER MENS RM	Tested	6:47:01 AM	04/11/2017
Speaker/Strobe	2ND FL EAST TOWER OUTSIDE STAIR 2	Tested	6:46:36 AM	04/11/2017
Speaker/Strobe	2ND FL EAST TOWER RHI REAR OFFICE	Tested	6:47:10 AM	04/11/2017
Speaker/Strobe	2ND FL EAST TOWER SCORE CONF RM	Tested	6:46:27 AM	04/11/2017
Speaker/Strobe	2ND FL EAST TOWER SCORE OFFICE	Tested	6:46:23 AM	04/11/2017
Speaker/Strobe	2ND FL EAST TOWER WOMENS RM	Tested	6:47:04 AM	04/11/2017
Speaker/Strobe	2ND FL WEST TOWER BOA OPEN OFFICE	Tested	6:49:40 AM	04/11/2017
Speaker/Strobe	2ND FL WEST TOWER BOA OPEN OFFICE	Tested	6:49:43 AM	04/11/2017
Speaker/Strobe	2ND FL WEST TOWER BOA OPEN OFFICE	Tested	6:49:48 AM	04/11/2017
Speaker/Strobe	2ND FL WEST TOWER BOA OPEN OFFICE	Tested	6:49:51 AM	04/11/2017
Speaker/Strobe	2ND FL WEST TOWER BOA OPEN OFFICE	Tested	6:50:00 AM	04/11/2017
Speaker/Strobe	2ND FL WEST TOWER Corridor by Restroom	Tested	6:42:01 AM	04/11/2017
Speaker/Strobe	2ND FL WEST TOWER INSIDE STAIR 3	Tested	6:43:28 AM	04/11/2017
Speaker/Strobe	2ND FL WEST TOWER INSIDE STAIR 4	Tested	6:49:02 AM	04/11/2017
Speaker/Strobe	2ND FL WEST TOWER MENS ROOM	Tested	6:49:08 AM	04/11/2017
Speaker/Strobe	2ND FL WEST TOWER OUTSIDE STAIR 3	Tested	6:49:16 AM	04/11/2017
Speaker/Strobe	2ND FL WEST TOWER SECRET SERVICE CORRIDOR	Tested	6:49:12 AM	04/11/2017
Speaker/Strobe	2ND FL WEST TOWER WOMENS ROOM	Tested	6:49:05 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER CONF ROOM	Tested	6:46:11 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER CORRIDOR	Tested	6:45:47 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER ELEVATOR LOBBY	Tested	6:45:04 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER INSIDE STAIR 1	Tested	6:45:11 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER INSIDE STAIR 2	Tested	6:45:28 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER MENS ROOM	Tested	6:45:22 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER OPEN OFFICE	Tested	6:45:50 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER OPEN OFFICE	Tested	6:45:54 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER OPEN OFFICE	Tested	6:45:57 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER OPEN OFFICE	Tested	6:46:00 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER OPEN OFFICE	Tested	6:46:05 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER OPEN OFFICE	Tested	6:46:08 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER OPEN OFFICE	Tested	6:46:14 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER OPEN OFFICE	Tested	6:46:16 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER OPEN OFFICE	Tested	6:46:20 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER OUTSIDE ELEC RM	Tested	6:45:31 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER OUTSIDE RESTROOMS	Tested	6:45:14 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER OUTSIDE STAIR 1	Tested	6:45:08 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER OUTSIDE STAIR 1	Tested	6:45:25 AM	04/11/2017

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Speaker/Strobe	3RD FL EAST TOWER RECEPTION	Tested	6:45:44 AM	04/11/2017
Speaker/Strobe	3RD FL EAST TOWER WOMENS ROOM	Tested	6:45:18 AM	04/11/2017
Speaker/Strobe	3RD FL WEST TOWER BOA OPEN OFFICE	Tested	6:49:53 AM	04/11/2017
Speaker/Strobe	3RD FL WEST TOWER BOA OPEN OFFICE	Tested	6:49:57 AM	04/11/2017
Speaker/Strobe	3RD FL WEST TOWER BOA OPEN OFFICE	Tested	6:50:38 AM	04/11/2017
Speaker/Strobe	3RD FL WEST TOWER BOA OPEN OFFICE	Tested	6:50:42 AM	04/11/2017
Speaker/Strobe	3RD FL WEST TOWER INSIDE STAIR 3	Tested	6:50:44 AM	04/11/2017
Speaker/Strobe	3RD FL WEST TOWER INSIDE STAIR 4	Tested	6:51:02 AM	04/11/2017
Speaker/Strobe	3RD FL WEST TOWER MENS RM	Tested	6:50:55 AM	04/11/2017
Speaker/Strobe	3RD FL WEST TOWER OPEN OFFICE	Tested	6:51:08 AM	04/11/2017
Speaker/Strobe	3RD FL WEST TOWER OPEN OFFICE	Tested	6:51:10 AM	04/11/2017
Speaker/Strobe	3RD FL WEST TOWER OUTSIDE STAIR 3	Tested	6:50:48 AM	04/11/2017
Speaker/Strobe	3RD FL WEST TOWER OUTSIDE STAIR 4	Tested	6:51:04 AM	04/11/2017
Speaker/Strobe	3RD FL WEST TOWER SA HUTNAK & ASSOCIATES	Tested	6:50:58 AM	04/11/2017
Speaker/Strobe	3RD FL WEST TOWER WOMENS RM	Tested	6:50:52 AM	04/11/2017
Speaker/Strobe	4TH FL EAST TOWER CONF RM	Tested	6:44:31 AM	04/11/2017
Speaker/Strobe	4TH FL EAST TOWER INSIDE STAIR 1	Tested	6:44:26 AM	04/11/2017
Speaker/Strobe	4TH FL EAST TOWER INSIDE STAIR 2	Tested	6:44:44 AM	04/11/2017
Speaker/Strobe	4TH FL EAST TOWER MENS RM	Tested	6:44:57 AM	04/11/2017
Speaker/Strobe	4TH FL EAST TOWER OPEN AREA	Tested	6:44:35 AM	04/11/2017
Speaker/Strobe	4TH FL EAST TOWER OPEN AREA	Tested	6:44:38 AM	04/11/2017
Speaker/Strobe	4TH FL EAST TOWER OPEN AREA	Tested	6:44:54 AM	04/11/2017
Speaker/Strobe	4TH FL EAST TOWER OPEN OFFICE	Tested	6:44:29 AM	04/11/2017
Speaker/Strobe	4TH FL EAST TOWER OPEN OFFICE	Tested	6:44:47 AM	04/11/2017
Speaker/Strobe	4TH FL EAST TOWER OPEN OFFICE	Tested	6:44:50 AM	04/11/2017
Speaker/Strobe	4TH FL EAST TOWER OUTSIDE STAIR 1	Tested	6:44:22 AM	04/11/2017
Speaker/Strobe	4TH FL EAST TOWER OUTSIDE STAIR 2	Tested	6:44:41 AM	04/11/2017
Speaker/Strobe	4TH FL EAST TOWER WOMENS RM	Tested	6:45:01 AM	04/11/2017
Speaker/Strobe	4TH FL WEST TOWER FBI	Tested	6:42:04 AM	04/11/2017
Speaker/Strobe	4TH FL WEST TOWER FBI	Tested	6:42:08 AM	04/11/2017
Speaker/Strobe	4TH FL WEST TOWER FBI	Tested	6:42:11 AM	04/11/2017
Speaker/Strobe	4TH FL WEST TOWER INSIDE STAIR 3	Tested	6:52:20 AM	04/11/2017
Speaker/Strobe	4TH FL WEST TOWER INSIDE STAIR 4	Tested	6:51:51 AM	04/11/2017
Speaker/Strobe	4TH FL WEST TOWER MENS RM	Tested	6:51:21 AM	04/11/2017
Speaker/Strobe	4TH FL WEST TOWER OPEN OFFICE	Tested	6:51:54 AM	04/11/2017
Speaker/Strobe	4TH FL WEST TOWER OPEN OFFICE	Tested	6:52:24 AM	04/11/2017
Speaker/Strobe	4TH FL WEST TOWER OPEN OFFICE	Tested	6:52:27 AM	04/11/2017
Speaker/Strobe	4TH FL WEST TOWER OPEN OFFICE	Tested	6:52:29 AM	04/11/2017
Speaker/Strobe	4TH FL WEST TOWER OUTSIDE STAIR 3	Tested	6:52:17 AM	04/11/2017
Speaker/Strobe	4TH FL WEST TOWER OUTSIDE STAIR 4	Tested	6:51:24 AM	04/11/2017
Speaker/Strobe	4TH FL WEST TOWER WOMENS RM	Tested	6:51:17 AM	04/11/2017
Speaker/Strobe	5TH FL EAST TOWER INSIDE STAIR 1	Tested	6:44:19 AM	04/11/2017
Speaker/Strobe	5TH FL EAST TOWER INSIDE STAIR 2	Tested	6:44:10 AM	04/11/2017
Speaker/Strobe	5TH FL EAST TOWER MENS RM	Tested	6:44:00 AM	04/11/2017
Speaker/Strobe	5TH FL EAST TOWER OPEN OFFICE	Tested	6:44:13 AM	04/11/2017
Speaker/Strobe	5TH FL EAST TOWER OUTSIDE STAIR 1	Tested	6:44:16 AM	04/11/2017
Speaker/Strobe	5TH FL EAST TOWER OUTSIDE STAIR 2	Tested	6:44:06 AM	04/11/2017
Speaker/Strobe	5TH FL EAST TOWER WOMENS RM	Tested	6:44:03 AM	04/11/2017
Speaker/Strobe	5TH FL WEST TOWER INSIDE STAIR 3	Tested	6:52:51 AM	04/11/2017
Speaker/Strobe	5TH FL WEST TOWER INSIDE STAIR 4	Tested	6:52:42 AM	04/11/2017

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Speaker/Strobe	5TH FL WEST TOWER MENS RM	Tested	6:52:36 AM	04/11/2017
Speaker/Strobe	5TH FL WEST TOWER OPEN OFFICE	Tested	6:52:39 AM	04/11/2017
Speaker/Strobe	5TH FL WEST TOWER OPEN OFFICE	Tested	6:52:49 AM	04/11/2017
Speaker/Strobe	5TH FL WEST TOWER OPEN OFFICE	Tested	6:53:00 AM	04/11/2017
Speaker/Strobe	5TH FL WEST TOWER OUTSIDE STAIR 4	Tested	6:52:45 AM	04/11/2017
Speaker/Strobe	5TH FL WEST TOWER WOMENS RM	Tested	6:52:32 AM	04/11/2017
Speaker/Strobe	6TH FL EAST TOWER ATTORNEY GENERAL OFFICE	Tested	6:43:17 AM	04/11/2017
Speaker/Strobe	6TH FL EAST TOWER ATTORNEY GENERAL OFFICE	Tested	6:43:20 AM	04/11/2017
Speaker/Strobe	6TH FL EAST TOWER ATTORNEY GENERAL OFFICE	Tested	6:43:22 AM	04/11/2017
Speaker/Strobe	6TH FL EAST TOWER ATTORNEY GENERAL OFFICE	Tested	6:43:25 AM	04/11/2017
Speaker/Strobe	6TH FL EAST TOWER INSIDE STAIR 1	Tested	6:43:57 AM	04/11/2017
Speaker/Strobe	6TH FL EAST TOWER MENS RM	Tested	6:43:48 AM	04/11/2017
Speaker/Strobe	6TH FL EAST TOWER OUTSIDE STAIR 1	Tested	6:43:54 AM	04/11/2017
Speaker/Strobe	6TH FL EAST TOWER STAIR 2	Tested	6:42:43 AM	04/11/2017
Speaker/Strobe	6TH FL EAST TOWER STAIR 2	Tested	6:43:46 AM	04/11/2017
Speaker/Strobe	6TH FL EAST TOWER WOMENS RM	Tested	6:43:51 AM	04/11/2017
Speaker/Strobe	6TH FL WEST TOWER INSIDE STAIR 3	Tested	6:53:15 AM	04/11/2017
Speaker/Strobe	6TH FL WEST TOWER INSIDE STAIR 4	Tested	6:53:06 AM	04/11/2017
Speaker/Strobe	6TH FL WEST TOWER MENS ROOM	Tested	6:53:12 AM	04/11/2017
Speaker/Strobe	6TH FL WEST TOWER OPEN OFFICE	Tested	6:52:57 AM	04/11/2017
Speaker/Strobe	6TH FL WEST TOWER OPEN OFFICE	Tested	6:53:03 AM	04/11/2017
Speaker/Strobe	6TH FL WEST TOWER OUTSIDE STAIR 3	Tested	6:53:18 AM	04/11/2017
Speaker/Strobe	6TH FL WEST TOWER WOMENS ROOM	Tested	6:53:08 AM	04/11/2017
Speaker/Strobe	7TH FL EAST TOWER ATTORNEY GENERAL OFFICE	Tested	6:43:05 AM	04/11/2017
Speaker/Strobe	7TH FL EAST TOWER ATTORNEY GENERAL OFFICE	Tested	6:43:11 AM	04/11/2017
Speaker/Strobe	7TH FL EAST TOWER ATTORNEY GENERAL OFFICE SMALL SECTION	Tested	6:43:14 AM	04/11/2017
Speaker/Strobe	7TH FL EAST TOWER MENS ROOM	Tested	6:42:50 AM	04/11/2017
Speaker/Strobe	7TH FL EAST TOWER OUTSIDE STAIR 1	Tested	6:42:59 AM	04/11/2017
Speaker/Strobe	7TH FL EAST TOWER OUTSIDE STAIR 2	Tested	6:42:53 AM	04/11/2017
Speaker/Strobe	7TH FL EAST TOWER STAIR 1	Tested	6:42:56 AM	04/11/2017
Speaker/Strobe	7TH FL EAST TOWER STAIR 2	Tested	6:43:02 AM	04/11/2017
Speaker/Strobe	7TH FL EAST TOWER WOMENS ROOM	Tested	6:42:46 AM	04/11/2017
Speaker/Strobe	7TH FL WEST TOWER INSIDE STAIR 3	Tested	6:50:12 AM	04/11/2017
Speaker/Strobe	7TH FL WEST TOWER INSIDE STAIR 4	Tested	6:53:34 AM	04/11/2017
Speaker/Strobe	7TH FL WEST TOWER MENS ROOM	Tested	6:54:10 AM	04/11/2017
Speaker/Strobe	7TH FL WEST TOWER OPEN OFFICE	Tested	6:48:30 AM	04/11/2017
Speaker/Strobe	7TH FL WEST TOWER OUTSIDE STAIR 3	Tested	6:48:33 AM	04/11/2017
Speaker/Strobe	7TH FL WEST TOWER OUTSIDE STAIR 4	Tested	6:53:47 AM	04/11/2017
Speaker/Strobe	7TH FL WEST TOWER WOMENS ROOM	Tested	6:53:51 AM	04/11/2017
Speaker/Strobe	LOWER LEVEL OUTSIDE PARKING	Tested	6:41:55 AM	04/11/2017
Speaker/Strobe	LOWER LEVEL OUTSIDE PARKING	Tested	6:47:50 AM	04/11/2017
Speaker/Strobe	LOWER LEVEL OUTSIDE PARKING	Tested	6:47:53 AM	04/11/2017
Speaker/Strobe	LOWER LEVEL OUTSIDE PARKING	Tested	6:47:56 AM	04/11/2017



Device Type	Location	Service	Time	Date
<b>Passed</b>				
Speaker/Strobe	LOWER LEVEL OUTSIDE PARKING	Tested	6:47:59 AM	04/11/2017
Speaker/Strobe	LOWER LEVEL OUTSIDE PARKING	Tested	6:48:02 AM	04/11/2017
Speaker/Strobe	LOWER LEVEL OUTSIDE PARKING	Tested	6:48:05 AM	04/11/2017
Speaker/Strobe	LOWER LEVEL OUTSIDE PARKING	Tested	6:48:09 AM	04/11/2017
Speaker/Strobe	LOWER LEVEL EAST PARKING OUTSIDE	Tested	6:47:44 AM	04/11/2017
Speaker/Strobe	LOWER LEVEL EAST PARKING OUTSIDE	Tested	6:47:47 AM	04/11/2017
Speaker/Strobe	LOWER LEVEL EAST PARKING OUTSIDE ELEVATOR LOBBY	Tested	6:47:41 AM	04/11/2017
Speaker/Strobe	LOWER LEVEL EAST TOWER GARAGE BY LOADING DOCK	Tested	6:43:35 AM	04/11/2017
Strobe	3RD FL EAST TOWER MENS RM	Tested	6:45:36 AM	04/11/2017
Strobe	3RD FL EAST TOWER WOMENS RM	Tested	6:45:39 AM	04/11/2017
<b>Initiating</b>				
Pull Station	1ST FL EAST TOWER A BY MORGAN STANLEY RESTROOM	Tested	9:09:35 AM	04/11/2017
Pull Station	1ST FL EAST TOWER A BY STAIR 1 Near Morgan Stanely	Tested	8:33:35 AM	04/11/2017
Pull Station	1ST FL EAST TOWER A MIDDLE ST ENT	Tested	8:33:29 AM	04/11/2017
Pull Station	1ST FL MAIN LOBBY EXIT TO PARKING	Tested	8:31:51 AM	04/11/2017
Pull Station	1ST FL MAIN LOBBY FRONT EXIT	Tested	8:31:54 AM	04/11/2017
Pull Station	1ST FL WEST TOWER B BY STAIR 3	Tested	7:19:47 AM	04/11/2017
Pull Station	1ST FL WEST TOWER B CITIZENS BANK	Tested	9:13:43 AM	04/11/2017
Pull Station	1ST FL WEST TOWER B HANDCAP ENTRY	Tested	9:05:49 AM	04/11/2017
Pull Station	2ND FL EAST TOWER A BY STAIR 1	Tested	7:56:54 AM	04/11/2017
Pull Station	2ND FL EAST TOWER A BY STAIR 2	Tested	8:00:53 AM	04/11/2017
Pull Station	2ND FL WEST TOWER B BY STAIR 3	Tested	7:15:25 AM	04/11/2017
Pull Station	2ND FL WEST TOWER B BY STAIR 4	Tested	9:26:40 AM	04/11/2017
Pull Station	3RD FL EAST TOWER A BY STAIR 1	Tested	7:56:24 AM	04/11/2017
Pull Station	3RD FL EAST TOWER A BY STAIR 2	Tested	7:49:09 AM	04/11/2017
Pull Station	3RD FL WEST TOWER B BY STAIR 3	Tested	7:10:38 AM	04/11/2017
Pull Station	3RD FL WEST TOWER B BY STAIR 4	Tested	7:13:12 AM	04/11/2017
Pull Station	4TH FL EAST TOWER A BY STAIR 1	Tested	7:43:24 AM	04/11/2017
Pull Station	4TH FL EAST TOWER A BY STAIR 2	Tested	7:48:38 AM	04/11/2017
Pull Station	4TH FL WEST BY ELEVATOR LOBBY	Tested	7:07:35 AM	04/11/2017
Pull Station	4TH FL WEST EXIT FROM BSSN TO LOBBY	Tested	7:05:07 AM	04/11/2017
Pull Station	4TH FL WEST TOWER B BY STAIR 3	Tested	7:03:17 AM	04/11/2017
Pull Station	4TH FL WEST TOWER B BY STAIR 4	Tested	7:06:41 AM	04/11/2017
Pull Station	4TH FL WEST TOWER B IN BSSN	Tested	7:06:26 AM	04/11/2017
Pull Station	5TH FL EAST TOWER A BY STAIR 1	Tested	7:40:55 AM	04/11/2017
Pull Station	5TH FL EAST TOWER A BY STAIR 2	Tested	7:38:34 AM	04/11/2017
Pull Station	5TH FL WEST BSSN EXIT BY STAIR 4	Tested	7:02:38 AM	04/11/2017
Pull Station	5TH FL WEST TOWER B BY STAIR 3	Tested	7:00:15 AM	04/11/2017
Pull Station	5TH FL WEST TOWER B BY STAIR 4	Tested	6:58:32 AM	04/11/2017
Pull Station	6TH FL EAST TOWER A BY STAIR 1	Tested	7:27:38 AM	04/11/2017
Pull Station	6TH FL EAST TOWER A BY STAIR 1 O/S ATTORNY	Tested	7:33:40 AM	04/11/2017
Pull Station	6TH FL EAST TOWER A BY STAIR 2	Tested	7:29:54 AM	04/11/2017
Pull Station	6TH FL EAST TOWER A US ATTNBY BY ELEV LOBBY	Tested	7:32:45 AM	04/11/2017
Pull Station	6TH FL WEST TOWER B BY STAIR 3	Tested	6:56:42 AM	04/11/2017

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Pull Station	6TH FL WEST TOWER B BY STAIR 4	Tested	6:57:50 AM	04/11/2017
Pull Station	7TH FL EAST TOWER A BY PENT STAIR 2	Tested	7:22:30 AM	04/11/2017
Pull Station	7TH FL EAST TOWER A BY STAIR 1	Tested	7:26:42 AM	04/11/2017
Pull Station	7TH FL WEST TOWER B BY STAIR 3	Tested	6:51:39 AM	04/11/2017
Pull Station	7TH FL WEST TOWER B BY STAIR 4	Tested	6:50:30 AM	04/11/2017
Smoke Detector	PENTHOUSE EAST TOWER A ELEV MACH RM	Tested	8:28:08 AM	04/11/2017
Smoke Detector	PENTHOUSE EAST TOWER A OPEN SPACE	Tested	7:23:40 AM	04/11/2017
Smoke Detector	PENTHOUSE WEST TOWER B ELEV MACH RM	Tested	8:47:38 AM	04/11/2017
Smoke Detector	PENTHOUSE WEST TOWER B IN STAIR 4	Tested	6:48:55 AM	04/11/2017
Smoke Detector	PENTHOUSE WEST TOWER B OPEN SPACE	Tested	6:49:32 AM	04/11/2017
Smoke Detector	1ST FL EAST TOWER A BY MAIL RM	Tested	9:04:39 AM	04/11/2017
Smoke Detector	1ST FL EAST TOWER A ELEV LOBBY	Tested	8:24:38 AM	04/11/2017
Smoke Detector	1ST FL EAST TOWER A IN STAIR 1	Tested	9:10:23 AM	04/11/2017
Smoke Detector	1ST FL EAST TOWER A MIDDLE ST ENT	Tested	9:05:09 AM	04/11/2017
Smoke Detector	1ST FL WEST TOWER B BY MANAG OFFC	Tested	9:07:31 AM	04/11/2017
Smoke Detector	1ST FL WEST TOWER B CITIZENS BANK	Tested	9:13:47 AM	04/11/2017
Smoke Detector	1ST FL WEST TOWER B CITIZENS BANK	Tested	9:13:53 AM	04/11/2017
Smoke Detector	1ST FL WEST TOWER B ELEV LOBBY	Tested	8:43:36 AM	04/11/2017
Smoke Detector	1ST FL WEST TOWER B HALL BY STAIR 3	Tested	7:20:11 AM	04/11/2017
Smoke Detector	1ST FL WEST TOWER B HALL BY STAIR 3	Tested	7:20:32 AM	04/11/2017
Smoke Detector	1ST FL WEST TOWER B HANDICAP ENTR	Tested	9:06:21 AM	04/11/2017
Smoke Detector	1ST FL WEST TOWER B SECURITY DESK	Tested	9:04:02 AM	04/11/2017
Smoke Detector	2ND FL EAST ELECTRIC ROOM	Tested	8:00:00 AM	04/11/2017
Smoke Detector	2ND FL EAST TOWER A BY ELEC RM	Tested	8:00:19 AM	04/11/2017
Smoke Detector	2ND FL EAST TOWER A BY RESTROOMS	Tested	7:59:38 AM	04/11/2017
Smoke Detector	2ND FL EAST TOWER A BY STAIR 1	Tested	7:57:25 AM	04/11/2017
Smoke Detector	2ND FL EAST TOWER A BY STAIR 2	Tested	8:00:43 AM	04/11/2017
Smoke Detector	2ND FL EAST TOWER A ELEV LOBBY	Tested	8:23:40 AM	04/11/2017
Smoke Detector	2ND FL EAST TOWER A NORTHCROSS GROUP	Tested	8:03:29 AM	04/11/2017
Smoke Detector	2ND FL EAST TOWER A NORTHCROSS GROUP	Tested	8:03:49 AM	04/11/2017
Smoke Detector	2ND FL EAST TOWER A NORTHCROSS GROUP	Tested	8:04:16 AM	04/11/2017
Smoke Detector	2ND FL EAST TOWER A NORTHCROSS GROUP	Tested	8:04:41 AM	04/11/2017
Smoke Detector	2ND FL EAST TOWER A OUTSIDE SCORE	Tested	8:01:27 AM	04/11/2017
Smoke Detector	2ND FL EAST TOWER A REAR OF SCORE	Tested	8:01:50 AM	04/11/2017
Smoke Detector	2ND FL EAST TOWER A SCORE TRAINING ROOM	Tested	8:02:21 AM	04/11/2017
Smoke Detector	2ND FL EAST TOWER A RHI REAR OFFICE	Tested	7:58:46 AM	04/11/2017
Smoke Detector	2ND FL WEST ELECTRIC ROOM	Tested	7:15:53 AM	04/11/2017
Smoke Detector	2ND FL WEST INSIDE BOA BY KITCHEN	Tested	9:21:55 AM	04/11/2017
Smoke Detector	2ND FL WEST INSIDE BOA ENTRANCE	Tested	7:16:37 AM	04/11/2017
Smoke Detector	2ND FL WEST OUTSIDE BOA ENTRANCE	Tested	7:16:14 AM	04/11/2017
Smoke Detector	2ND FL WEST TOWER B ELEV LOBBY	Tested	8:43:24 AM	04/11/2017
Smoke Detector	2ND FL WEST TOWER B HALL BY STAIR 3	Tested	7:15:15 AM	04/11/2017
Smoke Detector	2ND FL WEST TOWER B INSIDE BOA BY STAIR 4	Tested	7:17:47 AM	04/11/2017
Smoke Detector	2ND FL WEST TOWER B OUTSIDE STAIR 4	Tested	9:26:34 AM	04/11/2017
Smoke Detector	2ND FL WEST TOWER B SECRET SVC BY EVIDENC	Tested	9:21:12 AM	04/11/2017
Smoke Detector	2ND FL WEST TOWER B SECRET SVC BY SERVER	Tested	9:21:08 AM	04/11/2017
Smoke Detector	2ND FL WEST TOWER B INSIDE BOA LOBBY	Tested	7:19:03 AM	04/11/2017
Smoke Detector	3RD FL EAST ELECTRIC ROOM	Tested	7:50:23 AM	04/11/2017
Smoke Detector	3RD FL EAST TOWER A BY ELEC RM	Tested	7:50:03 AM	04/11/2017
Smoke Detector	3RD FL EAST TOWER A BY RESTROOMS	Tested	7:50:55 AM	04/11/2017

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Smoke Detector	3RD FL EAST TOWER A BY STAIR 1	Tested	7:56:15 AM	04/11/2017
Smoke Detector	3RD FL EAST TOWER A BY STAIR 2	Tested	7:49:30 AM	04/11/2017
Smoke Detector	3RD FL EAST TOWER A EAST CORRIDOR	Tested	7:51:40 AM	04/11/2017
Smoke Detector	3RD FL EAST TOWER A EAST CORRIDOR	Tested	7:54:59 AM	04/11/2017
Smoke Detector	3RD FL EAST TOWER A ELEV LOBBY	Tested	8:20:36 AM	04/11/2017
Smoke Detector	3RD FL EAST TOWER A NRTH CORRIDOR	Tested	7:54:43 AM	04/11/2017
Smoke Detector	3RD FL EAST TOWER A OPEN OFFICE	Tested	7:52:02 AM	04/11/2017
Smoke Detector	3RD FL EAST TOWER A OPEN OFFICE	Tested	7:52:31 AM	04/11/2017
Smoke Detector	3RD FL EAST TOWER A OPEN OFFICE	Tested	7:52:51 AM	04/11/2017
Smoke Detector	3RD FL EAST TOWER A OPEN OFFICE	Tested	7:54:25 AM	04/11/2017
Smoke Detector	3RD FL EAST TOWER A OPEN OFFICE	Tested	7:55:46 AM	04/11/2017
Smoke Detector	3RD FL EAST TOWER A OPEN OFFICE AREA	Tested	7:55:23 AM	04/11/2017
Smoke Detector	3RD FL EAST TOWER A RECEIPT AREA	Tested	7:51:16 AM	04/11/2017
Smoke Detector	3RD FL EAST TOWER A WEST CORRIDOR	Tested	7:53:29 AM	04/11/2017
Smoke Detector	3RD FL WEST BY ELEV INSIDE BOA BY KITCHEN	Tested	7:12:39 AM	04/11/2017
Smoke Detector	3RD FL WEST BY ELEV INSIDE BOA VESTIBULE	Tested	7:11:51 AM	04/11/2017
Smoke Detector	3RD FL WEST BY ELEV OUTSIDE BOA ENTRANCE	Tested	7:11:34 AM	04/11/2017
Smoke Detector	3RD FL WEST ELECTRIC ROOM	Tested	7:11:13 AM	04/11/2017
Smoke Detector	3RD FL WEST EXIT BY STAIR 3	Tested	7:09:52 AM	04/11/2017
Smoke Detector	3RD FL WEST TOWER B BY ELEV LOBBY	Tested	8:43:17 AM	04/11/2017
Smoke Detector	3RD FL WEST TOWER B BY STAIR 3	Tested	7:10:31 AM	04/11/2017
Smoke Detector	3RD FL WEST TOWER B CORR BY STAIR 3	Tested	7:09:24 AM	04/11/2017
Smoke Detector	3RD FL WEST TOWER B CORR BY STAIR 4	Tested	7:12:57 AM	04/11/2017
Smoke Detector	4TH FL EAST ELECTRIC ROOM	Tested	7:47:01 AM	04/11/2017
Smoke Detector	4TH FL EAST TOWER A BY B.D.M.P.	Tested	7:46:37 AM	04/11/2017
Smoke Detector	4TH FL EAST TOWER A BY STAIR 1	Tested	7:43:47 AM	04/11/2017
Smoke Detector	4TH FL EAST TOWER A ELEV LOBBY	Tested	8:18:15 AM	04/11/2017
Smoke Detector	4TH FL EAST TOWER A GRETA DIAMOND CONFERENCE	Tested	8:18:23 AM	04/11/2017
Smoke Detector	4TH FL EAST TOWER A IN B.D.M.P.	Tested	7:44:05 AM	04/11/2017
Smoke Detector	4TH FL EAST TOWER A IN B.D.M.P.	Tested	7:45:27 AM	04/11/2017
Smoke Detector	4TH FL EAST TOWER A IN B.D.M.P.	Tested	7:48:25 AM	04/11/2017
Smoke Detector	4TH FL EAST TOWER A OPEN OFFICE	Tested	7:47:33 AM	04/11/2017
Smoke Detector	4TH FL WEST ELECTRIC ROOM	Tested	7:08:01 AM	04/11/2017
Smoke Detector	4TH FL WEST INSIDE BSSN COMMON AREA	Tested	7:05:44 AM	04/11/2017
Smoke Detector	4TH FL WEST INSIDE BSSN COMMON AREA	Tested	7:06:17 AM	04/11/2017
Smoke Detector	4TH FL WEST INSIDE FBI MIDDLE ST SIDE	Tested	9:19:26 AM	04/11/2017
Smoke Detector	4TH FL WEST TOWER B BY RESTROOMS	Tested	7:07:23 AM	04/11/2017
Smoke Detector	4TH FL WEST TOWER B BY STAIR 3	Tested	7:08:26 AM	04/11/2017
Smoke Detector	4TH FL WEST TOWER B BY STAIR 4	Tested	7:07:04 AM	04/11/2017
Smoke Detector	4TH FL WEST TOWER B ELEV LOBBY	Tested	8:43:11 AM	04/11/2017
Smoke Detector	4TH FL WEST TOWER B INSIDE BSSN COMMON AREA	Tested	7:04:26 AM	04/11/2017
Smoke Detector	4TH FL WEST TOWER B INSIDE BSSN COMMON AREA	Tested	7:04:58 AM	04/11/2017
Smoke Detector	5TH FL EAST ELEC BREAKER ROOM	Tested	7:41:40 AM	04/11/2017
Smoke Detector	5TH FL EAST ELEC TRANSFORMER RM	Tested	7:41:59 AM	04/11/2017
Smoke Detector	5TH FL EAST TOWER A BY ELEC RM	Tested	7:42:15 AM	04/11/2017
Smoke Detector	5TH FL EAST TOWER A BY STAIR 1	Tested	7:40:46 AM	04/11/2017
Smoke Detector	5TH FL EAST TOWER A BY STAIR 2	Tested	7:38:56 AM	04/11/2017

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
Smoke Detector	5TH FL EAST TOWER A CONFERENCE RM	Tested	8:28:36 AM	04/11/2017
Smoke Detector	5TH FL EAST TOWER A ELEV LOBBY	Tested	8:16:15 AM	04/11/2017
Smoke Detector	5TH FL WEST ELECTRIC ROOM	Tested	7:01:54 AM	04/11/2017
Smoke Detector	5TH FL WEST TOWER B BY IB CONF RM	Tested	7:01:34 AM	04/11/2017
Smoke Detector	5TH FL WEST TOWER B BY RESTROOMS	Tested	7:01:18 AM	04/11/2017
Smoke Detector	5TH FL WEST TOWER B BY STAIR 3	Tested	7:02:27 AM	04/11/2017
Smoke Detector	5TH FL WEST TOWER B BY STAIR 4	Tested	6:59:20 AM	04/11/2017
Smoke Detector	5TH FL WEST TOWER B ELEV LOBBY	Tested	8:43:05 AM	04/11/2017
Smoke Detector	5TH FL WEST TOWER B SPIRAL STAIR	Tested	8:47:44 AM	04/11/2017
Smoke Detector	6TH FL EAST ELECTRIC ROOM	Tested	7:28:56 AM	04/11/2017
Smoke Detector	6TH FL EAST TOWER A BY ELEC RM	Tested	7:29:20 AM	04/11/2017
Smoke Detector	6TH FL EAST TOWER A BY RESTROOMS	Tested	7:28:18 AM	04/11/2017
Smoke Detector	6TH FL EAST TOWER A BY STAIR 2	Tested	7:29:42 AM	04/11/2017
Smoke Detector	6TH FL EAST TOWER A ELEV LOBBY	Tested	8:14:54 AM	04/11/2017
Smoke Detector	6TH FL EAST TOWER A STAIR 1 IN US ATTORNY GENERAL	Tested	7:33:28 AM	04/11/2017
Smoke Detector	6TH FL WEST ELECTRIC ROOM	Tested	6:55:16 AM	04/11/2017
Smoke Detector	6TH FL WEST TOWER B ELEV LOBBY	Tested	8:39:40 AM	04/11/2017
Smoke Detector	7TH FL EAST ELECTRIC ROOM	Tested	7:25:41 AM	04/11/2017
Smoke Detector	7TH FL EAST TOWER A ATTORNEY SMALL SECTION	Tested	7:36:15 AM	04/11/2017
Smoke Detector	7TH FL EAST TOWER A BY ELEC RM	Tested	7:25:21 AM	04/11/2017
Smoke Detector	7TH FL EAST TOWER A BY RESTROOMS	Tested	7:26:04 AM	04/11/2017
Smoke Detector	7TH FL EAST TOWER A BY STAIR 2	Tested	7:25:01 AM	04/11/2017
Smoke Detector	7TH FL EAST TOWER A ELEV LOBBY	Tested	8:13:42 AM	04/11/2017
Smoke Detector	7TH FL EAST TOWER A IN STAIR 1	Tested	7:27:12 AM	04/11/2017
Smoke Detector	7TH FL EAST TOWER A OUTSIDE STAIR 1	Tested	7:26:31 AM	04/11/2017
Smoke Detector	7TH FL EAST TOWER A US ATTORNEY SMALL SECTION	Tested	7:36:28 AM	04/11/2017
Smoke Detector	7TH FL WEST ELECTRIC RM	Tested	6:53:40 AM	04/11/2017
Smoke Detector	7TH FL WEST TOWER B ELECTRIC RM	Tested	6:54:04 AM	04/11/2017
Smoke Detector	7TH FL WEST TOWER B ELEV LOBBY	Tested	8:37:43 AM	04/11/2017
Smoke Detector	7TH FL WEST TOWER B IN STAIR 3	Tested	6:52:09 AM	04/11/2017
Smoke Detector	7TH FL EAST TOWER A INSIDE STAIR 2 TO PENTHOUSE	Tested	7:23:04 AM	04/11/2017
Smoke Detector	LOWER LEVEL EAST PARKING EAST ELEVATOR LOBBY	Tested	8:11:07 AM	04/11/2017
Smoke Detector	LOWER LEVEL WEST PARKING ELECTRIC ROOM	Tested	9:26:44 AM	04/11/2017
Smoke Detector	LOWER LEVEL WEST PARKING ELEVATOR LOBBY	Tested	8:47:25 AM	04/11/2017
<b><i>Untested</i></b>				
<b>Initiating</b>				
Smoke Detector	4TH FL WEST INSIDE ICE COMMON AREA			

# Service Summary

Generated by: BuildingReports.com

Building: 100 Middle Street		
<i>The Service Summary section provides an overview of the services performed in this report.</i>		
Device Type	Service	Quantity
<b><i>Passed</i></b>		
Battery	Checked	8
Control Panel	Tested	1
Expander Panel	Tested	3
Pull Station	Tested	38
Releasing Device	Tested	3
Smoke Detector	Tested	126
Speaker/Strobe	Tested	164
Strobe	Tested	2
Total		345
<b><i>Untested</i></b>		
Smoke Detector		1
Total		1

# Auxiliary Functions Testing

Generated by: BuildingReports.com

Building: 100 Middle Street		Control Panel: 1 - GE Security EST-3		
<p><i>The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.</i></p>				
Type	Location	Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Releasing Device</b>				
Door Holder	3RD FL WEST TOWER BOTTOM OF STAIRS	Passed	18982093	<input type="checkbox"/>
Door Holder	7TH FL WEST TOWER B ELEV LOBBY	Passed	18982021	<input type="checkbox"/>
Door Holder	7TH FL WEST TOWER B ELEV LOBBY	Passed	18982022	<input type="checkbox"/>
<b>Smoke Detector</b>				
Elevator Recall	1ST FL EAST TOWER A ELEV LOBBY	Passed	18981846	<input type="checkbox"/>
Elevator Recall	2ND FL EAST TOWER A ELEV LOBBY	Passed	18981964	<input type="checkbox"/>
Elevator Recall	4TH FL EAST TOWER A ELEV LOBBY	Passed	18981889	<input type="checkbox"/>
Elevator Recall	5TH FL EAST TOWER A ELEV LOBBY	Passed	18981876	<input type="checkbox"/>
Elevator Recall	6TH FL EAST TOWER A ELEV LOBBY	Passed	18981875	<input type="checkbox"/>
Elevator Recall	7TH FL EAST TOWER A ELEV LOBBY	Passed	18981814	<input type="checkbox"/>

# Smoke Management Testing

Generated by: BuildingReports.com

Building: 100 Middle Street		Control Panel: 1 - GE Security EST-3		
<i>The Smoke Management Testing section details the test and inspection of device items that are involved in controlling the spread of smoke in a building. Items are grouped by Passed or Failed/Other.</i>				
☐ Location	Description	🔧 Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Releasing Device</b>				
3RD FL WEST TOWER BOTTOM OF STAIRS	Door Holder	Passed	18982093	<input type="checkbox"/>
7TH FL WEST TOWER B ELEV LOBBY	Door Holder	Passed	18982021	<input type="checkbox"/>
7TH FL WEST TOWER B ELEV LOBBY	Door Holder	Passed	18982022	<input type="checkbox"/>

# Battery & Power Supply Testing

Generated by: BuildingReports.com

Building: 100 Middle Street		Control Panel: 1 - GE Security EST-3					
<p>The Control &amp; Power Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.</p>							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
<b>Passed</b>							
<b>Battery</b>							
Sealed Lead Acid	1ST FL SECURITY DESK INSIDE FLEXALERT	18	12				
Sealed Lead Acid	1ST FL SECURITY DESK INSIDE FLEXALERT	18	12				
Sealed Lead Acid	2ND FL WEST ELECTRIC ROOM IN BOOSTER	7.5	12				
Sealed Lead Acid	2ND FL WEST ELECTRIC ROOM IN BOOSTER	7.5	12				
Sealed Lead Acid	3RD FL EAST ELECTRIC ROOM INSIDE BOOSTER	7	12				
Sealed Lead Acid	3RD FL EAST ELECTRIC ROOM INSIDE BOOSTER	7	12				
Sealed Lead Acid	3RD FL WEST TOWER B INSIDE BOOSTER	7.5	12				
Sealed Lead Acid	3RD FL WEST TOWER B INSIDE BOOSTER	7.5	12				



# Inventory & Warranty Report

Generated by: BuildingReports.com

Building: 100 Middle Street		Control Panel: 1 - GE Security EST-3		
<p><i>The Inventory &amp; Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.</i></p>				
Device or Item	Category	% of Inventory	Quantity	
Smoke Detector	Initiating	36.71%	127	
Speaker/Strobe	Indicating	47.40%	164	
Strobe	Indicating	0.58%	2	
Releasing Device	Auxiliary	0.87%	3	
Control Panel	Control	0.29%	1	
Pull Station	Initiating	10.98%	38	
Expander Panel	Control	0.87%	3	
Battery	Control	2.31%	8	
Type	Qty	Model #	Description	Install Date
<b><i>In Service - 1 Year to 2 Years</i></b>				
<b>Genesis</b>				
Battery	1	NP12-7	Sealed Lead Acid	02/19/2016
Battery	1	NP7-12	Sealed Lead Acid	02/19/2016
<b><i>In Service - 2 Years to 3 Years</i></b>				
<b>GENESIS</b>				
Battery	2		Sealed Lead Acid	03/12/2015
<b><i>In Service - 3 Years to 5 Years</i></b>				
<b>Genesis</b>				
Battery	2		Sealed Lead Acid	04/01/2014
<b>Sigmas</b>				
Battery	2	SP 12-7.5	Sealed Lead Acid	07/26/2013
<b><i>In Service - 5 Years to 10 Years</i></b>				
<b>GE Security</b>				
Control Panel	1	EST-3		05/08/2009
Expander Panel	1	BPS 6A		05/08/2009
Expander Panel	2	BPS-6A		05/08/2009
Pull Station	38	SIGA-278	Dual Action	05/08/2009
Releasing Device	3		Door Holder	05/08/2009
Smoke Detector	126	SIGA-PS	Photoelectric	05/08/2009
Speaker/Strobe	159	G4F-S7VM		05/08/2009
<b>SPACE AGE</b>				
Speaker/Strobe	1			05/08/2009
<b>Wheelock</b>				
Speaker/Strobe	4			05/08/2009

Strobe	2			05/08/2009
<b>GE Security</b>				
Smoke Detector	1	SIGA-PS	Photoelectric	05/09/2008

# Zone Address Report

Generated by: BuildingReports.com

**Building: 100 Middle Street**

**Control Panel: 1 - GE Security  
EST-3**

*The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.*

Address	Device Type	Location	Type	ScanID
<b>Zone/Circuit: 02</b>				
0001	Smoke Detector	LOWER LEVEL WEST PARKING ELEVATOR LOBBY	Photoelectric	18982020
0002	Smoke Detector	LOWER LEVEL EAST PARKING EAST ELEVATOR LOBBY	Photoelectric	18982006
0003	Smoke Detector	LOWER LEVEL WEST PARKING ELECTRIC ROOM	Photoelectric	18982008
0004	Smoke Detector	1ST FL WEST TOWER B CITIZENS BANK	Photoelectric	18982156
0005	Smoke Detector	1ST FL WEST TOWER B CITIZENS BANK	Photoelectric	18982154
0006	Smoke Detector	1ST FL WEST TOWER B ELEV LOBBY	Photoelectric	18981848
0007	Smoke Detector	1ST FL WEST TOWER B HANDICAP ENTR	Photoelectric	18982152
0008	Smoke Detector	1ST FL WEST TOWER B HALL BY STAIR 3	Photoelectric	18982157
0009	Smoke Detector	1ST FL WEST TOWER B HALL BY STAIR 3	Photoelectric	18982159
0010	Smoke Detector	1ST FL WEST TOWER B BY MANAG OFFC	Photoelectric	18981849
0011	Smoke Detector	1ST FL WEST TOWER B SECURITY DESK	Photoelectric	18982161
0012	Smoke Detector	2ND FL WEST TOWER B ELEV LOBBY	Photoelectric	18982129
0013	Smoke Detector	2ND FL WST TOWER B INSIDE BOA LOBBY	Photoelectric	18982128
0014	Smoke Detector	2ND FL WEST TOWER B INSIDE BOA BY STAIR 4	Photoelectric	18982125
0015	Smoke Detector	2ND FL WEST TOWER B OUTSIDE STAIR 4	Photoelectric	18982143
0016	Smoke Detector	3RD FL WEST ELECTRIC ROOM	Photoelectric	18982107
0017	Smoke Detector	2ND FL WEST INSIDE BOA ENTRANCE	Photoelectric	18982120
0018	Smoke Detector	2ND FL WEST OUTSIDE BOA ENTRANCE	Photoelectric	18982130
0019	Smoke Detector	2ND FL WEST TOWER B HALL BY STAIR 3	Photoelectric	18982137
0020	Smoke Detector	2ND FL WEST INSIDE BOA BY KITCHEN	Photoelectric	18982123
0021	Smoke Detector	3RD FL WEST TOWER B CORR BY STAIR 3	Photoelectric	18982112
0022	Smoke Detector	3RD FL WEST TOWER B BY STAIR 3	Photoelectric	18982111
0023	Smoke Detector	2ND FL WEST ELECTRIC ROOM	Photoelectric	18982131
0024	Smoke Detector	3RD FL WEST BY ELEV INSIDE BOA VESTIBULE	Photoelectric	18982113
0025	Smoke Detector	3RD FL WEST BY ELEV OUTSIDE BOA ENTRANCE	Photoelectric	18982103
0026	Smoke Detector	3RD FL WEST BY ELEV INSIDE BOA BY KITCHEN	Photoelectric	18982116
0027	Smoke Detector	3RD FL WEST TOWER B CORR BY STAIR 4	Photoelectric	18982099
0028	Smoke Detector	3RD FL WEST TOWER B BY ELEV LOBBY	Photoelectric	18982092
0029	Smoke Detector	2ND FL WEST TOWR B SECRET SVC BY EVIDENC	Photoelectric	18982139
0030	Smoke Detector	3RD FL WEST EXIT BY STAIR 3	Photoelectric	18982119
0031	Smoke Detector	2ND FL WEST TOWR B SECRET SVC BY	Photoelectric	18982140

SERVER				
0130	Pull Station	1ST FL WEST TOWER B BY STAIR 3	Dual Action	18982160
0133	Pull Station	1ST FL WEST TOWER B CITIZENS BANK	Dual Action	18982153
0134	Pull Station	1ST FL WEST TOWER B HANDCAP ENTRY	Dual Action	18982151
0135	Pull Station	1ST FL MAIN LOBBY FRONT EXIT	Dual Action	18981855
0136	Pull Station	2ND FL WEST TOWER B BY STAIR 4	Dual Action	18982144
0139	Pull Station	2ND FL WEST TOWER B BY STAIR 3	Dual Action	18982135
0142	Pull Station	3RD FL WEST TOWER B BY STAIR 3	Dual Action	18982110
0143	Pull Station	3RD FL WEST TOWER B BY STAIR 4	Dual Action	18982096
0158	Pull Station	1ST FL MAIN LOBBY EXIT TO PARKING	Dual Action	18981850

**Zone/Circuit: 03**

0001	Smoke Detector	4TH FL WEST TOWER B ELEV LOBBY	Photoelectric	18982080
0002	Smoke Detector	4TH FL WEST TOWER B BY STAIR 3	Photoelectric	18982077
0003	Smoke Detector	4TH FL WEST INSIDE ICE COMMON AREA	Photoelectric	3935795621
0004	Smoke Detector	7TH FL WEST ELECTRIC RM	Photoelectric	18982023
0005	Smoke Detector	4TH FL WEST INSIDE FBI MIDDLE ST SIDE	Photoelectric	18982164
0006	Smoke Detector	4TH FL WEST INSIDE BSSN COMMON AREA	Photoelectric	18982083
0007	Smoke Detector	4TH FL WEST INSIDE BSSN COMMON AREA	Photoelectric	18982081
0009	Smoke Detector	4TH FL WEST TOWER B INSIDE BSSN COMMON AREA	Photoelectric	18982072
0010	Smoke Detector	4TH FL WEST TOWER B INSIDE BSSN COMMON AREA	Photoelectric	18982069
0011	Smoke Detector	4TH FL WEST TOWER B BY RESTROOMS	Photoelectric	18982089
0012	Smoke Detector	4TH FL WEST TOWER B BY STAIR 4	Photoelectric	18982088
0014	Smoke Detector	5TH FL WEST TOWER B ELEV LOBBY	Photoelectric	18982051
0015	Smoke Detector	6TH FL WEST ELECTRIC ROOM	Photoelectric	18982043
0016	Smoke Detector	5TH FL WEST TOWER B BY STAIR 4	Photoelectric	18982059
0017	Smoke Detector	5TH FL WEST TOWER B BY RESTROOMS	Photoelectric	18982061
0018	Smoke Detector	5TH FL WEST TOWER B BY IB CONF RM	Photoelectric	18982064
0019	Smoke Detector	5TH FL WEST TOWER B BY STAIR 3	Photoelectric	18982066
0020	Smoke Detector	5TH FL WEST TOWER B SPIRAL STAIR	Photoelectric	18982050
0021	Smoke Detector	6TH FL WEST TOWER B ELEV LOBBY	Photoelectric	18982039
0022	Smoke Detector	5TH FL WEST ELECTRIC ROOM	Photoelectric	18982065
0023	Smoke Detector	7TH FL WEST TOWER B IN STAIR 3	Photoelectric	18982029
0024	Smoke Detector	7TH FL WEST TOWER B ELEV LOBBY	Photoelectric	18982019
0025	Smoke Detector	7TH FL WEST TOWER B ELECTRIC RM	Photoelectric	18982024
0026	Smoke Detector	PENTHOUSE WEST TOWER B IN STAIR 4	Photoelectric	18982037
0027	Smoke Detector	PENTHOUSE WEST TOWER B OPEN SPACE	Photoelectric	18982036
0029	Smoke Detector	PENTHOUSE WEST TOWER B ELEV MACH RM	Photoelectric	18982038
0030	Smoke Detector	4TH FL WEST ELECTRIC ROOM	Photoelectric	18982078
0129	Pull Station	4TH FL WEST TOWER B IN BSSN	Dual Action	18982084
0130	Pull Station	4TH FL WEST EXIT FROM BSSN TO LOBBY	Dual Action	18982070
0132	Pull Station	4TH FL WEST TOWER B BY STAIR 3	Dual Action	18982074
0133	Pull Station	4TH FL WEST TOWER B BY STAIR 4	Dual Action	18982085
0134	Pull Station	5TH FL WEST TOWER B BY STAIR 3	Dual Action	18982053
0138	Pull Station	5TH FL WEST TOWER B BY STAIR 4	Dual Action	18982057
0139	Pull Station	6TH FL WEST TOWER B BY STAIR 3	Dual Action	18982041
0142	Pull Station	6TH FL WEST TOWER B BY STAIR 4	Dual Action	18982046
0143	Pull Station	7TH FL WEST TOWER B BY STAIR 3	Dual Action	18982027
0146	Pull Station	7TH FL WEST TOWER B BY STAIR 4	Dual Action	18982032

0157	Pull Station	4TH FL WEST BY ELEVATOR LOBBY	Dual Action	18982079
0158	Pull Station	5TH FL WEST BSSN EXIT BY STAIR 4	Dual Action	18982067

**Zone/Circuit: 04**

0001	Smoke Detector	1ST FL EAST TOWER A ELEV LOBBY	Photoelectric	18981846
0002	Smoke Detector	1ST FL EAST TOWER A IN STAIR 1	Photoelectric	18982001
0003	Smoke Detector	1ST FL EAST TOWER A MIDDLE ST ENT	Photoelectric	18982004
0004	Smoke Detector	1ST FL EAST TOWER A BY MAIL RM	Photoelectric	18981847
0005	Smoke Detector	2ND FL EAST ELECTRIC ROOM	Photoelectric	18981979
0006	Smoke Detector	2ND FL EAST TOWER A ELEV LOBBY	Photoelectric	18981964
0007	Smoke Detector	3RD FL EAST ELECTRIC ROOM	Photoelectric	18981931
0008	Smoke Detector	2ND FL EAST TOWER A BY STAIR 2	Photoelectric	18981975
0009	Smoke Detector	2ND FL EAST TOWER A REaR OF SCORE	Photoelectric	18981966
0011	Smoke Detector	2ND FL EAST TOWER A SCORE TRAINING ROOM	Photoelectric	18981969
0012	Smoke Detector	2ND FL EAST TOWER A OUTSIDE SCORE	Photoelectric	18981965
0013	Smoke Detector	2ND FL EAST TOWER A BY ELEC RM	Photoelectric	18981977
0014	Smoke Detector	2ND FL EAST TOWER A BY RESTROOMS	Photoelectric	18981983
0015	Smoke Detector	2ND FL EAST TOWER A BY STAIR 1	Photoelectric	18981984
0016	Smoke Detector	2ND FL EAST TOWER A RHI REAR OFFICE	Photoelectric	18981988
0017	Smoke Detector	2ND FL EAST TOWER A NORTHCROSS GROUP	Photoelectric	18981995
0018	Smoke Detector	2ND FL EAST TOWER A NORTHCROSS GROUP	Photoelectric	18981994
0019	Smoke Detector	2ND FL EAST TOWER A NORTHCROSS GROUP	Photoelectric	18981997
0020	Smoke Detector	2ND FL EAST TOWER A NORTHCROSS GROUP	Photoelectric	18981993
0022	Smoke Detector	3RD FL EAST TOWER A ELEV LOBBY	Photoelectric	18981917
0023	Smoke Detector	3RD FL EAST TOWER A OPEN OFFICE	Photoelectric	18981958
0024	Smoke Detector	3RD FL EAST TOWER A OPEN OFFICE	Photoelectric	18981961
0025	Smoke Detector	3RD FL EAST TOWER A OPEN OFFICE	Photoelectric	18981963
0026	Smoke Detector	3RD FL EAST TOWER A BY RESTROOMS	Photoelectric	18981923
0027	Smoke Detector	3RD FL EAST TOWER A RECEIPT AREA	Photoelectric	18981939
0028	Smoke Detector	3RD FL EAST TOWER A EAST CORRIDOR	Photoelectric	18981940
0029	Smoke Detector	3RD FL EAST TOWER A BY STAIR 1	Photoelectric	18981918
0030	Smoke Detector	3RD FL EAST TOWER A OPEN OFFICE	Photoelectric	18981942
0031	Smoke Detector	3RD FL EAST TOWER A OPEN OFFICE AREA	Photoelectric	18981945
0032	Smoke Detector	3RD FL EAST TOWER A EAST CORRIDOR	Photoelectric	18981946
0033	Smoke Detector	3RD FL EAST TOWER A NRTH CORRIDOR	Photoelectric	18981948
0034	Smoke Detector	3RD FL EAST TOWER A OPEN OFFICE	Photoelectric	18981950
0035	Smoke Detector	3RD FL EAST TOWER A WEST CORRIDOR	Photoelectric	18981957
0036	Smoke Detector	3RD FL EAST TOWER A BY ELEC RM	Photoelectric	18981935
0037	Smoke Detector	3RD FL EAST TOWER A BY STAIR 2	Photoelectric	18981928
0128	Pull Station	1ST FL EAST TOWER A BY MORGAN STANLEY RESTROOM	Dual Action	18982000
0129	Pull Station	1ST FL EAST TOWER A BY STAIR 1 Near Morgan Stanely	Dual Action	18981998
0130	Pull Station	1ST FL EAST TOWER A MIDDLE ST ENT	Dual Action	18982005
0131	Pull Station	2ND FL EAST TOWER A BY STAIR 1	Dual Action	18981989
0134	Pull Station	2ND FL EAST TOWER A BY STAIR 2	Dual Action	18981974
0135	Pull Station	3RD FL EAST TOWER A BY STAIR 1	Dual Action	18981919
0138	Pull Station	3RD FL EAST TOWER A BY STAIR 2	Dual Action	18981929

**Zone/Circuit: 05**

0001	Smoke Detector	4TH FL EAST ELECTRIC ROOM	Photoelectric	18981903
0002	Smoke Detector	4TH FL EAST TOWER A ELEV LOBBY	Photoelectric	18981889
0003	Smoke Detector	4TH FL EAST TOWER A IN B.D.M.P.	Photoelectric	18981905
0004	Smoke Detector	4TH FL EAST TOWER A IN B.D.M.P.	Photoelectric	18981912
0005	Smoke Detector	4TH FL EAST TOWER A OPEN OFFICE	Photoelectric	18981901
0006	Smoke Detector	4TH FL EAST TOWER A GRETA DIAMOND CONFERENCE	Photoelectric	18981900
0007	Smoke Detector	4TH FL EAST TOWER A BY STAIR 1	Photoelectric	18981893
0008	Smoke Detector	4TH FL EAST TOWER A IN B.D.M.P.	Photoelectric	18981897
0009	Smoke Detector	4TH FL EAST TOWER A BY B.D.M.P.	Photoelectric	18981909
0010	Smoke Detector	5TH FL EAST ELEC TRANSFORMER RM	Photoelectric	18981880
0011	Smoke Detector	5TH FL EAST ELEC BREAKER ROOM	Photoelectric	18981882
0012	Smoke Detector	5TH FL EAST TOWER A ELEV LOBBY	Photoelectric	18981876
0013	Smoke Detector	6TH FL EAST ELECTRIC ROOM	Photoelectric	18981868
0014	Smoke Detector	5TH FL EAST TOWER A BY STAIR 2	Photoelectric	18981886
0015	Smoke Detector	5TH FL EAST TOWER A BY ELEC RM	Photoelectric	18981881
0016	Smoke Detector	5TH FL EAST TOWER A CONFERENCE RM	Photoelectric	18981877
0017	Smoke Detector	5TH FL EAST TOWER A BY STAIR 1	Photoelectric	18981892
0018	Smoke Detector	6TH FL EAST TOWER A ELEV LOBBY	Photoelectric	18981875
0019	Smoke Detector	6TH FL EAST TOWER A BY RESTROOMS	Photoelectric	18981869
0020	Smoke Detector	6TH FL EAST TOWER A BY ELEC RM	Photoelectric	18981867
0021	Smoke Detector	6TH FL EAST TOWER A BY STAIR 2	Photoelectric	18981866
0022	Smoke Detector	6TH FL EAST TOWER A STAIR 1 IN US ATTORNEY GENERAL	Photoelectric	18981844
0023	Smoke Detector	7TH FL EAST ELECTRIC ROOM	Photoelectric	18981820
0024	Smoke Detector	7TH FL EAST TOWER A IN STAIR 1	Photoelectric	18981826
0025	Smoke Detector	7TH FL EAST TOWER A ATTORNEY SMALL SECTION	Photoelectric	18981837
0026	Smoke Detector	7TH FL EAST TOWER A US ATTORNEY SMALL SECTION	Photoelectric	18981838
0027	Smoke Detector	7TH FL EAST TOWER A ELEV LOBBY	Photoelectric	18981814
0029	Smoke Detector	7TH FL EAST TOWER A OUTSIDE STAIR 1	Photoelectric	18981823
0030	Smoke Detector	7TH FL EAST TOWER A BY ELEC RM	Photoelectric	18981821
0031	Smoke Detector	7TH FL EAST TOWER A BY RESTROOMS	Photoelectric	18981822
0032	Smoke Detector	7TH FL EAST TOWER A BY STAIR 2	Photoelectric	18981819
0033	Smoke Detector	7TH FL EAST TOWER A INSIDE STAIR 2 TO PENTHOUSE	Photoelectric	18981829
0035	Smoke Detector	PENTHOUSE EAST TOWER A OPEN SPACE	Photoelectric	18981832
0036	Smoke Detector	PENTHOUSE EAST TOWER A ELEV MACH RM	Photoelectric	18981830
0128	Pull Station	4TH FL EAST TOWER A BY STAIR 1	Dual Action	18981894
0129	Pull Station	4TH FL EAST TOWER A BY STAIR 2	Dual Action	18981906
0130	Pull Station	5TH FL EAST TOWER A BY STAIR 1	Dual Action	18981888
0133	Pull Station	5TH FL EAST TOWER A BY STAIR 2	Dual Action	18981883
0134	Pull Station	6TH FL EAST TOWER A BY STAIR 1	Dual Action	18981872
0137	Pull Station	6TH FL EAST TOWER A US ATTNBY ELEV LOBBY	Dual Action	18981841
0139	Pull Station	6TH FL EAST TOWER A BY STAIR 2	Dual Action	18981864
0140	Pull Station	7TH FL EAST TOWER A BY STAIR 1	Dual Action	18981824
0143	Pull Station	7TH FL EAST TOWER A BY PENT STAIR 2	Dual Action	18981818
0153	Pull Station	6TH FL EAST TOWER A BY STAIR 1 O/S ATTORNEY	Dual Action	18981845