



Non-Water-Based Fire Suppression System Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Bernstein Shur

Installation address: 100 Middle St CBL: _____

Exact location: (within structure) Records storage room - West Tower
5th Floor

Type of occupancy(s) (NFPA & ICC): Light Hazard

Building owner: Bernstein Shur

Managing Supervisor: ^{designer} Chad Lane License No: NICET 132825

Supervisor phone: Paul Doughty 482-2343 E-mail: pdaught@simplexgrinnell.com

Installing contractor: Simplex Grinnell License No: 1019

Contractor phone: 207-842-6440 E-mail: pdaught@simplexgrinnell.com

The suppression work to be done will be: New: Renovation: Addition to existing system:

This is an amendment to an existing permit: Yes: NO: Permit no: _____

System Type: Inergen

NFPA Standard: 2001 & 72 Edition: 2006

*Non-NFPA systems are not approved for use within the City of Portland.

Download a new copy of this document from www.portlandmaine.gov/fire for every submittal. Attach all working documents as required on electronic PDF's in addition to full sized plans.

COST OF WORK: \$31,079
PERMIT FEE: \$330.00
(\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)
Contact Wendy Hall
for payment with
credit card:
207-482-2350

Submit all information to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).

Applicant signature: Paul A. Doughty Date: 7-5-13