Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 10/14/14

BLAKE BUILDING

DIRECT VET MARKETING

3RD FLOOR INTERIOR RENOVATIONS

7 CUSTOM HOUSE ST.
PORTLAND, ME 04101

PERMIT SET
SEPTEMBER 2, 2014

BUILDING IS PROTECTED WITH AN AUTOMATIC SPRINKLER SYSTEM

SQUARE FOOTAGES ARE:
3RD FLOOR TOTAL 10,825 SQFT (BUSINESS)
RENOVATED OFFICE SPACE - 5,134 SQFT

MAXIMUM COMMON PATH DISTANCE NOT TO EXCEED 100FT
PROPOSED DISTANCE: 99'-2"

MAXIMUM TRAVEL DISTANCE NOT TO EXCEED 300 FT
PROPOSED DISTANCE: 122'-1"

FIRE ALARM SYSTEM REQUIRED
INITIATION OF ALARM TO BE BY MEANS OF SPRINKLER SYSTEM

MAX TRAVEL DISTANCE TO FIRE EXTINGUISHERS IS 56FT.

OWNER:
OLYMPIA EQUITY INVESTORS
7 CUSTOM HOUSE ST.
PORTLAND, ME 04101
207-874-9990

DRAWING LIST

ARCHITECTURALS

A0.0 - COVER SHEET

D1.0 - DEMO FLOOR PLAN

A1.0 - FLOOR PLAN

LS1.0 - LIFE SAFETY
LS2.0 - SPRINKLER PLAN