



OVERHANGS	FOUR STOP SCHEDULE
UP TO 5"	15
5" TO 6"	16
6" TO 7"	14
OVER 7"	STRUC. STEEL

**THIRD FLOOR FRAMING PLAN**

SCALE: 1/8" = 1'-0"

**NOTES:**  
 1. FLOOR IS 4" (3000 PSI) NORMAL WEIGHT CONCRETE SLAB w/6x6 M1.4xM1.4 MWR ON 1 1/2" LOK-FLOOR 20 GAUGE GALVANIZED COMPOSITE STEEL DECK. DECK MUST EXTEND OVER A MINIMUM OF (3) SPANS (TYP.)  
 2. TOP OF SLAB = 45'-10 1/2"  
 3. TOP OF STEEL = 45'-6 1/2" (UNLESS NOTED AS +/- FROM THIS ELEVATION ON PLAN)  
 4. [XX] INDICATES NUMBER OF 3/4" x 3" SHEAR STUDS (FU = 60KSI) WELDED TO BEAM THROUGH COMPOSITE DECK  
 5. DESIGN REACTIONS FOR COMPOSITE BEAMS HAVE BEEN INDICATED AT VARIOUS LOCATIONS ON PLAN. THE STRUCTURAL STEEL FABRICATOR MUST DESIGN THE BEAM FOR THE GREATER OF THE FOLLOWING:  
 a. REACTION INDICATED ON PLAN  
 b. MAXIMUM REACTION BASED ON UNIFORM LOAD CAPACITY OF BEAM AT GIVEN SPAN PER AISC ASD 9TH EDITION

6. SEE COLUMN SCHEDULE ON SHEET S41 FOR STRUCTURAL STEEL COLUMN DETAILING.  
 7. \* 4 \* DESIGNATES MOMENT CONNECTION. STRUCTURAL STEEL FABRICATOR MUST PROVIDE A CERTIFIED CONNECTION DESIGN BY AN ENGINEER LICENSED IN THE STATE OF MAINE TO MEET THE DESIGN MOMENT CONNECTION VALUES NOTED AS [XXX] FT-LB ON PLAN. SAID MOMENT CONNECTION DESIGN MUST NOT EXCEED 10% OF THE REQUIRED DESIGN VALUE.  
 8. SEE SHEET S01 FOR STRUCTURAL GENERAL NOTES.  
 → SEE Δ ITEM #15

**NOT FOR CONSTRUCTION**  
05/26/06

ISSUE: 05/26/2006 - ISSUED FOR PRICING

**CUSTOM HOUSE SQUARE**  
300 FORE STREET  
PORTLAND, MAINE  
THIRD FLOOR FRAMING PLAN

PROJECT ARCHITECT:  
MW  
DRAWN BY:  
BR, AC, SO  
PROJECT #:  
300506

**S2.3**