

**Report of Standard Test Method  
For Penetration Resistance of Hardened Concrete  
ASTM C803**

Project No: 05-0079.2 Project Name: Custom House Square

Client: Olympia Equity Investors IV b LLC Date: 1/23/2007

Date	Test Location	Aggregate (in.)	Mohs Value	Concrete Age (Days)	Probe Height (in.)	Indicated Strength (psi)
1/23/07	Wall @ 1/C +20'	¾	6	64	1.80	3800
1/23/07	Wall @ 1/between E&F	¾	6	64	1.90	4200
1/23/07	Wall @ 2.5/between F&G	¾	6	64	1.85	4600

Comments: Penetration tests were performed at high power.

SWC Representative: Dale Rickards

Reviewed By: Roger Domingo