

•
•
•
•
•
•
•

389 Congress St.rm 315
Portland, ME 04101
Phone: (207)874-8700
Fax: (207)874-8716

facsimile transmittal

To: Michael Czarnieki **From:** Mike Nugent

Fax: 947-4628 **Date:** July 16, 2004

Phone **Pages:** 1

Re: 57 Commercial St. (029 K003)

Urgent For Review Please Comment Please Reply Please Recycle



I have commenced the review of the above project. Sr. Planner, Bill Needleman advises that the final permit cannot be issued until they have finally signed off.
Here are my comments/Questions:

- 1) Several pages of the plans are not stamped.
- 2) Page AE301 The Stair width and Guard heights scale differently than the details.
- 3) Please provide a fire rates assembly penetration protection detail for the pneumatic tube system
- 4) Attached is page three of our certification forms, please complete, I'm looking for structural loads for the new stair and lobby area.
- 5) J8 on page AE402 show a handrail on one side of the Stairs only must be on both.
- 6) A8 on page AE402 window within the guard height on the stairway must be Safety Glazing.

A statement of Special Inspections is required for the Stair Steel and Sprayed on Fire resistance materials.

• • • • •