

**LEGEND**

- ALL DEVICES, FIXTURES, ETC. SHALL BE NEW UNLESS DESIGNATED WITH THE FOLLOWING TAGS.
- E EXISTING TO REMAIN
  - ER EXISTING REPLACED
  - NR NEW TO REPLACE EXISTING IN EXISTING LOCATION
  - R EXISTING TO BE REMOVED
  - RR REMOVE & RELOCATE EXISTING
  - NIGHT LIGHT
  - FLUORESCENT FIXTURE - UPPER CASE LETTER IS TYPE, LOWER CASE LETTER IS SWITCH CONTROL GROUP - RECTANGLE LETTER INDICATE NUMBER FIXTURES IN A ROOM
  - CEILING MOUNTED FIXTURE - NOTES SAME AS ABOVE
  - CEILING MOUNTED EXIT SIGN - ARROW INDICATES DIRECTIONAL ARROW ON SIGN
  - MALL MOUNTED EXIT SIGN - ARROW INDICATES DIRECTIONAL ARROW ON SIGN
  - EMERGENCY LIGHTING BATTERY BATTERY PACK WITH EMERGENCY LAMP AS SHOWN
  - EMERGENCY LIGHTING BATTERY BATTERY PACK WITH EMERGENCY LAMP AS SHOWN
  - REMOVE EMERGENCY LAMP LIGHT FIXTURES
  - THREE-WAY TOGGLE SWITCH - NOTES SAME AS SPST SWITCH ABOVE
  - DIMMER SWITCH - NOTES SAME AS SPST SWITCH ABOVE
  - FOUR-WAY TOGGLE SWITCH - NOTES SAME AS SPST SWITCH ABOVE
  - MALL KEY SWITCH - NOTES SAME AS ABOVE
  - PILOT LIGHT SWITCH - NOTES SAME AS ABOVE
  - 20 AMP DUPLEX CONVENIENCE RECEPTACLE - MOUNT AT 18" A.F.F. TO CENTER UNLESS INDICATED OTHERWISE - "U" INDICATES 48" TO CENTER A.F.F., "6F" INDICATES GROUND FAULT DEVICE, "6" INDICATES GFI PROTECTED BY UPSTREAM DEVICE, "MP" INDICATES WEATHERPROOF, "6" INDICATES INSULATED/ISOLATED GROUND, "C" INDICATES CEILING MOUNTED, "F" INDICATES FLOOR MOUNTED
  - 20 AMP GROUNDABLE (DOUBLE DUPLEX) - NOTES SAME AS ABOVE
  - SPECIAL PURPOSE OUTLET OR EQUIPMENT CONNECTION - COORDINATE LOCATION AND TYPE OF CONNECTION WITH EQUIPMENT BEING SERVED.
  - JUNCTION BOX WITH COVER
  - MOTOR - SIZE AS INDICATED - COORDINATE W/ ACTUAL EQUIPMENT BEING SERVED
  - MANUAL STARTER - COORDINATE WITH EQUIPMENT BEING SERVED
  - SINGLE THROW FUSED DISCONNECT SWITCH - NEMA ENCLOSURE AS REQUIRED
  - REMOVED CONTROL MAGNETIC STARTER - COORDINATE W/ EQUIPMENT BEING SERVED
  - GROUND
  - BRANCH CIRCUIT RUN IN CEILING OR IN WALLS
  - LOW VOLTAGE OR CONTROL WIRING - #12 MINIMUM OR AS NOTED
  - MULTI-CONDUCTOR BRANCH CIRCUIT - NUMBER OF HASHMARKS IS NUMBER OF WIRES (NOT INCLUDING GROUND WIRE) - WITH/OUT HASHMARKS IS TWO WIRE
  - HOMERUN TO CIRCUIT AND PANEL INDICATED - NUMBER OF ARROWS IS NUMBER OF PHASE WIRES - NUMBER OF WIRES AS INDICATED ABOVE
  - CONTINUATION OF CIRCUIT
  - DIRECTIONAL ARROW
  - PANELBOARD - SEE PANELBOARD SCHEDULE(S)
  - COMBINATION VOICE/DATA JACK - "V" INDICATES NUMBER OF VOICE LINES, "D" INDICATES NUMBER OF DATA LINES, PROVIDE (1) EACH UNLESS NOTED OTHERWISE - "U" INDICATES 48" TO CENTER A.F.F.
  - VOICE JACK - NOTES SAME AS VOICE/DATA JACK ABOVE - "W" INDICATES WALL PHONE, (1) VOICE LINE ONLY
  - DATA JACK - NOTES SAME AS VOICE/DATA JACK ABOVE
  - TELEVISION JACK - NOTES SAME AS RECEPTACLES
  - RECESSED FLOOR OR CEILING MOUNTED BOX - POWER & COMMUNICATIONS AS SHOWN-"F" INDICATES FLOOR MOUNTED, "C" INDICATES CEILING MOUNTED - NOTES SAME AS VOICE/DATA JACK ABOVE
  - MALL MOUNTED CLOCK
  - CEILING SPEAKER (SOUND OR INTERCOM SYSTEM AS SHOWN)
  - MALL SPEAKER (SOUND OR INTERCOM SYSTEM AS SHOWN)
  - FIRE ALARM VISUAL DEVICE WITH CANDELLA RATING AS NOTED
  - FIRE ALARM SYSTEM CONTROL PANEL
  - FIRE ALARM ANNUNCIATOR
  - FIRE ALARM SYSTEM CEILING MOUNTED HEAT DETECTOR
  - FIRE ALARM SYSTEM CEILING MOUNTED SMOKE DETECTOR
  - FIRE ALARM SYSTEM DUCT MOUNTED SMOKE DETECTOR
  - MALL MOUNTED FIRE ALARM SYSTEM MANUAL PULL STATION
  - FIRE ALARM SYSTEM WALL MOUNTED AUDIO/VISUAL DEVICE WITH VISUAL DEVICE CANDELLA RATING AS NOTED
  - FIRE ALARM SYSTEM CEILING MOUNTED SMOKE DETECTOR WITH ELEVATOR RECALL RELAY
  - FIRE ALARM SYSTEM/SPRINKLER SYSTEM PRESSURE SWITCH
  - FIRE ALARM SYSTEM/SPRINKLER SYSTEM FLOW SWITCH
  - FIRE ALARM SYSTEM/SPRINKLER SYSTEM TAMPER SWITCH
  - CEILING MOUNTED OCCUPANCY SENSOR
  - PARTIAL CIRCUIT
  - WEATHER PROOF
  - OWNER SUPPLIED & OWNER INSTALLED ITEM
  - HANDICAP ELECTRICALLY-ASSISTED DOOR OPENER PUSHBUTTON
  - INTERCOM SYSTEM CONTROL PANEL
  - FIRE ALARM SYSTEM POWER EXTENDER
  - PHOTO CELL

**ABBREVIATIONS**

- A AMPERES
- AFF ABOVE FINISHED FLOOR
- A55 ABOVE FINISHED GRADE
- AUTOMATIC TRANSFER SWITCH
- BATTERY
- BANGOR HYDRO ELECTRIC CO.
- BREAKER
- BUILDING
- CB CIRCUIT BREAKER
- CKT CIRCUIT
- CLG CEILING
- COMP CENTRAL MAINE POWER CO.
- CT CURRENT TRANSFORMER
- DM DRAWING
- EMERG EMERGENCY
- EMT ELECTRICAL METALLIC TUBING
- EQUIP EQUIPMENT
- FA FIRE ALARM ANNUNCIATOR
- FAC FIRE ALARM CONTROL PANEL
- FIN FINISH, FINISHED
- FLOOR
- HP HORSEPOWER, HEAT PUMP
- GND GROUND
- IB JUNCTION BOX
- KVA KILOVOLTS AMPS
- KG KILOGRAMS
- LG LIGHTING
- MAX MAXIMUM
- MIN MINIMUM
- N ON CENTER
- PVC POLYVINYL CHLORIDE
- RECEP RECEPTACLE
- TEL TELEPHONE
- TRP TYPICAL
- UG UNDERGROUND
- V VOLTS
- M MATS
- MIR MIRROR
- MP WEATHERPROOF

**LIGHT FIXTURE SCHEDULE**

TYPE	DESCRIPTION	SIZE	MANUFACTURER CAT. NO.	LAMPS	BALLASTS	VOLT.	NOTES
A	CEILING RECESSED	2 X 4	COOPER OVATION	1-1 LAMP	3-54W T5	277	ELECTRONIC T5 BALLASTS
B	PENDANT	55mm	BLANK MINI-LIGHT 220050MC	1-50M MH GLASS	-	277	NO SUB
C	SURFACE MOUNT	10"	PRESCOLITE	BUSHED ALUM CLINDER	2-26W	277	MOUNT LIGHTS @ 8" AFF WITH PENDANT
D	CEILING SURFACE	4' L	COLUMBIA	ACRYLIC GUAD TUBE	2-32W T8	277	MOUNT LIGHTS @ 8" AFF WITH PENDANT
F	UNDERCOUNTER	3' L	COLUMBIA	WHITE PRISMATIC	1-25W T8	120	
G	CEILING RECESSED	3' L	W36-125-EB0120-M6M	ACRYLIC	1-25W T8	277	MOUNT LIGHTS @ 8" AFF WITH CABLE
H	CEILING RECESSED	6"	COOPER PORTFOLIO	OPEN	3-26W	277	MOUNT LIGHTS @ 8" AFF WITH CABLE
J	CEILING PENDANT NMTD	8"	COOPER CORRELITE	TRIPL TUBE	4-54W T5	277	MOUNT LIGHTS @ 8" AFF WITH CABLE
K	CEILING RECESSED	2 X 4	LITHONIA	ACRYLIC	2-32W T8	277	GYPSUM WALL BOARD CEILING
L	CEILING RECESSED	2 X 4	25P F B 2 32 A12 277 GEB	ACRYLIC PRISMATIC	2-32W T8	277	
M	CEILING PENDANT NMTD	34"	SHARPER	WHITE ACRYLIC	4 (MINIMUM)	277	MOUNT LIGHTS @ 15" AFF WITH PENDANT
M	DIRECT/INDIRECT FLUOR	444-34-CF0/26-27755B-CC-XX'0A	SHARPER	WHITE ACRYLIC	2	277	MOUNT LIGHTS @ 4" AFF WITH PENDANT
M	CEILING PENDANT NMTD	22"	444-22-CF0/26-27755B-CC-XX'0A	WHITE ACRYLIC	4-F26TT	277	MOUNT LIGHTS @ 4" AFF WITH PENDANT
N	DIRECT/INDIRECT	-	KIM	POLYCARB	1-175M	277	NARROW DOWNLIGHT OPTICS
P	SURFACE STRIP	4'	COLUMBIA	NONE	2-26W T8	277	
Q	CEILING RECESSED	6"	PRESCOLITE	GUAD TUBE	2-26W T8	277	
S	WALL MOUNTED	4" X 10"	SHARPER	WHITE ACRYLIC	1-F26TT	277	OWNER SUPPLIED, ELECTRICAL CONTRACTOR TO INSTALL
T	SURFACE MOUNTED	-	693/4-5-CF1/26-277-CC-X	POLYCARB	LED	-	
U	OPEN/CLOSED SIGN	-	-	-	-	-	
V	EMERGENCY EXIT SIGN	-	DUAL LITE	BUSHED FACE LED	-	277	
V	EMERGENCY LIGHT	-	PROSCOLITE	WHITE	12W	-	

**WBRC ARCHITECTS • ENGINEERS**  
 44 Central Street  
 Bangor, Maine 04401  
 Tel: (207) 947-4311  
 Fax: (207) 947-4328

**BANGOR SAVINGS BANK**  
 FORE STREET  
 PORTLAND, MAINE

PROJECT TITLE:  
**LEGEND, ABBREVIATIONS, & LIGHT FIXTURE SCHEDULE**

SCALE: NTS  
 DATE: --

PROJECT MANAGER: MLC  
 JOB CAP/OWNER: PCB  
 N/E OF RECORD: RLR  
 SHEET NO.: E-001

PROJECT NO.: 2747.69  
 W88C CAD 024769-E-001

REV. DESCRIPTION DATE

0

ISSUED FOR CONSTRUCTION 06-11-04

CURRENT ISSUE STATUS:

