



NOTE:
 1. SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.

- KEYED NOTE:**
- ① 8-ZONE LIGHTING CONTROLLER - CONTROLLER SHALL BE WALL MOUNTED @ 8'-0" AFF TO CENTER AND SHALL BE EQUAL TO ETC, CAT. NO. ERM8-TC. REFER TO DETAIL A9/E-501 FOR ADDITIONAL INFORMATION.
 - ② LOW VOLTAGE SWITCH CONNECTED TO LIGHTING CONTROL SYSTEM - REFER TO DETAIL A9/E-501 FOR ADDITIONAL WIRING INFORMATION.
 - ③ OCCUPANCY SENSOR CONNECTED TO LIGHTING CONTROL SYSTEM - REFER TO DETAIL A9/E-501 FOR ADDITIONAL WIRING INFORMATION.
 - ④ 500W CENTRAL LIGHTING INVERTER FOR LOBBY EMERGENCY LIGHTING - INVERTER SHALL BE MOUNTED HIGH ON WALL (12" BELOW CEILING TO TOP). INVERTER SHALL BE EQUAL TO DUAL LITE, CAT. NO. DLS-525-277-B2003U.
 - ⑤ INTENT IS FOR NEW LIGHT FIXTURE TO BE INSTALLED IN THE SAME LOCATION AS EXISTING FIXTURE. FIELD COORDINATE EXACT LOCATION.

NO.	DATE	DESCRIPTION
0	02.13.18	ISSUED FOR CONSTRUCTION

ISSUED FOR CONSTRUCTION
 02.13.18

SMRT Architects and Engineers
 144 Fore Street
 Portland, Maine 04104
 1.877.700.7678
 www.smrtinc.com

TAC Architectural Group Inc.
 40 Summer St., Suite 4 Bangor, ME 04401

PROJECT NORTH:

BANGOR SAVINGS BANK - RENOVATIONS TO 280 FORE STREET PORTLAND, MAINE

PROJECT NO: 17231
 CAD DWG FILE: EL102-17231
 DRAWN BY: LJW
 CHK'D BY: LJW
 COPYRIGHT: 2018

SECOND FLOOR LIGHTING PLAN PHASE 1

EL102

SECOND FLOOR LIGHTING PLAN - PHASE 1
 1/8" = 1'-0" (A1)