



NOTE:
 1. SEE SHEET M-001 FOR THE LEGEND AND ABBREVIATIONS.

KEYNOTES

KEYNOTE NUMBER	KEYNOTE DESCRIPTION
1	CONNECT EXISTING 1-1/4" SUPPLY AND RETURN BASEBOARD RADIATION PIPING TO CREATE SINGLE ZONE FOR CONFERENCE ROOM 111.
2	3/4" HWS & HWR - DROP. RECONNECT TO CONFERENCE ROOM 111 RADIANT ZONE. BALANCE CONFERENCE ROOM 111 ZONE TO 1.8 GPM. SEE DETAIL G1/M502.
3	1-1/4" HWS & HWR - DROP. RECONNECT TO EXISTING BASEBOARD AND BALANCE TO 10 GPM. SEE DETAIL G1/M502.

NO.	DATE	DESCRIPTION
0	02.13.18	ISSUED FOR CONSTRUCTION

ISSUED FOR CONSTRUCTION
 02.13.18

SMRT Architects and Engineers
 144 Fore Street
 Portland, Maine 04104
 1.877.700.7678
 www.smrtinc.com

ARCHITECTURE | ENGINEERING | PLANNING | INTERIORS | ENERGY **SMRT**

TAC Architectural Group Inc.
 40 Summer St., Suite 4 Bangor, ME 04401

PROJECT NORTH:

BANGOR SAVINGS BANK - RENOVATIONS TO 280 FORE STREET PORTLAND, MAINE

PROJECT NO: 17231
 CAD DWG FILE: MP101-17231
 DRAWN BY: ASM
 CHK'D BY: MJC
 COPYRIGHT: 2018

SHEET TITLE
FIRST FLOOR MECHANICAL PIPING PLAN - PHASE 1

MP101

A1 FIRST FLOOR MECHANICAL PIPING PLAN
 1/8" = 1'-0"