



PO Box 2551
2257 West Broadway
South Portland, ME 04106

1.800.370.3473
fax 207.879.0540

www.norrisinc.com

August 7th, 2019

Mancini Electric
179 Sheridan Street
Portland, ME 04101

Subject: 280 Fore Street, Portland ME 04101

To Whom it may concern,

As requested, I am writing to confirm the fire alarm system for the above mentioned subject, was inspected and tested and at the time of inspection the system was found to be operational and to the best of our knowledge, met or exceeded all of the requirements as established by the plans and specifications for the project and all applicable codes including NFPA 72.

It was a pleasure working with you on this project. Should you have any questions or need additional information please do not hesitate to contact me.

Sincerely,

Jeremy Todd

Jeremy Todd
Service Manager



Advancing security, life safety, and communications.

SYSTEM RECORD OF COMPLETION

Form Completion Date: 7/31/19 Supplemental Pages Attached: 0

1. PROPERTY INFORMATION

Name of property: Bangor Savings Bank
Address: 280 Fore St. Portland, ME
Description of property: Bank/offices
Name of property representative: N/A
Address: N/A
Phone: N/A Fax: N/A E-mail: N/A

2. INSTALLATION, SERVICE, TESTING, AND MONITORING INFORMATION

Installation contractor: Mancini Electric
Address: 179 Sheridan St. Portland, ME 04101
Phone: 207-774-5829 Fax: N/A E-mail: N/A
Service organization: Norris, Inc
Address: 2257 West Broadway South Portland, ME
Phone: 800-370-3473 Fax: N/A E-mail: www.norrisinc.com
Testing organization: N/A
Address: N/A
Phone: N/A Fax: N/A E-mail: N/A
Effective date for test and inspection contract: N/A
Monitoring organization: HSMC
Address: N/A
Phone: 1-800-933-4762 Fax: N/A E-mail: N/A
Account number: 202-8259 Phone line 1: N/A Phone line 2: N/A
Means of transmission: Digital Communicator
Entity to which alarms are retransmitted: Portland FD Phone: 207-874-8576

3. DOCUMENTATION

On-site location of the required record documents and site-specific software: N/A

4. DESCRIPTION OF SYSTEM OR SERVICE

This is a: [] New system [X] Modification to existing system Permit number: N/A
NFPA 72 edition: N/A

4.1 Control Unit

Manufacturer: Notifier Model number: AFP-200

4.2 Software and Firmware

Firmware revision number: N/A

4.3 Alarm Verification

[X] This system does not incorporate alarm verification.

Number of devices subject to alarm verification: Alarm verification set for seconds



Advancing security, life safety, and communications.

SYSTEM RECORD OF COMPLETION (continued)

5. SYSTEM POWER

5.1 Control Unit

5.1.1 Primary Power

Input voltage of control panel: 120 VAC Control panel amps: 3
 Overcurrent protection: Type: Circuit Breaker Amps: 20
 Branch circuit disconnecting means location: N/A Number: N/A

5.1.2 Secondary Power

Type of secondary power: Batteries
 Location, if remote from the plant: In FACP
 Calculated capacity of secondary power to drive the system:
 In standby mode (hours): 24 In alarm mode (minutes): 5

5.2 Control Unit

- This system does not have power extender panels
- Power extender panels are listed on supplementary sheet A

6. CIRCUITS AND PATHWAYS

Pathway Type	Dual Media Pathway	Separate Pathway	Class	Survivability Level
Signaling Line	1	N/A	B	N/A
Device Power	N/A	N/A	N/A	N/A
Initiating Device	N/A	N/A	N/A	N/A
Notification Appliance	1	N/A	B	N/A
Other (specify):	N/A	N/A	N/A	N/A

7. REMOTE ANNUNCIATORS

Type	Location
N/A	N/A
N/A	N/A

8. INITIATING DEVICES

Type	Quantity	Addressable or Conventional	Alarm or Supervisory	Sensing Technology
Manual Pull Stations	N/A	N/A	N/A	N/A
Smoke Detectors	9	Addressable	Alarm	Photoelectric
Duct Smoke Detectors	N/A	N/A	N/A	N/A
Heat Detectors	N/A	N/A	N/A	N/A
Gas Detectors	N/A	N/A	N/A	N/A
Waterflow Switches	N/A	N/A	N/A	N/A
Tamper Switches	N/A	N/A	N/A	N/A



Advancing security, life safety, and communications.

SYSTEM RECORD OF COMPLETION (continued)

9. NOTIFICATION APPLIANCES

Table with 3 columns: Type, Quantity, Description. Rows include Audible, Visible, and Combination Audible and Visible.

10. SYSTEM CONTROL FUNCTIONS

Table with 2 columns: Type, Quantity. Rows include Hold-Open Door Releasing Devices, HVAC Shutdown, Fire/Smoke Dampers, Door Unlocking, Elevator Recall, and Elevator Shunt Trip.

11. INTERCONNECTED SYSTEMS

- Checkboxes for 'This system does not have interconnected systems' and 'Interconnected systems are listed on supplementary sheet'.

12. CERTIFICATION AND APPROVALS

12.1 System Installation Contractor

This system as specified herein has been installed according to all NFPA standards cited herein.

Signed: [Signature] Printed name: Craig Beardsley Date: 7/31/19
Organization: Mancini Electric Title: Electrician Phone: 207-774-5829

12.2 System Operational Test

This system as specified herein has tested according to all NFPA standards cited herein.

Signed: [Signature] Printed name: Wade Morin Date: 7/31/19
Organization: Norris, Inc Title: Technician Phone: 800-370-3473

12.3 Acceptance Test

Date and time of acceptance test:
Installing contractor representative:
Testing contractor representative: Wade Morin
Property representative: N/A
AHJ representative: N/A