

## DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK

# CITY OF PORTLAND



This is to certify that OLD PORT HOSPITALITY LLC

Job ID: 2011-03-708-UI


Located At 231 FORE ST

CBL: 029 - - L - 001 - 001 - - - - -

has permission to InstallYork Roof Tops Modcon Boiler and mechanical systems

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.



Fire Prevention Officer

Code Enforcement Officer / Plan Reviewen

THIS CA**RD MUST BE POSTED ON THE STREET** SIDE OF THE PROPERTY PENALTY FOR REMOVING THIS CARD

## City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, FAX: (207) 8716

Job No: Date App 2011-03-708-UI 3/31/2011 2011-2361-HVAC	lied:	CBL: 029 L - 001 - 00	1	
Location of Construction: Owner N 231 FORE ST (207) OLD POR	ame: T HOSPITALITY LLC	Owner Address: 11 CORPORATE DR BELMONT, NH 03220		Phone: 207-529-7808
Business Name: Contracto CDB Mech	or Name: anical LLC, Craig Bland	Contractor Addr 22 Greenwood Rd.	Phone: (603) 529-7808	
Lessee/Buyer's Name: Phone:		Permit Type: BLDG - HVAC		Zone: B-3
Mixed use – Restaurant & Mixed U	Proposed Use: Mixed Use – restaurant & hotel HVAC York Roof top Boiler		Approved w/ a Denied N/A	CEO District: Inspection: Use Group: R-1 Type: HVTL
Proposed Project Description: 207 Fore St HVAC		Signature: CKPT. Pedestrian Activ	Vities District (P.A.D.)	Signature by by b
Permit Taken By:			Zoning Approva	1
<ol> <li>This permit application does not pre Applicant(s) from meeting applicab Federal Rules.</li> <li>Building Permits do not include plu septic or electrial work.</li> <li>Building permits are void if work is within six (6) months of the date of False informatin may invalidate a bu permit and stop all work.</li> </ol>	clude the Shorela le State and Wetlan mbing, Flood 2 not started Subdiv issuance Site Pla	nds Zone rision	Zoning Appeal Variance Miscellaneous Conditional Use Interpretation Approved Denied Date:	Historic Preservation Not in Dist or Landmark Does not Require Review Requires Review Approved Approved w/Conditions Denied Date.
			Date:	Juc.

#### CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the appication is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE



Strengthening a Remarkable City, Building a Community for Life . www.portlandmaine.gov

Director of Planning and Urban Development Penny St. Louis

Job ID: 2011-03-708-UI

Located At: 231 FORE

CBL: <u>029 - - L - 001 - 001 - - - - -</u>

## **Conditions of Approval:**

#### Zoning

- 1. This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.
- 2. This permit is being issued with the condition that the noise level must meet the criteria of section 14-221.1(b) not exceeding the maximum allowable decibel level.

## Fire

- 1. Installation shall comply with City Code Chapter 10.
- 2. NFPA 91, Standard for Exhaust Systems for Air Conveying Vapors, Gases, Mists, and Noncombustible Particulate Solids;
- 3. NFPA 70, National Electrical Code; and the manufacturer's published instructions.
- 4. NFPA 54, National Fuel Gas Code;
- 5. NFPA 90A, Standard for the Installation of Air-Conditioning and Ventilating Systems,

## **Building**

- 1. The installation must comply with the State of Maine gas regulations.
- 2. Installation shall comply with the 2003 International Mechanical Code Section 607 for smoke or fire dampers or combination F/S dampers including actuation and access panels.
- 3. The ComCheck certificate of compliance for energy efficiency shall be submitted to this office.

## BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 or 874-8693 (ONLY) or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- 1. Close in inspections
- 2. Final at completion of work

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCU0PIED.



#### FILL IN AND SIGN WITH INK

## APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

_		

29-1-001

## To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL <u>207-209-211 FOREST</u> Name and address of owner of appliance <u>0115 Poet</u> A	Use of Building <u>Commercial</u> Date <u>31.1/11</u> Hos pile liky
Installer's name and address <u>CDB</u> MECHANICA 22 Greenwood Road Weare NH	103201 Telephone 613-529-7808
Location of appliance: Basement Attic Roof	Type of Chimney: Masonry Lined Factory built <u>Factory INStaller</u>
Type of Fuel: Gas Doil Solid	Metal Factory Built U.L. Listing #
Appliance Name: YORK - ROOF-TOPS. U.L. Approved A Yes D No MODCON Borley	Direct Vent Type <u>PVC</u> UL#VED
Will appliance be installed in accordance with the manufacture's installation instructions? Xes INO	Type of Fuel Tank Oil Gas MAR 3 1 2011 Dispections
IF <u>NO</u> Explain:	Gas Dept. of Building Inspections Size of Tank City of Portland Maine
The Type of License of Installer:	Number of Tanks
Master Plumber #     Solid Fuel #     Oil #     Gas #     Other	Distance from Tank to Center of Flame feet. Cost of Work: Algo, CDD Permit Fee: \$
Approved	Approved with Conditions
Fire:	See attached letter or requirement
Bldg.:	Inspector's Signature Date Approved

Yellow - File

White - Inspection

Pink - Applicant's

Gold - Assessor's Copy



FILL IN AND SIGN WITH INK

## APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

11.1	 

29-1-001

## To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

ocation / CBL 207-209-211 Ford ST	Use of Building DateDate		
ame and address of owner of appliance			
70			
staller's name and address MEChani	at the Cruig Bland.		
22 Greenwood Road Weave N	4 03781 Telephone 725-7808		
and the second s			
ocation of appliance:	Type of Chimney:		
Basement Floor	Masonry Lined		
Attic Roof	Factory built		
pe of Fuel:	Metal		
Gas Oil Solid	Factory Built U.L. Listing #		
ppliance Name: YARK - Root - TOPS	Direct Vent		
L. Approved I Yes I No Madrow Barley	Type UL#		
ill appliance be installed in accordance with the manufacture's	Type of Fuel Tank		
stallation instructions? I Yes I No			
	Gas		
NO Explain:			
	Size of Tank		
he Type of License of Installer:	Number of Tanks		
Master Plumber #			
Solid Fuel #	Distance from Tank to Center of Flame feet.		
• Oil #			
Gas # Gas #	Cost of Work: \$		
• Other	Permit Fee: S		
Approved	Approved with Conditions		
Fire:	See attached letter or requirement		
Ele.:			
Bldg.:	Deter Annual Deter Annual		
	Inspector's Signature Date Approved		
ignature of Installer	Ciara Bland Manager		
White - Inspection Yellow - File	Pink - Applicant's Gold - Assessor's Copy		

From:Jeff Daigneault <jeffd@opechee.com>To:"'amachado@portlandmaine.gov'' <amachado@portlandmaine.gov>, 'NicholasAd..CC:Tim Daigneault <timd@opechee.com>Date:5/23/2011 11:16 AMSubject:Sound reading.pdfAttachments:Sound reading.pdf

Ann, Here is the report from the sound tests, any question please call Thanks

Jeff Daigneault Project Manager

[cid:782011015@23052011-275E]

Opechee Construction Corporation 11 Corporate Drive Belmont, NH 03220 C (603) 848-9575

jeffd@opechee.com<mailto:jeffd@opechee.com>

# RECEIVED

MAY 2 3 2011

Dept. of Building Inspections City of Portland Maine



MECHANICAL

22 Greenwood Road Weare, NH 03281 (603)529-7808 phone (603)529-5201 Fax CdbMechanical@aol.com

DATE:

Opechee Construction 11 Corporate Drive Belmont, NH

Attn: Tim Diagneault, Jeff Diagneault

From: Craig Bland

RE: Noise Level recorded Portland Mixed use building

The Noise level measured with at the boundries of Lot 207,209,211 Fore Street with Roof top equipment running on the Lower Roof was recorded at 51 decibels pre construction hours. 5:30 am, Within the zones . Readings taken at 10:00 PM – 48.6 Decibels -- Reading taken with EXtech 407736 Sound level meter. Accuracy +- 1.5 DB IEC 651 ANSI s1.4 Type 2

THANK YOU CRAIG BLAND



MAY 2 3 2011

Dept. of Building Inspections City of Portland Maine