KITCHEN EXHAUST FAN EF-KH

DRYER EXHAUST W/ RAIN HOOD FOR DWELLING UNITS (TYP. FOR 12)

EF-1
EF-2
EF-3

RTU-11
RTU-12

EF-4
EF-5
EF-6
EF-7

RTU-9
MAU-RG2
RTU-10

EF-8
EF-9
EF-10

LINEN CHUTE VENT

MAU-HC

PROVIDE ELEVATOR SHAFT VENTILATION W/ MOTORIZED DAMPER INTERCONNECTED W/ LOBBY SMOKE DETECTION

EF-16

RTU-6

EF-20 EF-21

R.T.U. (TYP.)

EF-11
EF-12

EF-14 EF-15

RTU-7

EF-17

EF-18 EF-19

MAU-RG1

RTU-5

RTU-8

EF-13

GAS FLUE FOR TANKLESS HOT WATER HEATERS FOR DWELLING UNITS (TYP. FOR 12)

V.T.R. (TYP.)

EF-22 EF-23

DWELLING UNIT EXHAUST FAN TERMINATION (TYP.)

EF-24 EF-25

RTU-3

RTU-4

EF-26 EF-27

EF-28 EF-29

FRESH AIR INTAKE FOR GUESTROOMS (TYP.)

RTU-2

EF-32 EF-33

RTU-1

EF-30 EF-31

PROVIDE ELEVATOR SHAFT VENTILATION W/ MOTORIZED DAMPER INTERCONNECTED W/ LOBBY SMOKE DETECTION

N

PLAN

REVISION SCHEDULE

DATE	REVISION DESCRIPTION	BY

OPECHEE
CONSTRUCTION CORPORATION
11 CORPORATE DRIVE, BELMONT NH 03220
PHONE (603)527-9090 FAX (603)527-9191

ROOF HVAC PLAN

PROJECT:

Hotel, Restaurant, & Portside Residences

Portland ME

DATE: 08-18-10
SCALE: 1/8"= 1'-0"
DRAWN BY: dwd

SHEET: M7

© COPYRIGHT 2010 BY O.C.C.