



5/20/2015

Guest Room Renovations
Hampton Inn Downtown
209 Fore St.
Portland, ME 04101

To whom it may concern:

Nortech Systems has been contracted to modify the fire alarm system associated with the conversion of the 2nd floor conference room into three guest rooms.

The fire alarm was modified per the plans submitted to the City of Portland during the permit application process. The modifications include adding smoke and CO detection as well as notification appliances.

The resulting installation is in compliance with NFPA 70-2014, NFPA 72-2013, NFPA101-2012 and applicable local and state codes.

The modified components have been tested for proper operation.

Respectfully Submitted,

Mark Richards

A handwritten signature in black ink, appearing to read "Mark Richards", is written over the printed name.

President
NICET Level IV #132174