



Caitlin Cameron <ccameron@portlandmaine.gov>

203 Fore Street

Keith Gray <kgray@portlandmaine.gov>

Fri, Jan 5, 2018 at 3:30 PM

To: Caitlin Cameron <ccameron@portlandmaine.gov>

Cc: "Swett, Lauren" <lswett@woodardcurran.com>, "Errico, Thomas" <thomas.errico@tylin.com>, Bradley Roland <brad@portlandmaine.gov>

Hello Caitlin,

The following initial comment is in reference to the Level III Site Plan application for [203 Fore Street](#).

- We have concerns with the proposed parking deck being located over the existing utility easement. In addition to maintenance clearance concerns, the deck corner support would be very close to the existing SD-2 stormdrain. Provide additional information on clearance, deck support footprint and/or stormdrain relocation.

Please let me know if you have any questions.

Thank you,
Keith

--

Keith D. Gray, PE
Senior Engineer
Dept. of Public Works
City of Portland Maine

[207.874.8834](tel:207.874.8834)
kgray@portlandmaine.gov